

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2014/W2/926

Dated: 24/07/2014

FIRE SAFETY CERTIFICATE

Certified that **A P J International School, Main Jagat Pur Road, Wazirabad, Delhi-110084** earlier known as **A P J Convent School** comprised of **Ground floor** owned/occupied by **A P J International School** has already been issued fire safety certificate vide letter no. **letter No F-6/DFS/MS/2008/1688 dated 19/06/2008** The premises was re-inspected by the officer from this department on **07/07/2014** in the presence of **Sh. Chawal Singh (Manager)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular No 262-362 dated 17/01/2005** issued by Director of Education / NBC- Part IV and verified by the officer concerned of Fire Service and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **24/07/2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 24/07/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, A P J International School, Main Jagat Pur Road, Wazirabad, Delhi- 84
2. The Director of Education, Old Secretariat, Delhi

N/2

INSPECTION REPORT

1. Name & address of the building : APJ International School, Main Jagatpur Road, Wazirabad, Delhi-84 Educational
2. Type of Occupancy : Educational
3. Type of Case : ~~New Case~~ / Renewal
4. Details of previous NOC : F-6/DFS/ms/2008/1688 dt-19-6-08
5. Fire Safety directives letter No : circular of the director of Edn.
6. Date of inspection : 07-7-14 (G.F.) ✓
7. Name of the Inspecting Officers : N.P. Sharma
8. Name and designation of officers from the building side : Sr. Charan Singh (manager)
9. Year of Construction : 2008
10. Applicant's letter No. : - dt 06-6-14

Plot area- 1000 Sqds Covered area- 400 Sqds No's of student- 120 No's of class room- 08

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	b. Width of staircases	-	-	-
	• Upper Floors	-	-	-
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	1 mtr	MR ✓
3	Compartmentation.	N/A		
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4	Smoke Management System.	N/A		
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-

6. Date of inspection : 07-1-14 (G.F.)
 7. Name of the Inspecting Officers : N.P. Sharma
 8. Name and designation of officers from the building side : Sh. Charwel Singh (manager)
 9. Year of Construction : 2008
 10. Applicant's letter No. : - dt 06-6-14
 Plot area- 1000 sqds Covered area- 400 sqds No's of student- 120 No's of class room- 08

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible	Accessible	MR ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	<ul style="list-style-type: none"> Upper Floors Basements 	-	-	-
	b. Width of staircases	-	-	-
	<ul style="list-style-type: none"> Upper Floors Basements 	-	-	-
	c. Protection of exits	-	-	-
	<ul style="list-style-type: none"> Fire check door Pressurization 	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	1 mtr	1 mtr	MR ✓
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-	-	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	-	-
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	one @ 30 Smith 03 ISI marked	03 ABC yes	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.			
		N/A		

N/3

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One at each floor 30 m 5 mm	—	—	—
7	Automatic fire detection and alarming system. N/A				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	—	—	—	—
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System. N/A				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	—	—	—	—
11	Internal Hydrants N/A				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	—	—	—	—
12	Yard Hydrants. N/A				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	—	—	—	—
13	Pumping Arrangements. N/A				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	—	—	—	—
14	Captive Water Storage for fire fighting. N/A				
	<ul style="list-style-type: none"> Underground tank capacity 	—	—	—	—

	• Hooters' Location			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.	NIA		
	• Basement			
	• Upper Floor			
	• Sprinkler above false ceiling			
11	Internal Hydrants	NIA		
	• Size of riser/down-comer			
	• Number of hydrants per floor			
	• Hose Box			
12	Yard Hydrants.	NIA		
	• Total number of hydrants			
	• Hose Box			
13	Pumping Arrangements.	NIA		
	• Ground Level			
	➤ Discharge of main Pump			
	➤ Head of Main pump			
	➤ Number of main pumps			
	➤ Jockey Pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/ Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power Supply			
	➤ Auto Starting of pump			
14	Captive Water Storage for fire fighting.	NIA		
	• Underground tank capacity			
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity			
15	Exit Signage.			

N/A

16	Provision of Lifts.	N/A		
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	—	—	—
18	Refuge Area.			
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room			
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

x- Ser. Earlier FSC was issued in the name of APJ Convent school, main jagat bus road wazirabad, Delhi, SN, Now as per APPROVANT the name is changed as APJ International School. The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DPSP/MS/2008/1688 dated 19-6-08 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Signature of the Inspecting Officer

Name N.P. Sharma

Designation ADD R.

DOPM

9/7/14
20/11/14

Signature of the Inspecting Officer

Name

Designation