

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2014/W2/906

Dated: 22/07/2014

FIRE SAFETY CERTIFICATE

Certified that the M/S Asian Paints Ltd. at Khasra No. 111/6 & 111/15, Phirni Road, Mundka, New Delhi-110041 comprised of Ground Floor only owned / occupied by M/S Asian Paints Ltd. was earlier issued Fire Safety Certificate Vide Letter No.F6/DFS/MS/2011/1194 Dated 13.06.2011. The premises was re-inspected by the officer concerned of Fire Service on 05.07.2014 in the presence of Sh. Ravinder Kumar (Comm. Officer) and observed that Fire prevention and fire safety arrangements provided in the premises, found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the building / premises is fit for occupancy class **Storage (Group-H)** with effect from 22 / 07 / 2014 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 22/07/14 at New Delhi by.


(SANTOKH SINGH),
CHIEF FIRE OFFICER.
Phone:-23414250

Copy to :-

1. Sh. Dipanjan Nath, Asian Paints Ltd., Khasra No. 111/6 & 111/15, Phirni Road, Mundka, New Delhi-110041.
2. Administrative Officer, N.D.M.C., Narela Zone, Narela, Delhi-110040.

N/11
INSPECTION REPORT

1. Name & address of the building: **Asian Paints, Khasra No. 111/6, 111/15,
Phirni Road, Mundka, New Delhi-41.**
2. Type of Occupancy : **Storage (Group 'H')**
3. Type of Case : **Renewal**
4. Details of previous NOC : Letter No. **F6/DFS/MS/2011/1194 dated 13/6/2011**
5. Fire Safety directives Letter No. : **NBC (Part-IV)**
6. Date of inspection : **05/07/2014**
7. Name of the Inspecting Officer : **Ashok Kumar Jaiswal (A.D.O. Jwala Puri)**
8. Name and designation of Officer
from the building side : **Ravinder Kuamr (Comm. Officer)**
9. Year of Construction : **2011**
10. Applicant's letter No. : **Nil dated 20/06/2014**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE / NBC-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr.	12 Mtr. ✓	MR
	• Gate width	5 Mtr.	5 Mtr. ✓	MR
	• Width of internal road	3 Mtr.	3 Mtr. ✓	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NR	NR	NR
	• Basements	NR	NR	NR
	Width of staircases			
	• Upper floors	NR	NR	NR
	• Basements	NR	NR	NR
	Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	b. No of continuous staircase to terrace	NA	NA	NA
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	Old Case	Old Case ✓	Old Case
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	No Basement	NA	NA

6. Date of inspection : 05/07/2014
7. Name of the Inspecting Officer : Ashok Kumar Jaiswal (A.D.O. Jwala Puri)
8. Name and designation of Officer
from the building side : Ravinder Kuamr (Comm. Officer)
9. Year of Construction : 2011

10. Applicant's letter No. : Nil dated 20/06/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE / NBC-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 Mtr.	12 Mtr. ✓	MR
	• Gate width	5 Mtr.	5 Mtr. ✓	MR
	• Width of internal road	3 Mtr.	3 Mtr. ✓	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	NR	NR	NR
	• Basements	NR	NR	NR
	Width of staircases			
	• Upper floors	NR	NR	NR
	• Basements	NR	NR	NR
	Protection of exits			
	• Fire check door	NR	NR	NR
	• Pressurization	NR	NR	NR
	b. No of continuous staircase to terrace	NA	NA	NA
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	Old Case	Old Case ✓	Old Case
3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	No Basement	NA	NA
	• Upper floors / GF	Exhaust Fan	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	12	25	MR
	• Types	ABC /Co ₂ /Foam	Provided	MR
	• IS marking	ISI Marked	Provided	MR

N/12

6.	First – Aid Hose Reels			
	• Total numbers on each floor	3	10 ✓	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke / Beam	Beam ✓	MR
	• Location of Main Panel	GF	Provided ✓	MR
	• Location of Repeater Panel	GF	Provided ✓	MR
	• Alternate source of power	Required	Provided ✓	MR
	• Hooters' Location	GF	Provided ✓	MR
8.	MOEFA	NR	NR	NR
9.	Public Address System	Required	Provided ✓	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor / GF	Required	Provided ✓	MR
	• Sprinkler above false ceiling	NR	NP	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided ✓	MR
	• Number of hydrants per floor	5	Provided ✓	MR
	• Hose Box	5	Provided ✓	MR
12.	Yard Hydrants			
	• Total number of hydrants	5	10	MR
	• Hose Box	5	10	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 LPM	2280 LPM ✓	MR
	➤ Head of main pump	65 MH	65 MH ✓	MR
	➤ Number of main pumps	2	2	MR
	➤ Jockey pump out put	220 LPM	220 LPM ✓	MR
	➤ Jockey pump head	65 MH	65 MH	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM ✓	MR
	➤ Standby Pump Head	65 MH	65 MH	MR
	➤ Auto Staring/Manual stopping	Required	Provided ✓	MR
	➤ Pump House Access	Required	Provided ✓	MR
	• Terrace level			
	➤ Discharge of pump	NR	NR	NR
	➤ Head of the pump	NR	NR	NR

	• Type of detector	Smoke / Beam	Beam	MR
	• Location of Main Panel	GF	Provided ✓	MR
	• Location of Repeater Panel	GF	Provided ✓	MR
	• Alternate source of power	Required	Provided ✓	MR
	• Hooters' Location	GF	Provided ✓	MR
8.	MOEFA	NR	NR	NR
9.	Public Address System	Required	Provided ✓	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor / GF	Required	Provided ✓	MR
	• Sprinkler above false ceiling	NR	NP	NR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided ✓	MR
	• Number of hydrants per floor	5	Provided ✓	MR
	• Hose Box	5	Provided ✓	MR
12.	Yard Hydrants			
	• Total number of hydrants	5	10	MR
	• Hose Box	5	10	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 LPM	2280 LPM ✓	MR
	➤ Head of main pump	65 MH	65 MH ✓	MR
	➤ Number of main pumps	2	2	MR
	➤ Jockey pump out put	220 LPM	220 LPM ✓	MR
	➤ Jockey pump head	65 MH	65 MH	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM ✓	MR
	➤ Standby Pump Head	65 MH	65 MH	MR
	➤ Auto Starting/Manual stopping	Required	Provided ✓	MR
	➤ Pump House Access	Required	Provided ✓	MR
	• Terrace level			
	➤ Discharge of pump	NR	NR	NR
	➤ Head of the pump	NR	NR	NR
	➤ Power supply	NR	NR	NR
	➤ Auto starting of pump	NR	NR	NR
14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	50,000 Ltr.	50,000 Ltr. ✓	MR
	➤ Draw of connection	NR	NP	NR
	➤ Fire service inlet	NR	Provided ✓	NR
	➤ Access to tank	Required	Provided ✓	MR
	• Overhead Tank capacity	10,000Ltr.	Provided ✓	MR

N/13

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Batter backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/2011/1194 dated 13/06/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Ashok Kumar Jaiswal
5/7/14

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : A.D.O. (Jwala Puri)

D.O. / (co) *[Signature]*
2/7