

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/EH/2014/W2/917

Dated: 24/07/14

FIRE SAFETY CERTIFICATE

Certified that the M/s Atlantic Restaurants (A Unit of M/s Ravi Kishore Enterprises), located at Shop No. 1 (Rest. No. 1), First Floor, Plot No. G - 3, Cascade Shopping Centre, Netaji Subhash Place, New Delhi - 110034 was issued FSC vide Letter No. F6/DFS/MS/2011/EH/1422 dated 04-07-2011 in a building comprised of G + 1 Upper Floor. The premises was re inspected by the officers concerned of this department on 01-07-2014 in the presence of Mr. Ravinder Bhatia (Partner) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D with effect from 24/07/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 24/07/14 at New Delhi by.


(Santokh Singh)
Chief Fire Officer,
Ph: 011 - 23414250.

Copy to:

1. Deputy Health Officer (Rohini Zone),
Public Health Department (NDMC),
Sector - V, Delhi - 110085.
2. Sh. Ravinder Bhatia,
No. 1, G - 3, Cascade Shopping Centre,
Netaji Subhash Place, Pitampura, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Atlantic Restaurant (A Unit of M/s Ravi Kishor Enterprises), First Floor, No. 1, G - 3, Cascade Shopping Centre, Netaji Subhash Place, Pitampura, Delhi - 110034.
2. Type of Occupancy : Assembly (G + 1 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2011/EH/1422 dated 04-07-2011
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 01-07-2014
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Ravinder Bhatia (Partner)
9. Year of Construction : 2005
10. Applicant's letter No. : Nil dated 17-06-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	4	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	Old Case
3.	Compartmentation			
	• Fire check door	Required in Kitchen	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR

3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2011/EH/1422 dated 04-07-2011
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 01-07-2014
7. Name of the Inspecting Officer : DO (West) & ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Ravinder Bhatia (Partner)
9. Year of Construction : 2005
10. Applicant's letter No. : Nil dated 17-06-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 m	Provided	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	4	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old Case	Old Case	Old Case
3.	Compartmentation			
	• Fire check door	Required in Kitchen	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR
5.	Fire Extinguishers			

M/S

6.	• Total numbers	10 nos.	Provided	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
	First Aid Hose Reels			
7.	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	6.5 mm	Provided	MR
8.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	First Floor	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
9.	• Hooters' Location	Required	Provided	MR
	MOEFA	Required	Provided	MR
10.	Public Address System	Required	Provided	MR
11.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
12.	• Sprinkler above false ceiling	Required	Provided	MR
	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
13.	• Hose Box	NA	NA	NA
	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
14.	• Hose Box	NA	NA	NA
	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• Auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access			
	• Terrace level	450 lpm. 180	Provided	MR
	• Discharge of pump	lpm		
• Head of the pump	40 m	Provided	MR	
• Power supply				

	• Nozzle diameter	6.5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	First Floor	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants:			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• Auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access			
	• Terrace level	450 lpm. 180	Provided	MR
	• Discharge of pump	lpm		
	• Head of the pump	40 m	Provided	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	• Draw off connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	Provided	MR
	• Overhead Tank capacity	5000 litres	Provided	MR

M4

15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DPS/MS/2011/EH/1422 dated 04-07-2011-renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

MUKESH VERMA

Name

Designation

ADO (MN)

Designation

DO (West) 2/7