

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

E-mail:- [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in)

Fax:- 011-23412593

No. F.6/DFS/MS/GH/2014/ 1402/930

Dated: 24/07/14

**FIRE SAFETY CERTIFICATE**

Certified that the **Hotel Singh Sons** located at 7A/10-11, WEA, Karol Bagh, New Delhi-110005 is comprised of Basement, ground floor plus three upper floors, using basement as storage, ground floor as reception, office & 03 guest rooms, first, second & third floor each having 12 guest rooms respectively (Total 39 guest rooms) and a pantry with staff room on terrace was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2011/2140 dated 02.09.2011 owned/occupied by Sh. Amarjeet Singh. The guest house building was re- inspected by the officer concerned of this department on 16.07.2014 in the presence of Sh. Jaiveer (Manager) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for 39 guest rooms occupancy Group 'A' residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....24/07/14.....at New Delhi.

  
(DR. G.C. MISRA)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Ph:- 011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.)  
1<sup>st</sup> floor, P.S., Defence Colony, New Delhi.  
(Re. No. 24338/Joint C.P./Lic.(H), Dated 07.07.2014)
2. Sh. Amarjeet Singh (Owner),  
Hotel Singh Sons, 7A/10-11, WEA,  
Karol Bagh, New Delhi-110005.

a/c @

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

## INSPECTION REPORT

1. Name & address of the building : Hotel Singh Sons, 7A/10-11, WEA, Karol Bagh, N.D-05.
2. Type of Occupancy : Residential (Guest House )
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/GH/2011/2140 dated 02.09.2011
5. Fire Safety directives letter No : N/A
6. Date of inspection : 16.07.2014
7. Name of Inspecting Officer : Dy. C.F.O Rajesh Panwar
8. Name and designation of officers  
From the building side : Sh. Jaiveer (Manager)
9. Year of Construction : 2004-2005
10. Applicant's letter No. : 24338/Joint. C.P/Lic (H) dated 07.07.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site special area	Remarks MR/NMR
1.	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible — —	06 mtr — —	M/R — —
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	One Two	One Two	M/R, Old Case M/R,
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	125 cms 125 cms	125 cms 125 cms, 90 cms	M/R, Old Case M/R, Old Case
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	One	One	M/R
	f. Door Size	—	135cm, 255 cm	—
		N/A	80cm X 204 cm	N/A
3.	<b>Compartmentation</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	N/A — N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A — N/A N/A N/A
4.	<b>Smoke Management System</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	Exhaust Fans are provided Natural Ventilation	M/R M/R
5.	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	Two at each floor Water Co2, ABC ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	<b>First-Aid Hose Reels</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	One 30 m 5 mm	Provided Provided Provided	M/R M/R M/R

7.	<b>Automatic fire detection and alarming system</b>			
	• Type of detectors	N/A	N/A	NA M/R
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	D.G set of 125 KVA	M/R
	• Hooters' Location	N/A	N/A	N/A
8.	<b>MOEFA</b>	Required	Provided	M/R
9.	<b>Public Address System</b>	Required	Provided	M/R
10.	<b>Automatic Sprinkler System</b>			
	• Basement	Required	Provided	M/R
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	<b>Yard Hydrants</b>			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	<b>Pumping Arrangements</b>			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 LPM	450 LPM	M/R, Old Case
	➤ Head of the pump	30 M	30 M	M/R, Old Case
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	<b>Captive Water Storage for fire fighting</b>			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	M/R
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15000 ltr	5000 ltr	M/R, Old Case
		Required	Provided	M/R
15.	<b>Exit Signage.</b>			
16.	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	M/R
	• Fireman's Grounding Switch	Required	Provided	M/R
	• Lift Signage	Required	Provided	M/R

17.	<b>Standby power supply</b>	Required	Provided	M/R
18.	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	Required	Provided	M/R
	• Building Floor Plans	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2011/2140 dated 02.09.2011 renewal under rule 35 of Delhi Fire Service Rules 2010 is recommended.

Signature of Inspecting Officer

Name:- Rajesh Panwar

Designation:- Dy. C.F.O (NDZ)

Signature of Inspecting Officer

Name

Designation