

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID:cfohq.dlfire@nic.in


No F6/DFS/MS/2014/ *EH/MO2/919*

Dated *24/07/14*

FIRE SAFETY CERTIFICATE

Certified that the **McDonald's Family Restaurant** located at **42, Janpath, New Delhi** comprises of Ground floor was granted NOC by this department vide letter No. F6/DFS/MS/2011/EH/964 dated 24-05-2011. The premises was re-inspected by the officers concerned of this department on 09-07-2014 in the presence of Mr. DN Thakur and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy **Class Group D Assembly Building** with effect from ~~24/07/2014~~ *24/07/2014* for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on *24/07/14*..... at New Delhi by.



(Dr. G. C. Misra)
Chief Fire Officer
Delhi fire Service
Ph - 011-23414333

Dr. G. C. Misra

Copy to:-

1. Mr. DN Thakur McDonald's Family Restaurant located at 42, Janpath, New Delhi.
2. Medical officer of Health, Health Department, Palika Kendra, New Delhi - 110001
No.MOH/D/233/DSO (Lic.)/SI-1 dated 20/05/2014.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

- 1. Name & address of the building : McDonald's Family Restaurant located at 42, Janpath, New Delhi.
- 2. Type of Occupancy : Assembly Building Gr.+2 floor (Restaurant) at Ground floor
- 3. Type of Case : Renewal
- 4. Details of previous NOC : F6/DFS/MS/2011/EH/964 dated 24/05/2011
- 5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 09/07/2014
- 7 Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Mr. DN Thakur
- 9. Year of Construction : old Bldg.
- 10. Applicant's letter No. : No. MOH/246/D/CMO (Lic.)/SI-V dated 03/06/2014

Old Case

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks
1.	Access of building			MR/NMR
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<ul style="list-style-type: none"> 9 Mtr. NA NA 	<ul style="list-style-type: none"> 12 Mtr. NA NA 	<ul style="list-style-type: none"> MR NA NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA

h
Mark

N/8

	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.0 Mtr.	1.70 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors (Ground floor)	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	4 Nos.	6 Nos.	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA

h

Mewr

11	Internal Hydrants			
	• Size of riser/down- comer	NA	100 MM	NA
	• Number of hydrants per floor	NA	01	NA
	• Hose Box	NA	01	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level			
	• Discharge of pump	450 & 220 LPM	450 & 220 LPM	MR
	• Head of the pump	30 Mtr.	30 Mtr.	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
		NA	NA	NA
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	5000 Ltr.	5,000 I tr.	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts	NA	NA	NA


4

Mark

N/10

	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/EH/964 dated 24/05/2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended please.



Name :- Sh. Gurmukh Singh
Designation :-DO(CD)

(Handwritten signature)

(Handwritten signature)
9/7/14

Name:- Sh. M. K. Sharma
Designation :- A. D.O. (CC)