

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. FG/DFS/MS/EH/2014/M02/897

Dated: 22/07/14

FIRE SAFETY CERTIFICATE

Certified that the Mirror Restaurant running at F -32 ,34 & 37,First floor of a building comprised of basement, ground plus two upper floors named Star City Mall, Mayur Vihar Phase-1, Delhi, owned/occupied by M/s Mirror Restrobar & Lounge Pvt.Ltd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 21.06.2014 in the presence of Sh.Arun Tomar (Director) and found that the building is fit for occupancy Group -D Assembly building (Restaurant) with effect from 22/07/14. for a period of three years in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed overleaf.

Issued on.....22/07/14.....at New Delhi by



(Dr.G.C.Misra)
Chief Fire Officer
Ph.011-23414333

To,
The Dy.Health Officer
East Delhi Municipal Corporation
Health Department, Karkardooma,
South Zone, Shahdara, Delhi.

Copy to:-
M/s Mirror Restrobar & Lounge Pvt.Ltd.,
F -32 ,34 & 37,First floor
Star City Mall, Mayur Vihar Phase-1, Delhi,

ok f

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction/ unauthorized use of land if any.
6. All comments/ directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"

1. Name & address of the building : Mirror Restaurant at F-32,34 &37,FF,Star City Mall , Plot No.1A,District Centre,Mayur Vihar -1,Delhi.
2. Building Comprised of : Basement,ground plus two upper floors
3. Type of Occupancy : Assembly
4. Type of Case : New
5. Details of Previous FSC : N/A
6. Fire Safety directives No : F.6/DFS/MS/BP/2004/1969 Dated: 30.08.2004 for Mall
7. Date of Inspection : 21.06.2014
8. Name of the Inspecting Officer : DO Virendra Singh & ADO Suresh Singh
9. Name of the designation of Officer
From the building side : Sh.Arun Tomar (Director)
10. Year of Construction : 2007
11. Applicant's letter No : DHO/Sh.(S) Zone/2014/456 dated 10.06.2014

	Minimum Standards on fire prevention and fire safety U/R33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtrs	13 Mtrs.	MR
	• Gate width	4.5 Mtrs.	6 Mtrs.	MR
	• Width of internal road	6 Mtrs.	6 Mtrs.	MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2 Nos.	2 Nos.	MR
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper Floor	1.25 M	1.25 M	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	Required	Provided	MR
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	2.5 M	2.5 M	MR
	h. Door Size	2.0 Mtrs.	2.0 M	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire rating of shaft door	2 hrs.	2 hrs	MR
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basement	N/A	N/A	N/A
	• Upper floor	12 a/c per hour	12 a/c per hour	MR
5.	Fire Extinguisher			
	• Total numbers	6 Nos.	6 Nos.	MR
	• Types	ABC & Co2 type	ABC & Co2 type	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-aid-Hose Reels.			
	• Total numbers of each floor	1 no.	1 no.	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Heat or smoke	Heat & smoke	MR
	• Location of main panel	control room	basement	MR
	• Location of repeater panel	Reception	Provided	MR
	• Alternate source of power supply	Required	Provided	MR
	• Hooters's location	Strategic Locations	Provided	MR

8	MOEFA	Required	Provided	MR
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	Required	provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of wet riser	100 mm	150 mm	MR
	• Number of hydrants per floor	1 no.	1 no.	MR
	• Hose Box	1 no.	1 no.	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level		For Mall	
	➤ Discharge of main Pump	4500 LPM	4500 LPM	MR
	➤ Head of Main Pump	50 mtrs	50 mtrs	MR
	➤ Number of main pumps	2 nos.	2 nos.	MR
	➤ Jockey pump out put	450 LPM	450 LPM	MR
	➤ Jockey pump head	50 mtrs.	50 mtrs.	MR
	➤ Standby pump out put	4500 LPM	4500 LPM	MR
	➤ Standby pump Head	50 Mtrs.	50 Mtrs.	MR
	➤ Auto Starting /Manual stopping	Required	Auto	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace Level	All above	pumps on	terrace
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.		For Mall	
	• Underground tank capacity	2,00,000 Ltrs	2,00,000 Ltrs.	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	2,50,000 Ltrs.	2,50,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided for basement	MR
	• Communication in lift car	Required	Provided	MR
	• Firemen's grounding switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	Required	Provided	MR
	• Flow switch panel	Required	Provided	MR
	• PA system panel	Required	Provided	MR
	• Battery backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A

