

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001


No. F6/DFS/MS/EH/2014/M02/914

Dated: 22/07/14

FIRE SAFETY CERTIFICATE

Certified that M/S **Moti Mahal Restaurent**, located at **3704, Netaji Subash Marg, Darya Ganj, New Delhi-02**, comprised of Ground floor only having seating capacity of 100 persons, was granted NOC by this department vide letter No. F6/DFS/MS/EH/2011/1647, dated 19-07-2011. The premises was re-inspected by the officer concerned of this department on 17-07-2014 in the presence of Sh. Vinod Chadha (Owner) and found that the said restaurant building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Restaurant** (Assembly) at ground floor only with effect from 22/07/2014 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 22/07/14 at New Delhi by.



(Dr.G.C.M isra)
Chief Fire Officer
T.No.011-23414333



Copy to:-

1. The Dy. Health Officer, Health Deptt. North MCD, Civic Centre, New Delhi.
- 2 M/S Moti Mahal Restaurent, 3704, Netaji Subash Marg, Darya Ganj, New Delhi-02.

Conditions for the validity of fire safety certificate are overleaf:-

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. The employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All fire fighting equipments shall be maintained in perfect working condition all time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate, six month prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : M/S Moti Mahal Restaurant, 3704, Netaji Subash Marg,
Darya Ganj, New Delhi-02.
2. Building is comprised of : Ground floor only 100 seats.
3. Type of Occupancy : Assembly.
4. Type of Case : Old Case
5. Details of Previous NOC : No.F.6/DFS/MS/EH/2011/1647, dated-19.07.11.
6. Fire Safety direction letter No : Nil.
7. Date of Inspection : 17.07.2014
8. Name of the Inspecting Officers: : Vedpal (ADO)
9. Name and designation of Officer
from the building side : Sh. Vinod Chadha(Owner)
10. Year of Construction : 1947.
11. Applicant's letter No : No.Nil, dated 02.07.14.

S.No	Minimum Standards on fire prevention and fire safety U/R33	Old NOC Requirements	Provided at Site	Remarks
1	Access to building			
	Road width	6m	24 m	MR
	Gate width	N.A.	N.A.	N.A.
	Width of internal road	N.A.	N.A.	N.A.
2	Number, Width, Type and Arrangement of Exits.			
a. Number of Staircases Upper Floor Basement B. Width of Staircases Upper Floor Basement c. Protection of exits Fire check door Pressurization e. No. of continuous staircases to terrace g. Width of Corridor h. Door Size		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		N.A.	N.A.	N.A.
		1.5m	169 & 92cm	MR
	3	Compartmentation		
	Fire check door	N.A.	N.A.	N.A.
	Sealing of electrical shafts	N.A.	N.A.	N.A.
	Fire rating of shaft door	N.A.	N.A.	N.A.
	Water curtain	N.A.	N.A.	N.A.
	Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	Basement	30a/c per hour	N.A.	N.A.
	Upper floor	12 a/c per hour	Required	Provided

N/4

5.	Fire Extinguisher			
	Total numbers	02 nos.	08 nos.	MR
	types	CO ₂ & ABC	CO ₂ & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers on each floor	01no.	01no.	MR
	Length of hose reel hose	30m.	30m.	MR
	Nozzle diameter	5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Heat & Smoke	Heat & Smoke	MR
	Location of main panel	Reception	Reception	MR
	Location of repeater panel	N.A.	N.A.	N.A.
	Alternate source of power	Required	Provided	MR
	Hooters	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	Basement	N.A.	N.A.	N.A.
	upper floor	N.A.	N.A.	N.A.
	sprinkler above false ceiling	N.A.	N.A.	N.A.
11	Internal Hydrants			
	size of riser/down-comer	100mm	100mm	MR
	Number of hydrants per floor	01no.	01no.	MR
	Hose Box	01no.	10no.	MR
12	Yard Hydrants.			
	Total number of hydrants	N.A.	N.A.	N.A.
	Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level	01no.	01no with +ve Suction	MR
	➤ Discharge of main Pump	450LPM	450LPM	MR
	➤ Head of Main Pump	40m	40m	MR
	➤ Number of main pumps	01no.	01no.	MR
	➤ Jockey pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby pump out put	N.A.	N.A.	N.A.
	➤ Standby pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting /Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access	N.A.	N.A.	N.A.
	• Terrace Level	N.A.	N.A.	N.A.
	➤ Discharge of pump	N.A.	N.A.	N.A.
	➤ Head of the Pump	N.A.	N.A.	N.A.
	➤ Power supply	N.A.	N.A.	N.A.
	➤ Auto Starting of pump	Required	Provided	MR
		Required	Provided	MR

[Handwritten signature]

H/S

M/S Moti Mahal Restaurant, 3704, Netaji Subash Marg, Darya Ganj, New Delhi-02

Positive Water Storage for Fire Fighting.				
14	On ground tank capacity	13000liters.	13000liters.	MR
	Draw-off connection	N.A.	N.A.	N.A.
	Fire service inlet	N.A.	N.A.	N.A.
	Access to tank	N.A.	N.A.	N.A.
	Overhead Tank capacity	N.A.	N.A.	N.A.
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	Pressurization of Lift lobby	N.A.	N.A.	N.A.
	Communication in lift car	N.A.	N.A.	N.A.
	Firemen's grounding switch	N.A.	N.A.	N.A.
	Lift Signage	N.A.	N.A.	N.A.
17	Standby power supply	Required	Provided 10Kva Generator set	MR
18	Refuge Area.			
	Total area	N.A.	N.A.	N.A.
	Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	Detector system panel	N.A.	N.A.	N.A.
	Flow switch panel	N.A.	N.A.	N.A.
	PA system panel	N.A.	N.A.	N.A.
	Batter backup	N.A.	N.A.	N.A.
	Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection systems for of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection. In view of the deemed compliance of the minimum standards on fire prevention and fire safety required under the rules the NOC issued vide letter No.F.6/DFS/MS/EH/2011/1647, dated 19.07.2011 renewal under rule 35 of the Delhi Fire Service Rule 2010 is recommended.

Signature of the Inspecting Officer

Name : Vedpal

Designation : ADO

