

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfohq.dfire@nic.in

No. F6/DFS/MS/GH/2014/ *M02/922*

Dated *24/07/14*

**FIRE SAFETY CERTIFICATE**

Certified that the **Naseeb Guest House** located at **3441, Dariba Pan, Pahar Ganj, New Delhi** comprises of Ground floor (03 guest rooms + reception), 1<sup>st</sup> floor (04 guest rooms) and 2<sup>nd</sup> to 3<sup>rd</sup> floor (03 guest rooms at each floor) with total 13 guest rooms was granted NOC by this department vide letter No.F6/MS/DFS/2011/496 dated 16-03-2011. The premises was re-inspected by the officer concerned of this department on 11-07-2014 in the presence of Smt. Satinder Kaur and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 lodging or rooming houses** for 13 guest rooms with effect from *24/07/14*---2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on .....*24/07/14*..... at New Delhi by.

  
(Dr. G. C. Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph - 011-23414333

Copy to:-

1. The Joint. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi - 110049 w.r.t. letter No 24017-18/Joint. C.P./Lic. (H) dated New Delhi 03-07-2014.
2. Smt. Satinder Kaur Naseeb Guest House located at 3441, Dariba Pan, Pahar Ganj, New Delhi.
3. The Commissioner, North Delhi Municipal Corporation with the request to get the height of the building verified under intimation to this department.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

## INSPECTION REPORT

1. Name & address of the building : Naseeb Guest House located at 3441, Dariba Pan, Pahar Ganj, New Delhi.
2. Type of Occupancy : Residential (Guest house) G + 3 floors total guest rooms-13
3. Type of Case : Renewal
4. Details of previous NOC : F6/MS/DFS/2011/496 dated 16/03/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 11/07/2014
- 7 Name of the Inspecting Officer : Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer  
from the building side : Smt. Satinder Kaur (Manager)
- 9 Year of Construction : 2010
10. Applicant's letter No. : 24017-18/Joint.C.P./Lic. (H) dated New Delhi the 3/07/2014.

S No	Minimum standards on fire prevention and fire safety U/R 33	Existing Requirements	Provided at site (PSS)	Remarks MR/NMR
1.	Access of building			
	• Road width	NA	3 Mtr.	MR
	• Gate width	NA	NA	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1 No.	1 No.	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	0.80 Mtr.	1.25 Mtr.	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA

met

M/8

	<ul style="list-style-type: none"> <li>• Pressurization</li> </ul>	NA	NA	NA
	d. No of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width Of Corridor	1.0 Mtr.	1.0 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	10 Nos.	12 Nos.	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	ABC, CO <sub>2</sub> , Wco <sub>2</sub>	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	NA	01	NA
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	NA	NA	NA
8	MOEFA	NA	Provided	NA
9	Public Address System	NA	Provided	NA
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>• Upper floor</li> </ul>	NA	NA	NA

M/8

NA } M/8

MLM

N/9

	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down- comer</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
12	Yard Hydrants			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>Discharge of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Head of main pump</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Number of main pumps</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Jockey pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Jockey pump head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Standby Pump out put</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Standby Pump Head</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>auto Staring/Manual stopping</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Pump House Access</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Terrace level</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Discharge of pump</li> </ul>	NA	180 LPM	NA
	<ul style="list-style-type: none"> <li>Head of the pump</li> </ul>	NA	30 Mtr.	NA
	<ul style="list-style-type: none"> <li>Power supply</li> </ul>	NA	Provided	NA
	<ul style="list-style-type: none"> <li>Auto starting of pump</li> </ul>	NA	Provided	NA
14	Captive water Storage for fire fighting	NA	NA	NA
	<ul style="list-style-type: none"> <li>Under ground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Draw of connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	NA	2500 ltr.	NA
15	Exit Signage	Required	Required	MR

masli

N/10

16	Provision of Lifts	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of lift lobby	NA	NA	NA
	• Communication in lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire control room			
	• Detector system panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC,Co <sub>2</sub>	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/MS/DFS/2011/496 dated 16/03/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended please.

*Merbu*  
Name:- Sh. M. K. Sharma

Designation :- A. D.O. (CC)