

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax : 23412593, E-mail: [cfohq.dlfire@nic.in](mailto:cfohq.dlfire@nic.in), Tel:- 011-23414333

NO.F6/DFS/MS/ *club/2014/52/953*

Dated: *30/07/14*

**FIRE SAFETY CERTIFICATE**

Certified that **Friends Club Ltd. located at 17 A, Friends Colony (West), New Delhi-110065** comprised of basement, ground plus two upper floors was granted Fire Safety Certificate by this department vide letter no. F6/DFS/MS/2011/862 dated 11.05.2011. The premise was re-inspected by the officer concerned of this department on 28-06-2014 in presence of Mr. Pravin Kumar Mehta, General Manager of the club and found that the aforesaid club is running at basement, ground & first floor. Second floor is not in use & is under renovation. The aforesaid club have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy **Class- D Assembly (club)** with effect from *30/07/14* for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on *30/07/14* at New Delhi by.

  
(Dr. G.C. MISRA)  
CHIEF FIRE OFFICER

*9c* 

Copy to: -

1. The Assistant Commissioner (Excise), office of commissioner of Excise, L & N Block, Vikas Bhawan, New Delhi.
2. The General Manager, Friends Club Ltd., 17 A, Friends Colony (West), New Delhi-110065.

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : Friends Club Limited, 17 A, Friends Colony (West), New Delhi-110065
2. Type of Occupancy : Assembly (Club)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/862 dated 11.05.2011
5. Fire Safety directives letter No : Home Deptt. Order No. 4/22/2004/HP-III/356-359 dated 22-03-2005
6. Date of inspection : 28-06-2014
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(M.Rd)
8. Name and designation of officers from the building side : Mr. Pravin Kumar Mehta, General Manager
9. Year of Construction : 1982
10. Applicant's letter No. : nil dated 09-06-2014


Friends club is comprised of basement, ground, first & second floor (not in use & under renovation)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06 mts	Provided	MR
	• Gate width	4.5 mts	Provided	MR
	• Width of internal road	-----	Directly accessible from the road	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	-	-	-
	• Upper Floors	02	Provided (3)	MR
	• Basements	02	Provided (4)	MR
	b. Width of staircases	-	-	-
	• Upper Floors	1.5 mts	1.7 mts, 1.53 mts & 1.15 mts (ground to 1 <sup>st</sup> floor), 0.90 mts (first floor to terrace)	MR(old case)
	• Basement	1.5 mts	1.53, 1.15, 1.04, 0.82 mts	MR(old case)
	c. Protection of exits	---	---	---
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	01	01	MR
	f. Door Size	N/A	N/A	N/A
		N/A	N/A	N/A



3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Exhaust fan provided	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Smoke venting provided in kitchen	N/A
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	35	Provided	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC, CO <sub>2</sub> , W.CO <sub>2</sub>	Provided	MR
	<ul style="list-style-type: none"> <li>• IS Marking</li> </ul>	ISI marked	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	02	Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30 m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	Required	Provided(smoke)	MR
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	Required	Provided (GF)	MR
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	Required	Provided in entire building	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	02	Provided	MR

	• Hose Box	02	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	06	Provided	MR
	• Hose Box	06	Provided	MR
13	<b>Pumping Arrangements.</b>			
	• Ground Level	----	----	-----
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main pump	60 mts	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60 mts	Provided	MR
	➤ Standby Pump out put	2280	Provided	MR
	➤ Standby Pump Head	60 mts	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level	----	-----	-----
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	1,00,000 liters	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 liters	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	Required	Provided	MR




	<ul style="list-style-type: none"> <li>• Fireman's Grounding Switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Lift Signage</li> </ul>	Required	Provided	MR
17	<b>Standby power supply</b>	Required	Provided (125, 250 KVA)	MR
18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Flow Switch Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• PA System Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Batter backup</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Building Floor Plans</li> </ul>	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 CO <sub>2</sub> type fire extinguishers found provided near elect. Panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, the NOC issued vide letter No. F6/DFS/MS/2011/862 dated 11.05.2011, renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

DFA is put up for approval & signature please.

DD (SZ) - CL

  
18/2/14