

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2014 /EH/W2/961

Dated: 30/07/2014

c-16

FIRE SAFETY CERTIFICATE

Certified that Invitation Ceremonial, B-52, G T K Road Indl. Area, Delhi-110033 is Comprised of Ground + Two Upper floors owned / occupied by Invitation Ceremonial has already been issued fire safety certificate vide letter no. F.6/DFS/MS/2011/1739 dated 28/07/2011. The premises was re-inspected by the officers concerned of fire service on 21/06/2014 in the presence of Sh. Subhash and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and building / premises is fit for occupancy Class Sub Div. D-5 Assembly Buildings with effect 30/07/2014 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
2. The fire suppression / protection arrangements provided are to minimize losses, if maintained in good working condition. These systems cannot give a guarantee that there will be no fire or losses in the event of one.
3. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
4. This report may not in any way be treated as regularization of unauthorized construction, if any. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The trained fire fighting staff should be available round the clock.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 30/07/2014 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Dy. Health Officer, Civil Line Zone, Public Health Department, 16, Rajpur Road, Delhi-54.
2. Sh. Subhash Kakkar, Invitation Ceremonial, B-52, G T K Road Indl. Area, Delhi-110033

aca

128

INSPECTION REPORT

1. Name & address of the building : Invitation Ceremonial, B-52, G T K Road Indl. Area, Delhi-110033
2. Type of Occupancy : Assembly Place (Banquet Hall) **G + 2**
3. Type of Case : Renewal ✓
4. Details of previous NOC : F.6/DFS/MS/2011/1739 dated 28/07/2011 ✓
5. Fire Safety directives letter No : NBC / BBL ✓
6. Date of inspection : 21/06/2014 ✓
7. Name of the Inspecting Officers : ADO (N. P. Sharma) ✓
8. Name and designation of officers from the building side : Sh Subhash ✓
9. Year of Construction : 2004 ✓
10. Applicant's letter No. : nil dated 16/06/2014 ✓

S. No	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	02 mtr ✓	P	M/R
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	--	--	--
	• Upper Floors	2	2 ✓	M/R
	• Basements	--	--	--
	b. Width of staircases			
	• Upper Floors	Old Case	Old Case ✓	Old Case
	• Basements	--	--	--
	c. Protection of exits			
	• Fire check door	R	P ✓	M/R
	• Pressurization	N.A.	N.A. ✓	N.A.
	d. No. of continuous staircases to terrace	02	02 ✓	M/R
	e. Width of Corridor	--	--	--
	f. Door Size	2 X 2 mtr	P ✓	M/R

3	Compartmentation.			
	• Fire check door	R	P	M/R
	• Sealing of electrical shafts	R	P	M/R
	• Fire Rating of shaft door	R	P	M/R
	• Water Curtain	N.A.	N.A.	N.A.
	• Fire Dampers	N.A.	N.A.	N.A.
4	Smoke Management System.			
	• Basements	30 a/c per hour	--	--
	• Upper floors	12 a/c per hour	P	M/R
5	Fire Extinguishers			
	• Total numbers	17	P	M/R
	• Types		ABC, CO2 & WCO2	M.R
	• IS marking	ISI marked	Yes	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	One at each floor	P	M/R
	• Length of hose reel hose	30 m	P	M/R
	• Nozzle diameter	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	• Type of detectors	N.R.	P	N.A.
	• Location of Main Panel	--	--	--
	• Location of Repeater Panel	N.A.	N.A.	N.A.
	• Alternate source of power	R	P	M/R
	• Hooters' Location	N.A.	N.A.	N.A.
8	MOEFA	R	P at each floor	M/R
9	Public Address System.	N.A.	N.A.	N.A.
10	Automatic Sprinkler System.			
	• Basement	N.A.	N.A.	N.A.
	• Upper Floor	N.R.	P	N.A.
	• Sprinkler above false ceiling	N.R.	P	N.A.
11	Internal Hydrants			
	• Size of riser/down-comer	R	P	M/R
	• Number of hydrants per floor	01	P	M/R
	• Hose Box	R	P	M/R

12	Yard Hydrants.			
	• Total number of hydrants	N.A.	N.A.	N.A.
	• Hose Box	N.A.	N.A.	N.A.
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N.A.	N.A.	N.A.
	➤ Head of Main pump	N.A.	N.A.	N.A.
	➤ Number of main pumps	N.A.	N.A.	N.A.
	➤ Jockey Pump out put	N.A.	N.A.	N.A.
	➤ Jockey pump head	N.A.	N.A.	N.A.
	➤ Standby Pump out put	N.A.	N.A.	N.A.
	➤ Standby Pump Head	N.A.	N.A.	N.A.
	➤ Auto Starting/ Manual stopping	N.A.	N.A.	N.A.
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	900 LPM	P	M/R
	➤ Head of the pump	40 M	P	M/R
	➤ Power Supply	R	P	M/R
	➤ Auto Starting of pump	R	P	M/R
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw-off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	--	--	--
	• Overhead Tank capacity	15000 ltr	15000 ltr	M/R
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A.	N.A.	N.A.
	• Pressurization of Lift lobby	N.A.	N.A.	N.A.
	• Communication In lift Car	N.A.	N.A.	N.A.
	• Fireman's Grounding Switch	N.A.	N.A.	N.A.
	• Lift Signage	N.A.	N.A.	N.A.

N-0

17	Standby power supply	R	P	M/R
18	Refuge Area.			
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19	Fire Control Room			
	• Detector System Panel	N.A.	N.A.	N.A.
	• Flow Switch Panel	N.A.	N.A.	N.A.
	• PA System Panel	N.A.	N.A.	N.A.
	• Batter backup	N.A.	N.A.	N.A.
	• Building Floor Plans	N.A.	N.A.	N.A.
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F.6/DFS/MS/2011/1739** dated **28/07/2011** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

DOPW

[Signature]
11-7-14

R. Sharma

ADD 'R'

[Signature]
18/7/14

Signature of the Inspecting Officer

Name

Designation

446/Defro (192)