

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/GH/2014/ *MD2/935*

Dated: *28/07/14*

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Western Palace** located at 14A/80, WEA, Karol Bagh, New Delhi-110005 is comprised of Ground floor plus three upper floors, using ground floor as reception, shops & 01 guest rooms, first & second floor each having 07 guest rooms respectively (Total 15 guest rooms) and a pantry with staff room on third floor was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2011/1870 dated 05.08.2011 owned/occupied by Sh. Sarbjeet Singh. The guest house building was re-inspected by the officer concerned of this department on 19.07.2014 in the presence of Sh. Sarbjeet Singh (Owner) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for 15 guest rooms occupancy Group 'A' residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....*28/07/14*.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.)
1st floor, P.S., Defence Colony, New Delhi.
(Re. No. 25223/Joint C.P./Lic.(H), Dated 14.07.2014)
2. Sh. Sarbjeet Singh (Owner),
Hotel Western Palace, 14A/80, WEA,
Karol Bagh, New Delhi-110005.

g.c. Misra

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Hotel Western Palace, 14A/80, WEA, Karol Bagh, N.D-05.
2. Type of Occupancy : Residential (Guest House)
G.F + 03 upper floors, having 15 guest rooms.
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/GH/2011/1870 dated 05.08.2011
5. Fire Safety directives letter No : N/A
6. Date of inspection : 19.07.2014
7. Name of Inspecting Officer : Dy. C.F.O Rajesh Panwar
8. Name and designation of officers
From the building side : Sh. Sarbjeet Singh (Owner)
9. Year of Construction : 2000-2001
10. Applicant's letter No. : 25223/Joint. C.P/Lic (H) dated 14.07.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site special area	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	06 mtr — —	M/R — —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	One —	One —	M/R, Old Case No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	125 cms —	128 cms —	M/R, Old Case No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	One	One	M/R
	e. Width of Corridor	—	130 cm, 115 cm	—
	f. Door Size	N/A	88 cm X 200 cm	N/A
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A — N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A — N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A Natural Ventilation	No Basement M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Two at each floor Water Co2, Co2, ABC ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	N/R 30 m 5 mm	Provided Provided Provided	M/R M/R M/R


7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	Required	D.G set of 05 KVA	M/R
	• Hooters' Location		N/A	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	• Basement	N/A	N/A	No Basement
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual Stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	N/A	450 LPM	M/R
	➤ Head of the pump	N/A	30 M	M/R
	➤ Power Supply	Required	Provided	M/R
	➤ Auto Starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	2500 ltr	M/R
		Required	Provided	M/R
15.	Exit Signage.			
16.	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	No Lift
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

		Required	Provided	M/R
17.	Standby power supply			
18.	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	Required	Provided	M/R
	• Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2011/1870 dated 05.08.2011 renewal under rule 35 of Delhi Fire Service Rules 2010 is recommended.

Signature of Inspecting Officer



Name:- Rajesh Panwar

27/2

Designation:- Dy. C.F.O (NDZ)

Signature of Inspecting Officer

Name

Designation