

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/school/2014/W2/983 Dated: 05/08/2014


FIRE SAFETY CERTIFICATE

Certified that the **M.C.D. School** located at AI, Jawalपुरi, New Delhi-110041, comprised of G+one floor only, owned/occupied by **M.C.D.**, have complied with the fire prevention and fire safety requirements in accordance with director of education circular no. 3298/3398 dated 01-03-2011 and verified by the officer concerned of Fire Service on **28-07-2014** in the presence of **Mr. Sanwarmal** (Principal / evening) and that the building/premises is fit for occupancy class **Educational** occupancy with effect from 05/08/14.....for a period of three years, subject to the conditions mentioned below.

Conditions for the validity of Fire Safety Certificate :

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 6) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in
- 7) "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

Issued on...05/08/14.....at New Delhi by


(Santokh Singh)
Chief Fire Officer
Phone : 011 : 23414250

Copy to:

1. Rajesh Dagar (Principal)

M.C.D. School, AI, Jawalपुरi, New Delhi-110041

o/c
AD

1. Name & address of the building : **M.C.D. School, AI, Jawalपुरi, New Delhi-110041.**
2. Type of Occupancy : **Class –B (Educational)**
3. Type of Case : **New**
4. Details of previous NOC : **Nil**
5. Fire Safety directives letter No. : **DOE circular dated 01-03-2011**
6. Date of inspection : **28/07/2014**
7. Name of the Inspecting Officers : **A.K. Jaiswal A.D.O. (JWP)**
8. Name and designation of officers
From the building side : **Mr. Sanwarmal**
9. Year of Construction : **2008**
10. Applicant's letter No. : **101 dated 07.07.2014**

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	DOE circular dated 01-03-2011 Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Accessible	Accessible ✓	M/R
	• Gate width	Accessible	Accessible ✓	M/R
	• Width of internal road	N/A	N/A	N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	M/R
	• Basement	No basement	N/A	N/A
	b. Width of staircases			
	• Upper Floors	1.50 mtr	1.50 x 01 ✓ 1.40 x 01	M/R
	• Basement	No basement	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	01	Provided	M/R
	e. Width of Corridor	1.50 mtrs.	Provided ✓	M.R.
	f. Door size	1.00 mtr	Provided ✓	M.R.
3.	Compartmentation.			
		N/R	N/R	Not applicable

	<ul style="list-style-type: none"> Water Curtain Fire Dampers 	N/R	N/R	Not applicable
		N/R	N/R	Not applicable
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	N/R	N/R	N/R
		N/R	N/R	N/R
5.	Fire Extinguishers	<i>Handwritten</i>	<i>Handwritten</i>	<i>Handwritten</i>
	<ul style="list-style-type: none"> Total numbers Types IS marking 	05 ISI marked ABC & CO ² type Yes	06 ✓ provided provided	M/R M/R M/R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	N/R N/R N/R	N/R N/R N/R	N/R N/R N/R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	N/R N/R N/R N/R N/R	N/R N/R N/R N/R N/R	N/R N/R N/R N/R N/R
8.	MOEFA	N/R	N/R	N/R
9.	Public Address System.	N/R	N/R	N/R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/R N/R N/R	N/R N/R N/R	N/R N/R N/R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/R N/R N/R	N/R N/R N/R	N/R N/R N/R
12.	Yard Hydrants.			

	• Hose Box	N/R	N/R	N/R
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N/R	N/R	N/R
	➤ Head of Main pump	N/R	N/R	N/R
	➤ Number of main pumps	N/R	N/R	N/R
	➤ Jockey Pump out put	N/R	N/R	N/R
	➤ Jockey pump head	N/R	N/R	N/R
	➤ Standby pump out put	N/R	N/R	N/R
	➤ Standby pump Head	N/R	N/R	N/R
	➤ Auto Starting/Manual stopping	N/R	N/R	N/R
	➤ Pump Hose Access	N/R	N/R	N/R
	Terrace level			
	➤ Discharge of pump	N/R	N/R	N/R
	➤ Head of the pump	N/R	N/R	N/R
	➤ Power supply	N/R	N/R	N/R
	➤ Auto Starting of pump	N/R	N/R	N/R
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N/R	N/R	N/R
	➤ Fire service inlet	N/R	N/R	N/R
	➤ Access to tank	N/R	N/R	N/R
	➤ Overhead Tank Capacity	N/R	N/R	N/R
15	Exit Signage.	N/R	N/R	N/R
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N/R	N/R	N/R
	• Pressurization of Lift lobby	N/R	N/R	N/R
	• Communication In lift Car	N/R	N/R	N/R
	• Fireman's Grounding Switch	N/R	N/R	N/R
	• Lift Signage	N/R	N/R	N/R
17.	Standby power supply	N/R	N/R	N/R
18.	Refuge Area			

N/7

	➤ Location	N/R	N/R	N/R
19.	Fire Control Room			
	➤ Detector System Panel	N/R	N/R	N/R
	➤ Flow Switch Panel	N/R	N/R	N/R
	➤ PA system Panel	N/R	N/R	N/R
	➤ Battery backup	N/R	N/R	N/R
	➤ Building Floor plans	N/R	N/R	N/R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/R	N/R	N/R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010

A.K. Jaiswal
28/7/14

Signature of the Inspecting Officer

Name : A.K. Jaiswal

Designation : ADO (JWP)