

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: cfhq.dlfire@nic.in

No. F6/DFS/MS/GH/2014/ *M02/1986*

Dated *07/08/14*

FIRE SAFETY CERTIFICATE

Certified that the **Ashiana Guest House** located at **50, Arakashan Road, Pahar Ganj, New Delhi** comprises of Ground floor (06 guest rooms + reception), 1st floor to 4th floor (07 guest rooms at each floor) and 5th floor (sealed) with total 34 guest rooms was granted NOC by this department vide letter No.F6/DFS/MS/GH/2011/777 dated 28-04-2011. The premises was re-inspected by the officer concerned of this department on 03-08-2014 in the presence of Mrs. Anuradha (Manager) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 lodging or rooming houses** for 34 guest rooms with effect from *02/08/*-----2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ...*07/08/14*..... at New Delhi by.

[Signature]
(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333
OK Ma

Copy to:-

1. The Joint. Commissioner of Police (Lic), First Floor,P.S. Defence Colony New Delhi – 110049 w.r.t. letter No 24193/Joint. C.P./Lic. (H) dated New Delhi 04-07-2014.
2. Mrs. Anuradha (Manager) Ashiana Guest House located at 50, Arakashan Road, Pahar Ganj, New Delhi.
3. The Commissioner, North Delhi Municipal Corporation with the request to get the height of the building verified under intimation to this department.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

n/25

INSPECTION REPORT

- 1. Name & address of the building : Ashiana Guest House at 50, Arakashan Road, Pahar Ganj, New Delhi.
- 2. Type of Occupancy : Residential (Guest house) G + 5 floors total guest rooms-34
- 3. Type of Case : Renewal
- 4. Details of previous NOC : F6/DFS/MS/GH/2011/777 dated 28/04/2011
- 5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 03/08/2014
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer
from the building side : Mrs. Anuradha (Manager)
- 9 Year of Construction : 1991
- 10. Applicant's letter No. : 24193/Joint C.P./Lic.(H) dated New Delhi the 04/07/2014

| S No | Minimum standards on fire prevention and fire safety U/R 33 | Requirements | Provided at site (PSS) | Remarks MR/NMR |
|------|---|--------------|------------------------|-------------------|
| 1. | Access of building | | | |
| | • Road width | NA | 4 Mtr. | MR |
| | • Gate width | NA | NA | NA |
| | • Width of internal road | NA | NA | NA |
| 2. | Number, width, Type & Arrangements of exits | | | |
| | a. Number of staircases | | | |
| | • Upper floors | 1 No. | 1 No. | MR |
| | • Basements | NA | NA | NA |
| | b. Width of staircases | | | |
| | • Upper floors | 0.80 Mtr. | 1.25 Mtr. | MR |
| | • Basements | NA | NA | NA |
| | c. Protection of exits | | | |
| | Fire check door | NA | NA | NA |
| | | | | |

1
Ment

| | | | | |
|----|--|---|---|----|
| | <ul style="list-style-type: none"> • Pressurization | NA | NA | NA |
| | d. No of continuous staircase to terrace | 1 No. | 1 No. | MR |
| | e. Width Of Corridor | 1.0 Mtr. | 1.0 Mtr. | MR |
| | f. Door Size | 1.0 Mtr. | 1.0 Mtr. | MR |
| 3. | Compartmentation | | | |
| | <ul style="list-style-type: none"> • Fire check door | NA | NA | NA |
| | <ul style="list-style-type: none"> • Sealing of electrical shafts | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire Rating of shaft door | NA | NA | NA |
| | <ul style="list-style-type: none"> • Water Curtain | NA | NA | NA |
| | <ul style="list-style-type: none"> • Fire Dampers | NA | NA | NA |
| 4 | Smoke managements System | | | |
| | <ul style="list-style-type: none"> • Basements | NA | NA | NA |
| | <ul style="list-style-type: none"> • Upper floors | 12 ACPH | NATURAL | MR |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total numbers | 30 Nos. | 34 Nos. | MR |
| | <ul style="list-style-type: none"> • Types | ABC, CO ₂ , Wco ₂ | ABC, CO ₂ , Wco ₂ | MR |
| | <ul style="list-style-type: none"> • IS marking | Required | Provided | MR |
| 6 | First – Aid Hose Reels | | | |
| | <ul style="list-style-type: none"> • Total numbers on each floor | 01 | 01 | MR |
| | <ul style="list-style-type: none"> • Length of hose reel hose | 30 Mtr. | 30 Mtr. | MR |
| | <ul style="list-style-type: none"> • Nozzle diameter | 05 MM | 05 MM | MR |
| 7 | Automatic fire detection and alarming system | | | |
| | <ul style="list-style-type: none"> • Type of detectors | NA | NA | NA |
| | <ul style="list-style-type: none"> • Location of Main Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> • Location of Repeater Panel | NA | NA | NA |
| | <ul style="list-style-type: none"> • Alternate source of power | NA | NA | NA |
| | <ul style="list-style-type: none"> • Hooters' Location | NA | NA | NA |
| 8 | MOEFA | Required | Provided | MR |
| 9 | Public Address System | Required | Provided | MR |
| 10 | Automatic Sprinkler | | | |
| | <ul style="list-style-type: none"> • Basements | NA | NA | NA |
| | <ul style="list-style-type: none"> • Upper floor | NA | NA | NA |

Man

N/27

| | | | | |
|----|---|-----------|-----------|----|
| | • Sprinkler above false ceiling | NA | NA | NA |
| 11 | Internal Hydrants | | | |
| | • Size of riser/down- comer | NA | 100 MM | NA |
| | • Number of hydrants per floor | 01 | 01 | MR |
| | • Hose Box | 01 | 01 | MR |
| 12 | Yard Hydrants | | | |
| | • Total number of hydrants | NA | NA | NA |
| | • Hose Box | NA | NA | NA |
| 13 | Pumping Arrangements | | | |
| | ○ Ground Level | | | |
| | • Discharge of main pump | NA | NA | NA |
| | • Head of main pump | NA | NA | NA |
| | • Number of main pumps | NA | NA | NA |
| | • Jockey pump out put | NA | NA | NA |
| | • Jockey pump head | NA | NA | NA |
| | • Standby Pump out put | NA | NA | NA |
| | • Standby Pump Head | NA | NA | NA |
| | • auto Staring/Manual stopping | NA | NA | NA |
| | • Pump House Access | NA | NA | NA |
| | ○ Terrace level | | | |
| | • Discharge of pump | 450 LPM | 450 LPM | MR |
| | • Head of the pump | 30 Mtr. | 30 Mtr. | MR |
| | • Power supply | Required | Provided | MR |
| | • Auto starting of pump | Required | Provided | MR |
| | | | | |
| 14 | Captive water Storage for fire fighting | NA | NA | NA |
| | • Under ground tank capacity | NA | NA | NA |
| | • Draw of connection | NA | NA | NA |
| | • Fire service inlet | NA | NA | NA |
| | • Access to tank | Required | Provided | MR |
| | • Overhead Tank capacity | 2500 ltr. | 2500 ltr. | MR |
| 15 | Exit Signage | Required | Provided | MR |

Meh

N/2B

| | | | | |
|----|--|----------|---------------------|----|
| 16 | Provision of Lifts | NA | NA | NA |
| | • Pressurization of Lift Shaft | NA | NA | NA |
| | • Pressurization of lift lobby | NA | NA | NA |
| | • Communication in lift Car | NA | NA | NA |
| | • Fireman's Grounding Switch | NA | NA | NA |
| | • Lift Signage | NA | NA | NA |
| 17 | Standby power supply | Required | Provided | MR |
| 18 | Refuge Area | | | |
| | • Total area | NA | NA | NA |
| | • Location | NA | NA | NA |
| 19 | Fire control room | | | |
| | • Detector system panel | NA | NA | NA |
| | • Flow Switch Panel | NA | NA | NA |
| | • PA System Panel | NA | NA | NA |
| | • Batter backup | NA | NA | NA |
| | • Building Floor Plans | NA | NA | NA |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any; | Required | ABC,Co ₂ | MR |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2011/777 dated 28/04/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended please.

Meeta
4/8/14

Name:- Sh. M. K. Sharma
Designation :- A. D.O. (CC)