

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014 / school/w2/102/

Dated: 12 / 08 / 2014

FIRE SAFETY CERTIFICATE

Certified that **Govt. Girls Sr. Sec. School No- 2, Model Town-III, Delhi-110009** comprised of **Ground + First Floor Only** owned/occupied by **Govt. Girls Sr. Sec. School No- 2** has already been issued fire safety certificate **vide letter no. F-6/DFS/MS/2011/2101 dated 26/08/2011**. The premises was re-inspected by the officer from this department on dated **18/07/2014** in the presence of **Mrs. Rekha Hans** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of **circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **12 / 08 / 2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 12 / 08 / 14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Govt. Girls Sr. Sec. School No- 2, Model Town-III, Delhi-110009
2. The Director of Education, Old Secretariat, Delhi

N-4

One Block of GF + FF.

INSPECTION REPORT

1. Name & address of the building : Govt Girls Sr. Sec. School No-2 Model town-III Delhi-9 Educational
 2. Type of Occupancy :
 3. Type of Case : New case/ Renewal
 4. Details of previous NOC : F-6/OPS/ms/2011/2101 dt-26-8-11
 5. Fire Safety directives letter No : Circular of the director of Education
 6. Date of inspection : 18-2-14
 7. Name of the Inspecting Officers : N.P. Sharma
 8. Name and designation of officers from the building side : Mrs Rekha Kans
 9. Year of Construction : -
 10. Applicant's letter No. : 240 dt-02-2-14
- Plot area- Covered area- 1685 m² No's of student- 1100 No's of class room- 17

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	02	02	MR
	• Basements	-	-	-
	b. Width of staircases			
	• Upper Floors	1.5 mths	1-1.4 mths 2-1.4 mths	MR
	• Basements	-	-	-
	c. Protection of exits			
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size <i>All CR are having two exits</i>	1. mths	add case	MR
3	Compartmentation.			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
4	Smoke Management System.			
	• Basements	30 a/c per hour	-	-
	• Upper floors	12 a/c per hour	-	-

6. Date of inspection : 18-7-14
7. Name of the Inspecting Officers : N.P. Sharma
8. Name and designation of officers from the building side : Mrs Rekha Hans
9. Year of Construction : -
10. Applicant's letter No. : 240 dt 02-7-14

Plot area- Covered area- 1685 m² No's of student- 1100 No's of class room- 17

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible	Accessible	MR ✓
		-	-	-
		-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR ✓
	<ul style="list-style-type: none"> Upper Floors Basements 	02	02 ✓	MR ✓
		-	-	-
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	1.5 mtrs	1-1.4 mtrs 2-1.4 mtrs ✓	MR ✓
		-	-	-
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	-	-	-
		-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size <i>All CR are having two exits</i>	1. mtr	add case ✓	MR ✓
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour 12 a/c per hour	-	-
			-	-
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	one @ 300 ml ISI marked	P ✓ P yes ✓	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.			
		N/A		
	<ul style="list-style-type: none"> Total numbers on each floor 	One at each floor	-	-

N-5

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 m 5 mm			
7	Automatic fire detection and alarming system. NIA				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 				
8	MOEFA				
9	Public Address System.				
10	Automatic Sprinkler System. NIA				
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 				
11	Internal Hydrants NIA				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 				
12	Yard Hydrants. NIA				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 				
13	Pumping Arrangements. NIA				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 				
14	Captive Water Storage for fire fighting. NIA				
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 				

9	Public Address System.		-	-	-
10	Automatic Sprinkler System.	NIA			
	• Basement		-	-	-
	• Upper Floor		-	-	-
	• Sprinkler above false ceiling		-	-	-
11	Internal Hydrants	NIA			
	• Size of riser/down-comer		-	-	-
	• Number of hydrants per floor		-	-	-
	• Hose Box		-	-	-
12	Yard Hydrants.	NIA			
	• Total number of hydrants		-	-	-
	• Hose Box		-	-	-
13	Pumping Arrangements.	NIA			
	• Ground Level		-	-	-
	➤ Discharge of main Pump		-	-	-
	➤ Head of Main pump		-	-	-
	➤ Number of main pumps		-	-	-
	➤ Jockey Pump out put		-	-	-
	➤ Jockey pump head		-	-	-
	➤ Standby Pump out put		-	-	-
	➤ Standby Pump Head		-	-	-
	➤ Auto Starting/ Manual stopping		-	-	-
	➤ Pump House Access		-	-	-
	• Terrace level		-	-	-
	➤ Discharge of pump		-	-	-
	➤ Head of the pump		-	-	-
	➤ Power Supply		-	-	-
	➤ Auto Starting of pump		-	-	-
14	Captive Water Storage for fire fighting.	NIA			
	• Underground tank capacity		-	-	-
	➤ Draw-off connection		-	-	-
	➤ Fire service inlet		-	-	-
	➤ Access to tank		-	-	-
	• Overhead Tank capacity		-	-	-
15	Exit Signage.		-	-	-
16	Provision of Lifts.	NIA			
	• Pressurization of Lift Shaft		-	-	-

N-6

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	-
17	Standby power supply	-	-	-
18	Refuge Area.			
	➤ Total Area	-	-	-
	➤ Location	-	-	-
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DPS/MS/2011/2101 dated 26-8-11 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer 18-2-14

Name M.P. Sharma

Designation ADD R.

DONW
21/2/14

Signature of the Inspecting Officer

Name

Designation