

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No. F.6/DFS/MS/GH/2014/ *ND21985*

Dated: *06/08/14*

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Apra Inn** located at 15A/61, WEA, Karol Bagh, New Delhi-110005 is comprised of Basement, ground floor plus three upper floors, using basement as hall, ground floor as reception, office and hall, first, second & third floor each having 08 guest rooms respectively (Total 24 guest rooms) and a pantry for staff with temporary staff room on terrace was issued NOC by this department vide letter No.F.6/DFS/MS/GH/2011/1840 dated 04.08.2011 owned/occupied by Sh. Kamal Kishore. The guest house building was re- inspected by the officer concerned of this department on 01.08.2014 in the presence of Sh. Rajender Bhat (Manager) and found that the owner have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for 24 guest rooms occupancy Group 'A' residential w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....*06/08/14*.....at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Joint Commissioner of Police (Lic.)
1st floor, P.S., Defence Colony, New Delhi.
(Re. No. 30068/Joint C.P./Lic.(H), Dated 21.07.2014)
2. Sh. Kamal Kishore (Owner),
Hotel Apra Inn, 15A/61, WEA,
Karol Bagh, New Delhi-110005.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Hotel Apra Inn, 15A/61, WEA, Karol Bagh, N.D-05.
2. Type of Occupancy : Residential (Guest House)
Basement, G.F+03 upper floors, having 24 guest rooms
3. Type of Case : Renewal
4. Details of Previous NOC : F.6/DFS/MS/GH/2011/1840 dated 04.08.2011
5. Fire Safety directives letter No : N/A
6. Date of inspection : 01.08.2014
7. Name of Inspecting Officer : Dy. C.F.O Rajesh Panwar
8. Name and designation of officers
From the building side : Sh. Rajender Bhat (Manager)
9. Year of Construction : 2003-04
10. Applicant's letter No. : 30068/Joint C.P/Lic (H) dated 21.07.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site special area	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Accessible — —	09 mtr — —	M/R — —
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	One One	One One	M/R, Old Case M/R, Old Case
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	125 cms 125 cms	130 cms 150 cms	M/R, Old Case M/R, Old Case
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace			
		One	One	M/R
	e. Width of Corridor	—	150 cms	—
	f. Door Size	N/A	79cm X 204 cm	N/A
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A — N/A N/A N/A	N/A Sealed N/A N/A N/A	N/A — N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Exhaust Fans are provided Natural Ventilation	M/R M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	Two at each floor ABC, Water Co2, Co2 ISI marked	Provided Provided ISI marked	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	M/R M/R M/R

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> Hooters' Location 	Required	D.G set of 85 KVA	M/R
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	Required	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900 LPM	450 LPM	M/R, Old Case
		30 M	30 M	M/R
		Required	Provided	M/R
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	Provided	M/R
		N/A	N/A	N/A
		10000 ltr	5000 ltr	M/R, Old Case
		Required	Provided	M/R
15.	Exit Signage.			
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
17.	Standby power supply	Required	Provided	M/R

18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	M/R
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:		N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/GH/2011/1840 dated 04.08.2011 renewal under rule 35 of Delhi Fire Service Rules 2010 is recommended.

Signature of Inspecting Officer

Name:- Rajesh Panwar

Designation:- Dy. C.F.O (NDZ)

Signature of Inspecting Officer

Name

Designation