

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2014/School/WZ/ 1018

Dated: 12 / 08 /2014

FIRE SAFETY CERTIFICATE

Certified that **J. S International School, Agar Nagar, Prem Nagar-III, Near Main Mubarak Pur Road, Delhi-110086** comprised of **Ground floor only** owned/occupied by **J. S International School** has already been issued fire safety certificate **vide letter no. F-6/DFS/MS/2009/2926 dated 01/10/2009.** The premises was re-inspected by the officer from this department on dated **22/07/2014** in the presence of **Mrs. Saroj (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of **circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **12 / 08 /2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 12/08/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:-

1. The Principal, J. S International School, Agar Nagar, Prem Nagar-III, Near Main Mubarak Pur Road, Delhi-110086
2. The Director of Education, Old Secretariat, Delhi

N/2

one Block - G.F.

INSPECTION REPORT

1. Name & address of the building : J.S. International School, Agar Nagar, Crem.
2. Type of Occupancy : Nagar III Mubarak Pur Road, Delhi-86
Educational
3. Type of Case : Renewal
4. Details of previous NOC : F-6/DPS/MS/09/2926 dt 01-10-2009.
5. Fire Safety directives letter No : Circular of the director of Education
6. Date of inspection : 22-7-14
7. Name of the Inspecting Officers : N.P. Sharma
8. Name and designation of officers from the building side : Mrs Saroj Yadav
9. Year of Construction : 2006
10. Applicant's letter No. : - 01-4-14

Plot Area- 4400m² Sq mtr, Covered Area- 800 Sq.mtr, No of Students- 216 , No of Rooms- 13 no's

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/Director of Education Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	one meter	1.5 mtr	MR ✓
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA

8. Name and designation of officers : Mrs Saroj Yadav

9. Year of Construction : 2006

10. Applicant's letter No. : - 01-4-14

Plot Area- 4400m² Sq mtr, Covered Area- 800 Sq.mtr, No of Students- 216 , No of Rooms- 13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/Director of Education Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	<p>Accessible</p> <p>—</p> <p>—</p>	<p>Accessible</p> <p>—</p> <p>—</p>	<p>MR</p> <p>—</p> <p>—</p>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floors Basements 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	b. Width of staircases	NA	NA	NA
	<ul style="list-style-type: none"> Upper Floors Basements 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	c. Protection of exits	NA	NA	NA
	<ul style="list-style-type: none"> Fire check door Pressurization 	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	NA	NA	NA
	f. Door Size	one meter	1.5 mtr	MR ✓
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	<p>30 a/c per hour</p> <p>12 a/c per hour</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
5	Fire Extinguishers			

	Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA

N/4

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.			
		NA	NA	NA
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply			
		NA	NA	NA
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:			
		NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DPS/ms/09/2926 dated 01-10-09 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer 22-714

Signature of the Inspecting Officer

Name

N.P. Sharma

Name

Designation

ADO 'R'

Designation

Done

Handwritten signature and date: 28/11/14

Recd on 28/7/14