

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/School/2014/W2/1012

Dated: 11/8/14

FIRE SAFETY CERTIFICATE

Certified that the **Jagannath International School** located at **D Block, Pushpanjali Enclave, Pitampura, Delhi - 110034** comprised of Basement + Ground + 02 Upper Floors was issued FSC vide Letter No. F6/DFS/MS/2011/249 Dated 10-02-2011. The premises was re inspected by the officers concerned of this department on 19-07-2014 in the presence of Sh. Nand Kishore (Transport Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance DOE Circular 262-362 dated 17-01-2005 and that the premises is fit for occupancy class "Educational" Group B with effect from 11/8/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 11/8/14 at New Delhi by.

C
11/8
(Santokh Singh)
Chief Fire Officer,
Ph: - 011- 23414250.

Copy to:

1. The Principal,
Jagannath International School,
D Block, Pushpanjali Enclave, Pitampura, Delhi-110034.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. Basement shall be used strictly as per building bye laws.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

Plot Area -	4977.63 M ²
Covered Area -	2502.56 M ²
No. or Class Rooms-	22
No. of Student-	608

1. Name & address of the building: Jagannath International School, D Block,
Pushpanjali Enclave, Pitampura,
Delhi – 110034.
2. Type of Occupancy : Educational (Basement + Ground + 2 Upper Floor)
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/2011/249 Dated 10-02-2011
5. Fire Safety directives Letter No. : 262-362 dated 17-01-2005
6. Date of inspection : 19-07-2014
7. Name of the Inspecting Officer : Mukesh Verma, ADO (MN)
8. Name and designation of Officer
from the building side : Sh. Nand Kishore (Transport Manager)
9. Year of Construction : 2005
10. Applicant's letter No. : JIS/6/449 Dated 26-06-2014

S No	Minimum standards on fire prevention and fire safety U/R 33	Cr.No.262-362 dated 17-01-2005	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible ✓	Provided	MR
	• Gate width	Accessible ✓	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 ✓	Provided	MR
	• Basements	2 ✓	Provided	MR
	b. Width of staircases			
	• Upper floors	Old Case ✓	Old Case	MR
	• Basements	Old Case ✓	Old Case	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	Provided	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Old case ✓	Old Case	MR

2/11

3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	Required	Provided ✓	MR ✓
	• Upper floors	NA	NA	NA
5.	Fire Extinguishers			
	• Total numbers	12 nos.	Provided ✓	MR
	• Types	ABC & CO ₂	Provided ✓	MR
	• IS marking	ISI marked	Provided ✓	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	Provided ✓	MR ✓
	• Length of hose reel hose	30m	Provided ✓	MR
	• Nozzle diameter	5mm	Provided ✓	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided ✓	MR ✓
9.	Public Address System	NR	Provided ✓	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided ✓	MR ✓
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	100 mm	Provided ✓	MR ✓
	• Number of hydrants per floor	1	Provided ✓	MR
	• Hose Box	1	Provided ✓	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	450 lpm, 180 lpm	Provided	MR	✓
		40Mtr	Provided	MR	
		Required	Provided	MR	
		Required	Provided	MR	
14.	Captive water Storage for fire fighting:				
	• Under ground tank capacity	NA	NA	NA	
	➤ Draw off connection	NA	NA	NA	
	➤ Fire service inlet	NA	Provided	NA	
	➤ Access to tank	NA	NA	NA	
	• Overhead Tank capacity	10.000Ltr	Provided	MR	✓
15	Exit Signage	Required	Provided	MR	
16.	Provision of Lifts				
	➤ Pressurization of Lift Shaft	NA	NA	NA	
	➤ Pressurization of lift lobby	NA	NA	NA	
	➤ Communication in lift Car	NA	NA	NA	
	➤ Fireman's Grounding Switch	NA	NA	NA	
	➤ Lift Signage	NA	NA	NA	
17.	Standby power supply	NA	NA	NA	
18.	Refuge Area				
	➤ Total area	NA	NA	NA	
	➤ Location	NA	NA	NA	
19.	Fire control room				
	➤ Detector system panel	NA	NA	NA	
	➤ Flow Switch Panel	NA	NA	NA	
	➤ PA System Panel	NA	NA	NA	
	➤ Battery backup	NA	NA	NA	
	➤ Building Floor Plans	NA	NA	NA	
20.	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide Letter No. F6/DFS/MS/2011/249 Dated 10-02-2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer

Name **MUKESH VERMA**

Designation **ADD (MN)**

DO (NKSJ) dm
23/17

26/91
31/7/14
01/8/14

14/Dec/2022