

**FORM 'H': FORM FOR ISSUING FIRE SAFETY CERTIFICATE**

[See sub-rule (1) of rule 35]

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/2014/ W2/1009

Dated: 11 / 08 / 2014

**FIRE SAFETY CERTIFICATE**

Certified that the Le- Grand Banquet Hall at Plot No. E-2 Udyog Nagar Industrial Area, Main Rohtak Road, Delhi - 41, comprised of **Basement + Ground Floor + Mezzanine Floor + 1<sup>st</sup> Floor + 2<sup>nd</sup> Floor** owned / occupied by Le-Grand Banquet Hall have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verified by the officer concerned of Fire Service on **28/07/2014** in the presence of Mr. Chadha and that the building / premises is fit for occupancy class **Assembly** with effect from 11 / 08 / 2014 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

**Issued on** 11 / 08 / 14 **at New Delhi by.**

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

Copy to :-

1. Sant Lal Maggu E-2, Udyog Nagar Industrial Area Main Rohtak Road, Delhi – 41.
2. Deputy Health Officer, NDMC, Rohini Zone, Sector – 5, Rohini, Delhi - 85



N/21

To see the compliance of Department's Letter No. F6/DFS/MS/2014/1683  
Dated - 23/07/2014. (B + GF + MezF + 1<sup>st</sup> Floor + 2<sup>nd</sup> Floor. Plot Area - 2405 m<sup>2</sup>)

### INSPECTION REPORT

1. Name & address of the building: **Le-Grand Banquet Hall, Plot No. E-2, Udyog Nagar Ind. Area, Rohtak Road, Delhi - 41**
2. Type of Occupancy : **Assembly**
3. Type of Case : **New**
4. Details of previous NOC : **Nil**
5. Fire Safety directives Letter No. : **NBC (Part-IV)**
6. Date of inspection : **28/07/2014**
7. Name of the Inspecting Officer : **Ashok Kumar Jaiswal A.D.O. (Jwala Puri) & Sunil Chawdhary D.O. (West)**
8. Name and designation of Officer  
from the building side : **Mr. Chadha**
9. Year of Construction : **2010**
10. Applicant's letter No. : **Nil**

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mtr.	> 9 Mtr. ✓	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	Required	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 ✓	2	MR
	• Basements	2 + ( 1 Ramp)	Provided ✓	MR
	Width of staircases			
	• Upper floors	2.00 Mtr.	Provided ✓	MR
	• Basements	2.00 Mtr.	Provided ✓	MR
	Protection of exits			
	• Fire check door	Required	Provided ✓	MR
	• Pressurization	Required	Provided ✓	MR
	b. No of continuous staircase to terrace	1	Provided ✓	MR
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	2 x 2.00 Mtr.	Provided ✓	MR
3.	Compartmentation			

2. Type of Occupancy : Assembly
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : NBC (Part-IV)
6. Date of inspection : 28/07/2014
7. Name of the Inspecting Officer : Ashok Kumar Jaiswal A.D.O. (Jwala Puri)  
& Sunil Chawdhary D.O. (West)
8. Name and designation of Officer  
from the building side : Mr. Chadha
9. Year of Construction : 2010
10. Applicant's letter No. : Nil

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC-IV Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mtr.	9 Mtr. ✓	MR
	• Gate width	4.5 Mtr.	4.5 Mtr.	MR
	• Width of internal road	Required	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 ✓	2	MR
	• Basements	2 + ( 1 Ramp)	Provided ✓	MR
	Width of staircases			
	• Upper floors	2.00 Mtr.	Provided ✓	MR
	• Basements	2.00 Mtr.	Provided ✓	MR
	Protection of exits			
	• Fire check door	Required	Provided ✓	MR
	• Pressurization	Required	Provided ✓	MR
	b. No of continuous staircase to terrace	1	Provided ✓	MR
	c. Width Of Corridor	NA	NA	NA
	d. Door Size	2 x 2.00 Mtr.	Provided ✓	MR
3.	Compartmentation			
	• Fire check door	Required	Provided ✓	MR
	• Sealing of electrical shafts	Required	Provided ✓	MR
	• Fire Rating of shaft door	Required	Provided ✓	MR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	Mechanical Ventilation	Provided ✓	MR

N/22

	• Upper floors / GF	Mechanical Ventilation	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	15	20	MR
	• Types	ABC /Co <sub>2</sub> /Foam	Provided	MR
	• IS marking	ISI Marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	Provided	MR
	• Length of hose reel hose	30 Mtr.	30 Mtr.	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Smoke	Provided	MR
	• Location of Main Panel	GF	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	At all strategic locations	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NR	NP	NR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor / GF	Required	Provided	MR
	• Sprinkler above false ceiling	Required	Provided	MR
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	2	Provided	MR
	• Hose Box	2	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	4	Provided	MR
	• Hose Box	4	Provided	MR
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2280 Lit/min	Provided	MR
	➤ Head of main pump	70 MH	Provided	MR
		2	Provided	MR

	• Length of hose reel hose		5 mm	✓	MR
	• Nozzle diameter	5 mm			
7.	Automatic fire detection and alarming system				
	• Type of detector	Smoke	Provided	✓	MR
	• Location of Main Panel	GF	Provided	✓	MR
	• Location of Repeater Panel	NA	NA		NA
	• Alternate source of power	Required	Provided	✓	MR
	• Hooters' Location	At all strategic locations	Provided	✓	MR
8.	MOEFA	Required	Provided		MR
9.	Public Address System	NR	NP		NR
10.	Automatic Sprinkler System				
	• Basements	Required	Provided	✓	MR
	• Upper Floor / GF	Required	Provided	✓	MR
	• Sprinkler above false ceiling	Required	Provided	✓	MR
11.	Internal Hydrants				
	• Size of riser/down-comer	150 mm	Provided	✓	MR
	• Number of hydrants per floor	2	Provided		MR
	• Hose Box	2	Provided		MR
12.	Yard Hydrants				
	• Total number of hydrants	4	Provided		MR
	• Hose Box	4	Provided		MR
13.	Pumping Arrangements				
	• Ground Level				
	• Discharge of main pump	2280 Lit/min	Provided	✓	MR
	➤ Head of main pump	70 MH	Provided	✓	MR
	➤ Number of main pumps	2	Provided		MR
	➤ Jockey pump out put	180 Lit/min	Provided	✓	MR
	➤ Jockey pump head	70 MH	Provided	✓	MR
	➤ Standby Pump out put	2280 Lit/min	Provided	✓	MR
	➤ Standby Pump Head	70 MH	Provided	✓	MR
	➤ Auto Staring/Manual stopping	Required	Provided		MR
	➤ Pump House Access	Required	Provided		MR
	• Terrace level				

N/23

➤	Discharge of pump	900 Lit/min ✓	Provided	MR
➤	Head of the pump	70 MH ✓	Provided	MR
➤	Power supply	Required	Provided	MR
➤	Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	100,000 Ltr. ✓	100,000 Ltr.	MR
	➤ Draw of connection	Required	Provided	NR
	➤ Fire service inlet	Required	Provided	NR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 Ltr. ✓	20,000 Ltr.	MR
15	Exit Signage	Required ✓	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required ✓	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in lift Car	Required ✓	Provided	MR
	➤ Fireman's Grounding Switch	Required ✓	Provided	MR
	➤ Lift Signage	Required ✓	Provided	MR
17.	Standby power supply	Required ✓	Provided	MR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NR	NR	NR
	➤ Flow Switch Panel	NR	NR	NR
	➤ PA System Panel	NR	NR	NR
	➤ Batter backup	NR	NR	NR
	➤ Building Floor Plans	NR	NR	NR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Keeping In view of the substantial compliance of the minimum standards of fire prevention and fire safety measures as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

CFO/8/14  
6/8/14

*Ak Jaiswal*

Signature of the Inspecting Officer  
Name : Ashok Kumar Jaiswal

*ds*

Signature of the Inspecting Officer  
Name : Sunil Chawdhary

