

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No: F.6/DFS/MS/School/2014/ 52 / 902

Dated: 22/07/14

FIRE SAFETY CERTIFICATE

Certified that the building of **M.C. Primary Girls School**, 22-Block, West Patel Nagar, New Delhi -110008 is comprised of ground floor only in temporary shed owned/occupied by MCD was inspected by the officer concerned of this department on 14.07.2014 in the presence of Smt. Manju Bagga (Principal) and found that the M.C.D have complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on ...22/07/14.....at New Delhi.



(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Ph:- 011-23414333

Copy to: -

1. The Principal,
M.C. Primary Girls School,
22-Block, West Patel Nagar, N.D-08.
2. Director of Education,
North Delhi Municipal Corporation
15th floor, Dr. S.P.M Civic Centre,
Minto Road, New Delhi-110002.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/1. Ground Floor only

INSPECTION REPORT

1. Name & address of the building: M.C. Primary Girls School, 22-Block, West Patel Ngr, N.D-08.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. — Dated —
5. Fire Safety directives letter No : —
6. Date of inspection : 14.07.2014
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Smt. Manju Bagga (Principal)
9. Year of Construction : 1963
10. Applicant's letter No. : Nil dated 30.06.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	<u>Accessible</u>	<u>06 mtr</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>03 mtr</u>	<u>MR</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>—</u>	<u>—</u>	<u>Ground Floor only</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	b. Width of staircases			
	• Upper Floor	<u>—</u>	<u>—</u>	<u>Ground Floor only</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	c. Protection of exits			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	d. No. of continuous staircases to terrace	<u>—</u>	<u>—</u>	<u>—</u>
	e. Width of Corridor	<u>—</u>	<u>—</u>	<u>Ground Floor only</u>
	f. Door Size	<u>—</u>	<u>110 cms x 210 cms</u>	<u>—</u>
3.	Compartmentation			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Sealing of electrical shafts	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Rating of shaft door	<u>—</u>	<u>—</u>	<u>—</u>
	• Water Curtain	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Dampers	<u>—</u>	<u>—</u>	<u>—</u>
4.	Smoke Management System			
	• Basements	30 a/c per hour	<u>—</u>	<u>No Basement</u>
	• Upper floors / <u>Ground Floor</u>		<u>Natural Ventilation</u>	<u>MR</u>

(M)

N/2-

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	03 Nos	Provided	MR
	• Types	ABC	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	-	-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	-	-
	• Hooters' Location	-	-	-
8.	MOEFA			
9.	Public Address System			
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

22-Block, West Patel Nagar,

New Delhi - 110008.

M.C. Poojari School

H/3

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
15.	Exit Signage.	-	-	-
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
17.	Standby power supply	-	-	-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

(10)

N/4.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The school building is comprised of Ground Floor only in temporary shed. In each class students less than 45 as per declaration given by the Principal of the school. Same is placed in the file. FSC is recommended please.


Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer

DO (SW)


1617114

Signature of Inspecting Officer

Name

Designation

