

**FIRE SAFETY CERTIFICATE**

Certified that Manav Bhawna Public School, Nathu Pura Village, Delhi-110084 comprised of Ground + Two & Ground + Three upper floor owned/occupied by Manav Bhawna Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2011/1257 dated 16/06/2011. The premises was re-inspected by the officer from this department on dated 10/07/2014 in the presence of Smt. Urmila Gaur (Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 07/08/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 07/08/14 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Ph: 011-23414250

**Copy to:**

1. The Principal, Manav Bhawna Public School, Nathu Pura Village, Delhi-110084
2. The Director of Education, Old Secretariat, Delhi

N-11

Two Blk. Gr+2 + Gr+3 interconnected.

**INSPECTION REPORT**

1. Name & address of the building : Manava Bhawna Public School  
Nathu Pura Delhi-83
2. Type of Occupancy : Educational
3. Type of Case : New case/ Renewal
4. Details of previous NOC : F-6/DFS/M-2/2011/1257 dt-16.6.11
5. Fire Safety directives letter No : Dir. of Edu.
6. Date of inspection : 10.7.14
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers from the building side : Smt. Umida Gaur Principal
9. Year of Construction : 2003 + 2008
10. Applicant's letter No. : MBPS/DFS/14/2192 dt-10.6.14

Plot area-2673 m<sup>2</sup> Covered area-2860 m<sup>2</sup> No's of student- 1130 No's of class room- 36  
one lab.

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	2	3	MR ✓
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	old case	90 cms, 115 cms + 120 cms.	old case ✓
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	P	MR ✓
	g. Width of Corridor	—	—	—
	h. Door Size	old case	old case	old case ✓
3	<b>Compartmentation.</b>			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
5	<b>Fire Extinguishers</b>			
		12	12	MR ✓



8. Name and designation of officers : Smt. Umida Bhatta Principal.  
 from the building side :  
 9. Year of Construction : 2003 & 2008  
 10. Applicant's letter No. : MBPS/DFS/14/2192 dt. 10.6.15.  
 Plot area-2673 m<sup>2</sup> Covered area-2860 m<sup>2</sup> No's of student- 1130 No's of class room- 36  
 one lab.

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	2	3	MR ✓
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	old case	90 cms, 115 cms & 120 cms.	old case ✓
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	P	MR ✓
	g. Width of Corridor	—	—	—
	h. Door Size	old case	old case	old case ✓
3	<b>Compartmentation.</b>			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
	<del>N/A</del>			
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
	<del>N/A</del>			
5	<b>Fire Extinguishers</b>			
	• Total numbers	17 ABC	17 ✓	MR ✓
	• Types	ABC		MR ✓
	• IS marking	ISI marked	yes	MR ✓
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	One at each floor two	P	MR ✓



N-12

	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m	P	MR	✓
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm	P	MR	✓
7	<b>Automatic fire detection and alarming system.</b>				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A			
8	<b>MOEFA</b>				
9	<b>Public Address System.</b>				
10	<b>Automatic Sprinkler System.</b>				
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A			
11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	R	P	MR	✓
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	one	one	MR	✓
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	R	P	MR	✓
12	<b>Yard Hydrants.</b>				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	—	—	—	
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	—	—	—	
13	<b>Pumping Arrangements.</b>				
	<ul style="list-style-type: none"> <li>Ground Level           <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level           <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A			
	<ul style="list-style-type: none"> <li>Discharge of pump</li> </ul>	900 LPM	900 LPM	MR	✓
	<ul style="list-style-type: none"> <li>Head of the pump</li> </ul>	40M	40M	MR	✓
	<ul style="list-style-type: none"> <li>Power Supply</li> </ul>	—	—	—	
	<ul style="list-style-type: none"> <li>Auto Starting of pump</li> </ul>	R	P	MR	✓
14	<b>Captive Water Storage for fire fighting.</b>				
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	—	—	—	
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	—	—	—	





14-13

Manav Bhawan Public school Neth-pur

	<ul style="list-style-type: none"> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>				
17	Standby power supply	R	P	MR	
18	Refuge Area.				
	➤ Total Area				
	➤ Location				
19	Fire Control Room				
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>				
20	Special Fire Protection Systems for Protection of special Risks, if any:				


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-C/DFS/MS/2011/1257 dated 16.6.11 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name


Designation



Signature of the Inspecting Officer

Name

Designation

  
14/7/11  
ADO (SW)