

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:-011-23412593

E-mail ID: cfqhq.dfire@nic.in

No. F6/DFS/MS/GH/2014/ *MD2/991*

Dated *07/08/14*

FIRE SAFETY CERTIFICATE

Certified that the **Raman Palace Guest House** located at **1310-1311-A, Sangtrashan Bazar, Pahar Ganj, New Delhi** comprises of Ground floor (reception), 1st floor to 2nd floor (06 guest rooms at each floor) and terrace floor (01 guest room) with total 13 guest rooms was granted NOC by this department vide letter No.F6/DFS/MS/GH/2011/1709 dated 26-07-2011. The premises was re-inspected by the officer concerned of this department on 03-08-2014 in the presence of Mr. Ansaar (Manager) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Residential, Sub-Division A-1 lodging or rooming houses** for 13 guest rooms with effect from ~~-----~~ *07/08/14* 2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on ~~-----~~ *07/08/14* at New Delhi by.


(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi – 110049 w.r.t. letter No 21900/Addl. C.P./Lic. (H) dated New Delhi 09-06-2014.
2. Mr. Ansaar (Manager) Raman Palace Guest House located at 1310-1311-A, Sangtrashan Bazar, Pahar Ganj, New Delhi.
3. The Commissioner, North Delhi Municipal Corporation with the request to get the height of the building verified under intimation to this department.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry"

INSPECTION REPORT

1. Name & address of the building : Raman Place Guest House located at 1310-1311-A, Sangtrashan Bazar, Pahar Ganj, New Delhi.
2. Type of Occupancy : Residential (Guest house) G + 2 floor + 01 room on terrace total 13 guest rooms.
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/2011/1709 dated 26/07/2011
5. Fire Safety directives Letter No. : NA
- 6 Date of inspection : 03/08/2014
- 7 Name of the Inspecting Officer : M. K. Sharma (Assistant Divisional Officer)
- 8 Name and designation of Officer from the building side : Mr. Ansaar (Manager)
- 9 Year of Construction : 2008
10. Applicant's letter No. : 21900/Addl. C.P./Lic.(H) dated New Delhi the 09/06/2014

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site (PSS)	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	NA	3.5 Mtr.	MR
		NA	NA	NA
		NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1 No.	1 No.	MR
		NA	NA	NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	0.80 Mtr.	0.92 Mtr.	MR
		NA	NA	NA
	c. Protection of exits			
	Fire check door	NA	NA	NA

mark

N/11

	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1 No.	1 No.	MR
	e. Width Of Corridor	1.0 Mtr.	1.0 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.0 Mtr.	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	• Total numbers	06 Nos.	08 Nos.	MR
	• Types	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	• IS marking	Required	Provided	MR
6	First – Aid Hose Reels			
	• Total numbers on each floor	NA	01	NA
	• Length of hose reel hose	NA	30 Mtr.	NA
	• Nozzle diameter	NA	05 MM	NA
7	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8	MOEFA	NA	Provided	NA
9	Public Address System	NA	Provided	NA
10	Automatic Sprinkler			
	• Basements	NA	NA	NA
	• Upper floor	NA	NA	NA

Meh

N/12

	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements			
	○ Ground Level			
	• Discharge of main pump	NA	NA	NA
	• Head of main pump	NA	NA	NA
	• Number of main pumps	NA	NA	NA
	• Jockey pump out put	NA	NA	NA
	• Jockey pump head	NA	NA	NA
	• Standby Pump out put	NA	NA	NA
	• Standby Pump Head	NA	NA	NA
	• auto Starting/Manual stopping	NA	NA	NA
	• Pump House Access	NA	NA	NA
	○ Terrace level	NA	NA	NA
	• Discharge of pump	NA	450 LPM	NA
	• Head of the pump	NA	30 Mtr.	NA
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting	NA	NA	NA
	• Under ground tank capacity	NA	NA	NA
	• Draw of connection	NA	NA	NA
	• Fire service inlet	NA	NA	NA
	• Access to tank	NA	Provided	NA
	• Overhead Tank capacity	NA	2500 ltr.	NA
15	Exit Signage	Required	Provided	MR

men

N/B

16	Provision of Lifts	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of lift lobby • Communication in lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC,Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/GH/2011/1709 dated 26/07/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended please.



Signature of the Inspecting Officer

Name :- M.K. Sharma
Designation :- A. D.O. (CC)