

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**

**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel:- 011-23414373

No. F6/MS/DFS/Club/2014/S2/1000

Dated: 08/08/14

**FIRE SAFETY CERTIFICATE**

Certified that the Vasant Vihar Club located at 88, Paschimi Marg, Vasant Vihar, New Delhi-110057, comprised of basement, ground and two upper floors owned/occupied by Govt. Servants Co-operative House Building Society Ltd. was granted FSC by this department vide letter NO.F6/DFS/MS/2010/265 Dated-10/09/2010. The premises was re-inspected by the officer concerned of this department on 30/12/13 in the presence of Mr. Jaideep S. Dayal (Gen. Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class Group – D, Assembly Building (Club) with effect from ~~08/08/14~~ for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued ~~08/08/14~~ at New Delhi by.



**(Dr. G.C. Misra)**  
**Chief Fire Officer**

Copy to:-

1. The Addl. Commissioner of Police, (Lic.),  
First Floor, PS Defence Colony, New Delhi
2. The DEO  
Office of the Commissioner of Excise, Entt. & L.Tax Deptt.  
Govt. of National Capital Territory of Delhi  
L & N Block, I.P.Estate, Vikas Bhawan  
New Delhi-110002

o/c  
7/8/14  
AD01(B&P)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building:-Vasant Vihar Club,88,Paschimi Marg,Vasant Vihar,New Delhi-110057
2. Type of occupancy:- Assembly (Club)
3. Type of case:- Renewal
4. Details of previous NOC:-F6/DFS/MS/2010/2651 Dated-10/09/2010
5. Fire safety directives No.-F6/DFS/MS/90/258 Dated:27-02-1990
6. Date of inspection:-30/07/14
7. Name of the inspecting officer:- D.B.Mukherjee, A.D.O.(BCP)
8. Name & designation of officer From the building side:- Mr. Jaideep S. Dayal (Gen. Manager)
9. Year of construction:- 1977.
- 10.Applicant's letter No:-VVC/Admn/FFS/NOC/2013 dated 18/07/13,

The building is comprised of basement, ground and two upper floors.

S.No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	09 m	Provided	MR
	2) Gate width	Required	3nos, 4.60 m each	MR
	3)Width of internal road	06 m	Provided	MR
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	05 nos.	5 nos.	MR
	2. Basements	03 nos.	3 nos.	MR
	B. Width of staircase			
	1. Upper floors	1.5 mtrs.	1.46, 1.47, 0.98, 1.30, 1.30 All in mtrs.	MR (Old Case)
	2. Basements	1.5 mtrs.	1.36mtrs,3.05mtrs,3.60mtr	MR(Old Case)
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	Provided	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	Required	2m, 1.77m & 1.90m	MR
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	Required	Provided	MR
	2) Sealing of electrical shafts	Required	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Exhaust fans	MR
	2) Upper floors	12 a/c per hour	Natural Ventilation	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	25Nos.	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	One	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR

<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	Required	Provided in restaurant	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	100 mm	Provided	MR
	2) Number of hydrants per floor	01	Provided	MR
	3) Hose box	01	Provided	MR
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	Required	2nos Provided	MR
	2) Hose box	Required	Provided	MR
<b>13.</b>	<b>Pumping Arrangement</b>			
	2) Ground level			
	a) Discharge of main pump	1620 LPM	1020 LPM	MR
	b) Head of main pump	60 m	44m	MR
	c) Number of main pump	01	Provided 1 no.	MR
	d) Jockey pump out put	180LPM	180 LPM	MR
	e) Jockey pump head	60 m	60 m	MR
	f) Stand by pump output	1620 LPM	Provided diesel driven	MR
	g) Stand by pump head	60 m	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	3) Terrace level			
	a) Discharge of pump	450 LPM	900 LPM	MR
	b) Head of pump	Required	60m	MR
	c) Power supply	Required	DG Set	MR
	d) Auto starting of pump	Required	Provided	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	50000 L	Provided	MR
	a) Draw-off connection	Required	Provided	MR
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	Required	10,000 ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	Required	Provided	MR
	b) Pressurization of lift lobby	Required	Provided	MR
	c) Communication in lift car	Required	Provided	MR
	d) Fireman's switch	Required	Provided	MR
	e) Lift signage	Required	Provided	MR
<b>17.</b>	<b>Stand by Power Supply</b>	Required	DG Set 125 Kva	MR
<b>18.</b>	<b>Refuge Area</b>			
	Total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

N/34

19.	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>	<b>Provided ABC Type fire extinguishers in electrical panels</b>		MR

The fire protection system provided in the building were checked and found functional at the time of inspection.

The shortcoming given by the department vide letter no.F6/DFS/MS/Club/2014/1461 dated: 24/06/14 have been rectified. In view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2010/2651 dated-10/09/2010 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for perusal and signature If approved.

Signature of the inspecting officer

*[Handwritten Signature]*  
4/8/14

Name :- D.B. Mukherjee.  
Designation :- Assistant Divisional Officer.

DO (~~Santh~~)  
*[Handwritten Signature]*  
4/8/14