

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/ School 2014/w2/1020

Dated: 12/08/2014

FIRE SAFETY CERTIFICATE

Certified that Vikas Bharti Public School, Sector-24, Rohini, Delhi-110085 comprised of Basement + Ground + Three upper floor owned/occupied by Vikas Bharti Public School has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2011/1200 dated 14/06/2011. The premises was re-inspected by the officer from this department on dated 03/07/2014 in the presence of Sh Anoop Solanki (Manager) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 12/08/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 12/08/14 at New Delhi by

S
n/8
(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. Sh Anoop Solanki, Manager, Vikas Bharti Public School, Sector-24, Rohini, Delhi-1100850
2. The Director of Education, Old Secretariat, Delhi

N-10

INSPECTION REPORT

(B + G + 3)

1. Name & address of the building : Vikas Bharti Public School, Sector-24, Rohini, Delhi-110085
2. Type of Occupancy : **Educational**
3. Type of Case : **Renewal**
4. Details of previous NOC : F-6/DFS/MS/2011/1200 dated 14/06/2011
5. Fire Safety directives letter No : Director of education /NBC Part-IV
6. Date of inspection : 03/07/2014
7. Name of the Inspecting Officers : DO (NW) & ADO (R)
8. Name and designation of officers
from the building side : *Mr Anoop Solanki (Manager)* &
9. Year of Construction : 2000-2001
10. Applicant's letter No. : VBPS/ADMIN/2014/101 dated 20/06/2014

Plot area: 1.6 Acer Covered area: 7200 sq mtr No.'s of students: 2900 No's of classrooms: -81

	Minimum Standards on fire prevention and fire safety U/R 33	Director of education/NBC	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	P	M/R
	• Gate width	5 m	P	M/R
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	05	05	M/R
	• Basements	02	02	M/R
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.5 mtr each	M/R
	• Basements	1.5 mtr	1.5 mtr each	M/R
	c. Protection of exits			
	• Fire check door	--	--	--
	• Pressurization	--	--	--
	e. No. of continuous staircases to terrace	05	05	M/R
	g. Width of Corridor	--	--	--
	h. Door Size	Old case	Old case	Old case

[Signature]

N-11

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A N/A	N/A N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	30 ISI marked	35 25 ABC, 07 WCO2 & 03 CO2 Yes	M/R M/R M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	03 30 m 5 mm	03 at each floor P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
8	MOEFA	R	P	M/R
9	Public Address System.	R	P	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	R N/A N/A	P N/A N/A	M/R N/A N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	4" 03 03	P 03 03	M/R M/R M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A N/A	N/A N/A	N/A N/A

JK

N-12

13	Pumping Arrangements.																																									
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">1000 LPM</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">--</td><td style="text-align: center;">--</td><td style="text-align: center;">--</td></tr> <tr><td style="text-align: center;">--</td><td style="text-align: center;">--</td><td style="text-align: center;">--</td></tr> <tr><td style="text-align: center;">--</td><td style="text-align: center;">--</td><td style="text-align: center;">--</td></tr> <tr><td style="text-align: center;">--</td><td style="text-align: center;">--</td><td style="text-align: center;">--</td></tr> <tr><td style="text-align: center;">--</td><td style="text-align: center;">--</td><td style="text-align: center;">--</td></tr> <tr><td style="text-align: center;">--</td><td style="text-align: center;">--</td><td style="text-align: center;">--</td></tr> <tr><td style="text-align: center;">--</td><td style="text-align: center;">--</td><td style="text-align: center;">--</td></tr> <tr><td style="text-align: center;">--</td><td style="text-align: center;">--</td><td style="text-align: center;">--</td></tr> <tr><td style="text-align: center;">2 x 450 LPM</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">40 LPM</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">R</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">R</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> </table>	1000 LPM	P	M/R	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	2 x 450 LPM	P	M/R	40 LPM	P	M/R	R	P	M/R	R	P	M/R	
1000 LPM	P	M/R																																								
--	--	--																																								
--	--	--																																								
--	--	--																																								
--	--	--																																								
--	--	--																																								
--	--	--																																								
--	--	--																																								
--	--	--																																								
2 x 450 LPM	P	M/R																																								
40 LPM	P	M/R																																								
R	P	M/R																																								
R	P	M/R																																								
14	Captive Water Storage for fire fighting.																																									
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">50,000 ltr</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">R</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">R</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">R</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">50,000 ltr</td><td style="text-align: center;">(20 + 30 LTR) P</td><td style="text-align: center;">M/R</td></tr> <tr><td style="text-align: center;">R</td><td style="text-align: center;">P</td><td style="text-align: center;">M/R</td></tr> </table>	50,000 ltr	P	M/R	R	P	M/R	R	P	M/R	R	P	M/R	50,000 ltr	(20 + 30 LTR) P	M/R	R	P	M/R																						
50,000 ltr	P	M/R																																								
R	P	M/R																																								
R	P	M/R																																								
R	P	M/R																																								
50,000 ltr	(20 + 30 LTR) P	M/R																																								
R	P	M/R																																								
15	Exit Signage.																																									
16	Provision of Lifts.																																									
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td></tr> <tr><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td></tr> <tr><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td></tr> <tr><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td></tr> <tr><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td><td style="text-align: center;">N/A</td></tr> </table>	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A																									
N/A	N/A	N/A																																								
N/A	N/A	N/A																																								
N/A	N/A	N/A																																								
N/A	N/A	N/A																																								
N/A	N/A	N/A																																								
17	Standby power supply																																									
		R	P M/R																																							

N-13

18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. **F-6/DFS/MS/2011/1200 dated 14/06/2011** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

[Handwritten Signature]
8/8/14