

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001
Fax: 23412593, Tel: 011-23414333


NO.F6/ DFS/ MS/School/2014/ 52/1051

Dated: 21/08/14

FIRE SAFETY CERTIFICATE

Certified that Lalit Mahajan SVM School, Located at Vasant Vihar, New Delhi-110057 comprised of Ground and 03 Upper floors, having total 38 rooms,(33 class room, 1 office, 04 staff room) owned/occupied by Samarth Shiksha Samiti Delhi was issued NOC vide letter no.F6/DFS/MS/2011/1963 dated: 12/08/2011 by this department. The school building was re-inspected by the officer concerned of this department on 01/08/2014 in the presence of Mr. Chander Prakash (Admn. Officer) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class- Educational (School) with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on 21/08/14 at New Delhi by.



(Dr. G.C.Misra)
Chief Fire Officer

Copy to: -

The Principl,
Lalit Mahajan SVM School,
Vasant Vihar,
New Delhi-110057

97C
14/8/14
Add (REP)

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building :Lalit Mahajan SVM School, Vasant Vihar, New Delhi-110057
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/1963 Dated: 12/08/2011
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2003/313 dated-07/02/2003
6. Date of inspection : 01/08/2014
7. Name of the Inspecting Officers : D.B.Mukherjee, ADO (BCP)
8. Name and designation of officers
from the building side : Mr. Chander Prakash (Administrative Officer)
9. Year of Construction :2006
10. Applicant's letter No. : LMSVN/2014-15/5 dated: 11/07/2014

(Building is comprised of ground + 3 upper floors)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 mtrs.	Provided	MR ?
	• Gate width	5 mtrs.	Provided	MR ✓
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	03 nos.	Provided	MR
	• Basements	N/A	N/A	N/A
b.	Width of staircases			
	• Upper Floors	1.50 m	1.80, 1.50 & 1.50 All in mtrs.	MR ✓
	• Basements	N/A	N/A	N/A
c.	Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
e.	No. of continuous staircases to terrace	01	03	MR
g.	Width of Corridor	N/A	N/A	N/A
h.	Door Size	N/A	N/A	N/A

✓

3	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural	MR
5	Fire Extinguishers			
	• Total numbers	Required	40 nos	MR
	• Types	ABC,CO ₂	Provided	MR
	• IS marking	Required	Provided	MR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8	MOEFA	Not Required	Provided	-----
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• Size of riser/down-comer	Required	Provided	MR
	• Number of hydrants per floor	Required	Provided 02 nos at each floor	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A

13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		450 LPM	900LPM & 180LPM	MR
		40 mtrs.	40 mtrs. each	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	50,000 Ltrs.	50,000 Ltrs.	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10000 Ltrs.	10000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A

mm

19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	02 nos. of ABC Type Fire Extinguishers are provided electric panel board.	MR

The fire protection systems provided in the school were test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/2011/1963 Dated: 12/08/2011 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for approval pl.

Signature of the Inspecting Officer

D.B. Mukherjee
4/8/14

Name:- D.B.Mukherjee
Designation :- Asstt. Div. Officer (BCP)

~~DO (South)~~

D.B. Mukherjee
4/8/14