

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No.F.6/DFS/MS/School/2014/ 52 /1062

Dated: 22 / 08 / 14

FIRE SAFETY CERTIFICATE

Certified that the building of **Ramjas School** located at Anand Parbat, New Delhi-110005 having two wings namely Upper Wing and Lower Wing. Upper Wing is comprised of ground floor only and Lower Wing is comprised of ground floor plus one upper floor was issued NOC by this department vide letter No.F.6/DFS/MS/2011/1472 dated 06.07.2011. The School building was re- inspected by the officer concerned of this department on 19.08.2014 in the presence of Sh. C.P. Singh (Estate Officer) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on..... 22 / 08 / 14 at New Delhi.

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333

Copy to:-

1. The Principal,
Ramjas School,
Anand Parbat, New Delhi-110005.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Ground Floor plus one upper floor

M/S

INSPECTION REPORT

1. Name & address of the building: Ramjas School, Anand Parbat, New Delhi-05.
2. Type of Occupancy: Educational (School)
3. Type of Case: New Case/Renewal
4. Details of Previous NOC: Letter No. F.6/DFS/MS/2011/1472 Dated 06.07.2011
5. Fire Safety directives letter No: —
6. Date of inspection: 19.08.2014
7. Name of Inspecting Officer: A.D.O P.S. Nahiya
8. Name and designation of officers
From the building side: Sh. C.P. Singh (Estate Officer)
9. Year of Construction: Before 1990
10. Applicant's letter No.: RJS/191/2014 dated 29.07.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	<u>Accessible</u>	<u>06 mtr</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>232 cms</u>	<u>MR</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>Three</u>	<u>Three</u>	<u>MR</u>
	• Basements	<u>—</u>	<u>—</u>	<u>NO Basement</u>
	b. Width of staircases			
	• Upper Floor	<u>—</u>	<u>152, 130, 108 cms</u>	<u>MR, Old Case</u>
	• Basements	<u>—</u>	<u>—</u>	<u>No Basement</u>
	c. Protection of exits			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	d. No. of continuous staircases to terrace	<u>—</u>	<u>One</u>	<u>—</u>
	e. Width of Corridor	<u>—</u>	<u>240 cms, 300 cms</u>	<u>—</u>
	f. Door Size	<u>—</u>	<u>100 cms x 210 cms 102 cms x 220 cms</u>	<u>—</u>
3.	Compartmentation			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Sealing of electrical shafts	<u>—</u>	<u>Sealed</u>	<u>—</u>
	• Fire Rating of shaft door	<u>—</u>	<u>—</u>	<u>—</u>
	• Water Curtain	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Dampers	<u>—</u>	<u>—</u>	<u>—</u>
4.	Smoke Management System			
	• Basements	<u>30 a/c per hour</u>	<u>—</u>	<u>No Basement</u>
	• Upper floors		<u>Natural Ventilation</u>	<u>MR</u>

N/B.

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	25 Nos	Provided	MR
	• Types	CO ₂ , ABC, WCO ₂	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/R	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	+
	• Location of Main Panel	-	-	+
	• Location of Repeater Panel	-	-	+
	• Alternate source of power	-	-	+
	• Hooters' Location	-	-	+
			D.G. Set of 62.5 KVA	MR
8.	MOEFA			
		-	-	-
9.	Public Address System			
		N/R	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	-	-
	• Number of hydrants per floor	-	-	-
	• Hose Box	-	-	-
12.	Yard Hydrants			
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	—	—	—
		—	180 LPM Each	MR (02 Pumps)
		—	30 m Each	- do -
		—	—	—
		—	—	—
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	5000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	NO Lift
		—	—	- do -
		—	—	- do -
		—	—	- do -
		—	—	- do -
17.	Standby power supply	—	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
		—	—	—
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection System for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/DFS/MS/2011/1472 dated 06.07.2011 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.


Signature of Inspecting Officer

Name P. S. Dahiya

Designation Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation