

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**  
**Fax: 23412593, Tel:- 011-23414333**

No.F6/DFS/MS/EH/2014/ 52/1099

Dated: 21/08/14

**FIRE SAFETY CERTIFICATE**

Certified that the restaurant at Essex Farms Pvt. Ltd., 4, Aurbindo Marg, New Delhi running at ground floor of the building comprised of only ground floor was granted NOC by this department vide letter no. F6/DFS/MS/EH/2011/1987 dated 12.08.2011. The premises was re-inspected by the officer concerned of Delhi Fire Service on 30.07.2014 in the presence of sh. Mathur and other tech. Staff of the restaurant and observed that fire safety norms as required under rule 33 of Delhi Fire Service Rules, 2010 have deemed complied and that the building/ premises is fit for occupancy class-D Assembly "Restaurant" with effect from ~~21/08/14~~ 21/08/14 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010.

Issued on ~~21/08/14~~ at New Delhi by.

**(G.C.Misra)**  
**Chief Fire Officer**

Copy to:

1. The D.H.O (South Zone), Office of Deputy Health Officer, SDMC, South Zone, Green Park, New Delhi.
2. The Director, M/s Essex Farms Pvt. Ltd., 4, Aurbindo Marg, New Delhi-110016

7c  
21/08/14  
ADG (BUP)

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of NBC/BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J"[ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT** Pvt Ltd

1	Name & address of the building	Restaurant at Essex Farms, 4, Aurbindo Marg, New Delhi-110016.		
2	Type of Occupancy	Assembly Building "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/EH/2011/1987 Dated 12.08.2011		
5	Fire safety directives letter No	Nil		
6	Date of inspection	30.07.2014		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj , ADO D.B. Mukherjee		
8	Name and designation of officers	Sh. Mathur & other tech. staff.		
	from the building side			
9	Year of construction			
10	Applicant's letter No.	No. DHO/HD/SZ/2014/D-682 Dated 23.06.2014	(Restaurant running at ground floor )	

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
<b>1</b>	<b>Access to building</b>			
	1) Road width	6 Mtr	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrac</b>	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	1.55 & 1.05Mtr	MR <i>old cov.</i>
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	N/A	N/A
	upper floors	12 a/c per hour	Exhust Fans Provided	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers	ISI	7 Nos	MR
	Types		ABC, Water Co2	MR
	ISI marking		Yes	MR
<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	Required	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5MM	Provided	MR



Automatic fire detection and alarming system:-

	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	N/A	N/A	N/A
10	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	225 LPM	900 LPM Provided	MR
	b. Head of main pump	28 Mtr	Provided	MR
	c. Number of main pumps	One	Provided	MR
	d. jockey pump out put	N/A	180 LPM	MR
	e. jockey pump head	N/A	28 Mtr	MR
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	N/A	N/A	N/A
	b. head of the pump	N/A	N/A	N/A
	c. Power supply	N/A	N/A	N/A
	d. Auto starting of pump	N/A	N/A	N/A
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	MR
	a. Draw-off connection	N/A	N/A	MR
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	MR
	Over head tank Capacity	2500 Ltr	10,000 Ltr	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A
17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>			
	total area	N/A	N/A	N/A
	location	N/A	N/A	N/A

**Fire control room**

a. detector system Panel

N/A

N/A

N/A

b. Flow switch Panel

N/A

N/A

N/A

c. PA system Panel

N/A

N/A

N/A

d. Batter backup

N/A

N/A

N/A

e. Building floor plans

N/A

N/A

N/A

20

**Special Fire Protection systems for protection of special risks, if any: N/A**

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules of NOC issued vide letter no. **F6/DFS/MS/EH/2011/1987 dated 12.08.2011** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly DFA is put up for your approval and signature please.

Signature of the Inspecting Officer

Name D.P. BHARDWAJ

Designation:- D.O. (South)

Signature of the Inspecting Officer

Name :- D.B. Mukherjee

Designation :- ADO (BCP)