

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2014/ *school/1047*

Dated: *21/08/2014*

FIRE SAFETY CERTIFICATE

Certified that Sarvodaya Vidyalaya, Sannoath, Delhi-110040 comprised of Ground + First floor Only owned and occupied by Sarvodaya Vidyalaya, has already been issued fire safety certificate vide letter no. F6/DFS/MS/2011/1566 dated 14/07/2011. The premises was re-inspected by the officer from this department on dated 26/07/2014 in the presence of Sh. Ranbir Singh (Vice Principal) and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education / NBC-Part IV and verified by the officer concerned of Fire Service and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 21 / 08 / 2014 for a period of three years, subject to compliance of the conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 21/08/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

to

The Principal, Sarvodaya Vidyalaya, Sannoath, Delhi-110040

Director of Education, Old Secretariat, Delhi-110054

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2014/ *school/1047*

Dated: *21/08/2014*

FIRE SAFETY CERTIFICATE

Certified that **Sarvodaya Vidyalaya, Sannoath, Delhi-110040** comprised of **Ground + First floor Only** owned and occupied by **Sarvodaya Vidyalaya**, has already been issued fire safety certificate vide letter no. **F6/DFS/MS/2011/1566 dated 14/07/2011**. The premises was re-inspected by the officer from this department on dated **26/07/2014** in the presence of **Sh. Ranbir Singh (Vice Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education / NBC-Part IV and verified by the officer concerned of Fire Service and that the building / premises is fit for occupancy of **Group Class B (Educational)** with effect from **21 / 08 / 2014** for a period of **three years**, subject to compliance of the conditions mentioned below.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on *21/08/14* at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to

1. The Principal, Sarvodaya Vidyalaya, Sannoath, Delhi-110040
2. The Director of Education, Old Secretariat, Delhi-110054

14-3

Two Blk. Single Storey.

INSPECTION REPORT

1. Name & address of the building : Sakvodaya Vidyalaya Sannoth Delhi-40
2. Type of Occupancy : Educational
3. Type of Case : New case/ Renewal
4. Details of previous NOC : F-6/DFS/MS/2011/1366 dt. 14.7.11
5. Fire Safety directives letter No : Dir. of Edu.
6. Date of inspection : 26.7.14
7. Name of the Inspecting Officers : ADO (BW)
8. Name and designation of officers from the building side : Sh. Ranvir Singh, vice Principal
9. Year of Construction : 1996
10. Applicant's letter No. : SV/Sannoth/2014/208 dt. 8.7.14

Plot area- 19742 sqm Covered area- 1124 sqm No's of student- 625 No's of class room- 15

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessable	Accessable	MR ✓
	• Gate width	- do -	- do -	MR ✓
	• Width of internal road	- do -	- do -	MR ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			N/A
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	old case	old case	old case ✓
3	Compartmentation.			
	• Fire check door			N/A
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		N/A
	• Upper floors	12 a/c per hour		
5	Fire Extinguishers			
	• Total numbers	5 ABC	12	MR ✓
	• Types	ISI marked	ABC	MR ✓
	• IS marking		yes	MR ✓

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 			
15	Exit Signage.			

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F-6/DFSI/MS/2011/366 dated 14.7.11 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

20 (a/w) [Signature]

Signature of the Inspecting Officer

Name

Designation

[Signature]
11/8/14
ADO (BW)