

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014 / school/w2/1048

Dated: 21/08/2014

FIRE SAFETY CERTIFICATE

Certified that Shree Keshav Vidya Mandir, B-202, Karan Vihar III, Mangal Bazar, 30 ft Road, Nangloi, New Delhi -110086 comprised of Ground + First Floor Only owned/occupied by Shree Keshav Vidya Mandir has already been issued fire safety certificate vide letter no. F-6/DFS/MS/2007/1432 dated 23/05/2007 (For Ground Floor) The premises was re-inspected by the officer from this department on dated 31/07/2014 in the presence of Sh. Sachin (Manager) and observed that the school is running at Ground Floor only, First floor is being used as residence, all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of Circular issued by Director of Education letter dated 17/01/2005 and the building / premise is fit for occupancy of Group Class B (Educational) with effect from 21 / 08 /2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 21/08/14 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Principal, Shree Keshav Vidya Mandir, B-202, Karan Vihar III, Mangal Bazar, 30 ft Road, Nangloi, New Delhi -110086
2. The Director of Education, Old Secretariat, Delhi.



INSPECTION REPORT

N/2

(GF + PF)

1. Name & address of the building: SHREE KESHAV VIDYA MANDIR, B-202, KARAN VIHAR IV, MANGAL BAZAR, 30 FT ROAD, MAGHANAGLOI, NEW DELHI-86, Educational
2. Type of Occupancy: GF + PF
3. Type of Case: New Case / Renewal
4. Details of previous NOC: F-6/DPS/ms/2007/1432 dt 23-5-2007 For GF only.
5. Fire Safety directives letter No: Circular of the director of Education
6. Date of inspection: 31-7-14
7. Name of the Inspecting Officers: N.P. Sharma
8. Name and designation of officers from the building side: Sh. Sachin (Manager)
9. Year of Construction: 2002
10. Applicant's letter No.: S.K.V.M/12/130-14

Plot area:- 200m² Covered area:- 200m² No.'s of students:- 135 No's of classrooms:- 05

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBE/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	one meter	old case	MR

3	Compartmentation.	NA	NA	NA
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
4	Smoke Management System.	NA	---	---
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NA NA	NA NA
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	02 ISI marked	04 ABC yes	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.	NA		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	NA NA NA	NA NA NA
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	NA	NA	NA
11	Internal Hydrants	NA		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	NA	NA	NA

12	Yard Hydrants.	NA		
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump			
	➤ Head of Main pump			
	➤ Number of main pumps			
	➤ Jockey Pump out put			
	➤ Jockey pump head			
	➤ Standby Pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/ Manual stopping			
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power Supply			
	➤ Auto Starting of pum			
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity			
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity			
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA		
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA

18	Refuge Area.	NA		
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA
		NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. P-6/P.F.S./M.S/2007/1432 Dated 23.05.2007 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

(Signature)

Signature of the Inspecting Officer 31/07/14

Name N.P. Sharma

Designation ADO 'R'

Signature of the Inspecting Officer

Name

Designation

