

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593


No.F.6/DFS/MS/School/2014/ 82/1061

Dated: 22/08/14

FIRE SAFETY CERTIFICATE

Certified that the building of **Shri Nijatam Prem Vidyalaya** located at 17/52, Anand Parbat, New Delhi-110005 is comprised of Basement, ground floor plus two upper floors was issued NOC by this department vide letter No.F.6/DFS/MS/09/1226 dated 06.05.2009. The School building was re- inspected by the officer concerned of this department on 19.08.2014 in the presence of Sh. Anil Dhingra (Manager) and found that the school management have deemed complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on.....22/08/14..... at New Delhi.


(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Ph:- 011-23414333

Copy to:-

1. The Principal,
Shri Nijatam Prem Vidyalaya,
17/52, Anand Parbat, New Delhi-110005.
2. Director of Education,
Govt. of NCT of Delhi, Old Secretariat,
New Delhi – 110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The basement shall be used strictly as per the provisions of the building bye laws.
7. The owner/ occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Basement, Ground Floor plus two upper floors.

N/S.

INSPECTION REPORT

1. Name & address of the building: Shri Nijalam Prem Vidyalaya, 17/S2, Anand Parbat, New Delhi
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/DFS/MS/09/1226 Dated 06.05.2009
5. Fire Safety directives letter No : —
6. Date of inspection : 19.08.2014
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers
From the building side : Sh. Anil Dhingra (Manager)
9. Year of Construction : Before 1980
10. Applicant's letter No. : NPV/S18/2014 dated 01.08.2014

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	<u>Accessible</u>	<u>06mtr</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>250cms</u>	<u>MR</u>
	• Width of internal road	<u>—</u>	<u>—</u>	<u>—</u>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	<u>Two</u>	<u>Two</u>	<u>MR</u>
	• Basements	<u>-do-</u>	<u>-do-</u>	<u>MR</u>
	b. Width of staircases			
	• Upper Floor	<u>—</u>	<u>120cms, 90cms</u>	<u>MR, Old Case</u>
	• Basements	<u>—</u>	<u>110 cms, 210 cms</u>	<u>-do-</u>
	c. Protection of exits			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• pressurization	<u>—</u>	<u>—</u>	<u>—</u>
	d. No. of continuous staircases to terrace	<u>—</u>	<u>Two</u>	<u>—</u>
	e. Width of Corridor	<u>—</u>	<u>450cms, 133cms</u>	<u>—</u>
	f. Door Size	<u>—</u>	<u>95cms x 202cms</u>	<u>—</u>
3.	Compartmentation			
	• Fire check door	<u>—</u>	<u>—</u>	<u>—</u>
	• Sealing of electrical shafts	<u>—</u>	<u>Sealed</u>	<u>—</u>
	• Fire Rating of shaft door	<u>—</u>	<u>—</u>	<u>—</u>
	• Water Curtain	<u>—</u>	<u>—</u>	<u>—</u>
	• Fire Dampers	<u>—</u>	<u>—</u>	<u>—</u>
4.	Smoke Management System			
	• Basements	30 a/c per hour	<u>Exhaust Fans are Provided</u>	<u>MR</u>
	• Upper floors		<u>Natural Ventilation</u>	<u>MR</u>

20

N/B-

		12 a/c per hour		
5.	Fire Extinguishers			
	• Total numbers	12 Nos	Provided	MR
	• Types	ABC, WCO ₂	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G. Set of 62.5 KVA	MR
	• Hooters' Location	-	-	-
8.	MOEFA			
		-	-	-
9.	Public Address System			
		Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	Required	Provided	MR
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100 M.M	MR
	• Number of hydrants per floor	-	One	MR
	• Hose Box	-	- do -	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	One	MR
	• Hose Box	-	- do -	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

N/7


17/S2, Anand Parbat,
New Delhi -

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		900LPM	900LPM, 180LPM	MR (02 Pumps)
		30M Required	30M Each Provided	-do-
		-	-	MR
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
		-	Provided	MR
		-	-	-
		-	5000 Ltr	MR, Old Case
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts:			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
		-	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	-	-	-

M/8.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F.6/AFS/MS/09/1226 dated 06.05.2009 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.



Signature of Inspecting Officer

Name P. S. Dahiya

Designation Asstt. Divisional Officer

Signature of Inspecting Officer

Name

Designation