

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001

NO. F6/DFS/MS/School/2014/SZ/ 1042

DATED: 20/08/14

FIRE SAFETY CERTIFICATE

Certified that the Sulabh International Centre for action Sociology, Sulabh Bhavan, RZ-83, Mahavir Enclave, New Delhi-110045, having two blocks Ground, Ground plus one & ground plus two upper floors have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education GNCT of Delhi Letter No: Estate/CC/FireSafety/2011/3298 Dtd. 01.03.2011, and verified by the officers concerned of Fire Service on 9.8.2014 in presence of Sh. Anil Kumar (Secretary) and that the building is fit for occupancy class B "Educational building" with effect from 20/08/14..... for a period of **three years** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and rule 38 of the Delhi Fire Service Rules, 2010, subject to compliance of the conditions printed overleaf.

Issued on 20/08/14..... at New Delhi by


20/8
(SANTOKH SINGH)
Chief Fire Officer
Ph: 011-23414250

Copy to:

1. The Dy. Director, (Education), G.N.C.T.of Delhi, Old Secretariat, N. Delhi-54.
2. Anil Kumar, Secretary, Sulabh International centre for action Sociology, Sulabh Bhavan, RZ-83, Mahavir Enclave, New Delhi-110045.

20/8

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with a copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1	Name & address of the building	Sulabh International Centre for Action Sociology, Sulabh Bhavan, RZ-83, Mahavir Enclave, New Delhi-110045.	
2	Type of Occupancy	Educational Building "B"	
3	Type of case	NEW	
4	Details of previous NOC	NIL	
5	Fire safety directives letter No	Directorate of Education: F/16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011	
6	Date of inspection	9.8.2014	
7	Name of the inspecting Officers :	ADO S.P. Bhardwaj	
8	Name and designation of officers from the building side	Sh. Anil Kumar (Secretary)	
9	Year of construction	1990, 2010	
10	Applicant's letter No.	F/Fire/31/2014 dated 21.7.2014	2 Blocks : Old Ground & Ground + 1, New: G+2 upper floors

S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	6 Mtrs.	6 Mtrs. ✓	MR
	2) Gate width	Approachable For FE	4.5 Mtrs. ✓	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	4Nos	4 Nos. ✓	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtrs.	4 Nos. 1.04, 1.05, 1.09, .90 Mtrs. ✓	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace			MR
	e. Width of corridor	1.25 Mtrs.	1.25 to 1.80 Mtrs. ✓	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement		N/A	N/A
	upper floors	12 a/c per hour	Natural Vent.	MR
5	Fire Extinguishers			
	total numbers	One Co2 OR ABC for every 300 Sq. Meters	31 Nos. ✓	MR
	Types	ISI Marked	Co2 & ABC	MR
	ISI marking	ISI Marked	Provided	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	1 No. Each floor	1 No. each floor	MR
	Length of Hose reel hose	30 Mtrs.	30 Mtrs.	MR
	Nozzle Diameter	5mm	5 mm	MR
7	Automatic fire detection and alarming system			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	MR
10	Automatic Sprinkler System.			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
12	Yard Hydrants.			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	450 Lpm.	450 Lpm	MR
	b. head of the pump	40 Mtrs.	40 Mtrs.	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	Required	10,000 Ltrs.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

N/S

17	Standby power supply	N/A	N/A	N/A
8	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:	N/A		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, grant of Fire Safety Certificate is recommended under 35 of the Delhi Fire Service Rules, 2010. The shortcomings communicated vide letter no.F6/DFS/MS/School/2014/SZ/1529 dared 30.6.2014 found rectified.

Accordingly DFA is put up for approval and signature please.

S.P. Bhardwaj
11/8/14

Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)