

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI-110001**

No F 6 / DFS / MS / SCHOOL/2014 / W2 / 1078

Dated: 28/08/14

**FIRE SAFETY CERTIFICATE**

Certified that the Amar Convent School, near Sarvodaya Govt. School, H-2 Block Kunwar Singh Nagar, Ranhola Delhi-110041, Comprised of Ground + One upper floor only owned/occupied by Amar Convent School, has already been issued Fire Safety Certificate vide Letter No.F6/DFS/MS/2011/1648 dated 19/07/2011. The Premises was re-inspected by the officer concerned of Fire Service on 11.08.2014 in the presence of Sh. Manoj Kumar and observed that all the fire prevention and Fire Safety arrangements provided in the premises was found in good working condition. The premises have therefore deemed complied with D.O.E. circular No. 3298-3398 Dated 01/03/2011 and the Building/Premises is fit for occupancy class **Educational** with effect from 28 / 08 / 2014 for a period of three years subject to the compliance of the conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanction agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Issued on 28/08/14 at New Delhi by:

  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Principal, Amar Convent School, near Sarvodaya Govt. School, H-2 Block Kunwar Singh Nagar, Ranhola Delhi-110041.

OIC for 2618

**INSPECTION REPORT**

**Ground + One upper floor**

1. Name & address of the Building : **Amar Convent School, near Sarvodaya Govt. School, H-2 Block, Kunwar Singh Nagar, Ranhola, Delhi – 41.**
2. Type of Occupancy : **Educational**
3. Type of Case : **Renewal**
4. Details of previous NOC : Letter No. - **F6/DFS/MS/2011/1648 Dated 17/01/2005**
5. Fire Safety directives Letter No. : **D.O.E. Circular No. 3298-3398 Dated 01/03/2011**
6. Date of inspection : **11.08.2014**
7. Name of the Inspecting Officer : **A.K. Jaiswal A.D.O. (J.W.P. )**
8. Name and designation of Officer  
from the building side : **Manoj Kumar**
9. Year of Construction : **2005**
10. Applicant's letter No. : **Nil. Dated 04.07.2014**

S No	Minimum standards on fire prevention and fire safety U/R 33	DOE Circular 01.03.2011 Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	Provided	MR
	• Gate width	Accessible	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2	2	MR
	• Basements	NA	NA	NA (No Basement)
	b. Width of staircases			
	• Upper floors	Old Case	Old Case	Old Case
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Old Case	Old Case	Old Case
	e. Width Of Corridor	Old Case	Old Case	Old Case
	f. Door Size	Old Case	Old Case	Old Case

3.	Compartmentation			
	• Fire check door	NR	NR	NR
	• Sealing of electrical shafts	NR	NR	NR
	• Fire Rating of shaft door	NR	NR	NR
	• Water Curtain	NR	NR	NR
	• Fire Dampers	NR	NR	NR
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	NA	NA
5.	Fire Extinguishers			
	• Total numbers	4	4	MR
	• Types	ABC/CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	1	Provided & Functioning	MR
	• Length of hose reel hose	30 Mtr.	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NR	NR	NR
	• Location of Main Panel	NR	NR	NR
	• Location of Repeater Panel	NR	NR	NR
	• Alternate source of power	NR	NR	NR
	• Hooters' Location	NR	NR	NR
8.	MOEFA	NR	NP	NR
9.	Public Address System	NR	NP	NR
10.	Automatic Sprinkler System			
	• Basements	NR	NR	NR

	<ul style="list-style-type: none"> <li>• Upper Floor / GF</li> <li>• Sprinkler above false ceiling</li> </ul>	NR	NR	NR
		NR	NR	NR
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level / Over Head			
	• Discharge of main pump	NR	NR	NR
	Head of main pump	NR	NR	NR
	Number of main pumps	NR	NR	NR
	Jockey pump out put	NR	NR	NR
	Jockey pump head	NR	NR	NR
	Standby Pump out put	NR	NR	NR
	Standby Pump Head	NR	NR	NR
	Auto Staring/Manual stopping	NR	NR	NR
	Pump House Access	NR	NR	NR
	• Terrace level			
	Discharge of pump	450 LPM	Provided & Functioning	MR
	Head of the pump	40 MH	Provided & Functioning	MR
	Power supply	Required	Provided	MR
	Auto starting of pump	Required	Provided & Functioning	MR
14.	Captive water Storage for fire fighting			
	• Under Ground tank capacity	NR	NR	NR
	➤ Draw of connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR

	➤ Access to tank			
	• Overhead Tank capacity	5,000Ltr.	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NR	NR	NR
	➤ Pressurization of lift lobby	NR	NR	NR
	➤ Communication in lift Car	NR	NR	NR
	➤ Fireman's Grounding Switch	NR	NR	NR
	➤ Lift Signage	NR	NR	NR
17.	Standby power supply	NR	NR	NR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Batter backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NR	NR	NR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules NOC issued vide letter No. **F6/DFS/MS/2011/1648 Dated 19/07/2011** renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

*Ashok Kumar Jaiswal*  
11/8/14

Signature of the Inspecting Officer

Name : Ashok Kumar Jaiswal

Designation : A.D.O. (Jwala Puri)