

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel: 011-23414333

No.F6/ DFS/ MS/School/2014/ *sz/1104*

Dated: *01/08/14*

**FIRE SAFETY CERTIFICATE**

Certified that Amity International School, Located at 44,M block, Saket, New Delhi-110017 comprised of basement, ground and 03 upper floors, owned/occupied by Amity School Management was issued NOC vide letter no.F6/DFS/MS/2011/2059 dated: 19/08/2011 by this department. The school building was re-inspected by the officer concerned of this department on 20/08/2014 in the presence of Mr. G Hazra (Admn. Officer) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class- Educational (School) with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on ~~19/08/11~~ *01/08/14* at New Delhi by.



**(Dr. G.C. Misra)  
Chief Fire Officer**

*01/08/14*  
*Amity*  
*ADMB*

Copy to: -

Mr.G Hazra  
Amity International School,  
44,M,Block Saket,  
New Delhi-110017

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. The basement shall be used as per the provisions of National Building Code.
5. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : Amity International School, 44, M Block Saket, New Delhi-110017
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/2059 Dated: 19/08/2011
5. Fire Safety directives letter No : Nil
6. Date of inspection : 20/08/2014
7. Name of the Inspecting Officers : D.B. Mukherjee, ADO (BCP)
8. Name and designation of officers  
from the building side : WG CDR G. Hazra (Administrative Officer)
9. Year of Construction : 1990 & 1995
10. Applicant's letter No. : Nil dated: 27/06/2014

(The school is running in two blocks comprised of basement, ground and 3 upper floors and both blocks are connected at each floor level through corridor)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	09 mtrs.	Provided	MR
	• Gate width	05 mtrs.	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
a.	Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	04	MR
b.	Width of staircases			
	• Upper Floors	1.50 m	1.41 m & 1.48m	MR
	• Basements. Protection of exits	1.50m	1.51m, 1.02m, 1.16m, & 1.48m	MR
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
e.	No. of continuous staircases to terrace	01	02	MR
g.	Width of Corridor	N/A	N/A	N/A
h.	Door Size	N/A	N/A	N/A



3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Rating of shaft door</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Water Curtain</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> </ul>	30 a/c per hour	Exhaust fans	MR
	<ul style="list-style-type: none"> <li>• Upper floors</li> </ul>	12 a/c per hour	Natural ventilation	MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> </ul>	Required	56 nos	MR
	<ul style="list-style-type: none"> <li>• Types</li> </ul>	ABC,CO <sub>2</sub>	Provided	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	Required	Provided	MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> </ul>	01	02 nos. Provided	MR
	<ul style="list-style-type: none"> <li>• Length of hose reel hose</li> </ul>	30m	Provided	MR
	<ul style="list-style-type: none"> <li>• Nozzle diameter</li> </ul>	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Location of Main Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Location of Repeater Panel</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Alternate source of power</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Hooters' Location</li> </ul>	N/A	N/A	N/A
8	<b>MOEFA</b>			
		N/A	N/A	N/A
9	<b>Public Address System.</b>			
		N/A	N/A	N/A
10	<b>Automatic Sprinkler System</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>	Required	Provided 02 nos at each floor	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>	Not Required	But Provided	MR
	<ul style="list-style-type: none"> <li>• Hose Box</li> </ul>	Not Required	But Provided	MR



19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One Co <sub>2</sub> extinguisher provided near electric panels.	MR

The fire protection systems provided in the school were test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/2011/2059 Dated: 19/08/2011 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for approval pl.

*Signature*  
25/8/14

*DO (South)*

*Signature*  
25/8/14

Signature of the Inspecting Officer  
Name (D.B.Mukherjee)  
Designation :- Assistant Divisional Officer