

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

Fax: 23412593, Tel: 011-23414333

No.F6/ DFS/ MS/School/2014/ *sz/1103*

Dated: *01/09/14*

FIRE SAFETY CERTIFICATE

Certified that Apeejay School, Located at J Block, Gurudwara Road, Saket, New Delhi-110017 comprised of basement, ground and 03 upper floors owned/occupied by Apeejay School Management was issued NOC vide letter no.F6/DFS/MS/2011/2034 dated: 19/08/2011 by this department. The school building was re-inspected by the officer concerned of this department on 20/08/2014 in the presence of Mr. Anuj Kumar (Admn. Officer) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class- Educational (School) with effect from the date of issue of this certificate for a period of three years, subject to compliance of the below mentioned conditions.

Issued on --*01/09/14*-- at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer

etc

ADO (B&P)

Copy to: -

Mrs. Anita Paul (Principal),
Apeejay School
J Block, Saket,
New Delhi-110017

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. The basement shall be used as per the provisions of National Building Code.
5. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Apeejay School, J Block Gurudwara Road, Saket, New Delhi-110017
2. Type of Occupancy : Educational (School)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/2034 Dated: 19/08/2011
5. Fire Safety directives letter No : Nil
6. Date of inspection : 20/08/2014
7. Name of the Inspecting Officers : D.B. Mukherjee, ADO (BCP)
8. Name and designation of officers
from the building side : Mr. Anuj Kumar (Administrative Officer)
9. Year of Construction : 1988
10. Applicant's letter No. : Nil dated: 21/07/2014

Building is comprised of basement, ground and 3 upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	09 mtrs.	Provided	MR
	• Gate width	4.5 mtrs.	Provided	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
a. Number of staircases				
	• Upper Floors	02	03	MR
	• Basements	02	03	MR
b. Width of staircases				
	• Upper Floors	1.50 m	1.46 m, 1.44m & 1.45m	MR
	• Basements	1.50m	1.37m, 1.25m & 1.17m	MR
c. Protection of exits				
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
e. No. of continuous staircases to terrace				
		01	03	MR
g. Width of Corridor				
		N/A	N/A	N/A
h. Door Size				
		N/A	N/A	N/A

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Exhaust fans	MR
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	Natural ventilation	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	Required	13 nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC,CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	01	03 nos. Provided	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30m	Provided	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Not Required	But Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System			
	<ul style="list-style-type: none"> • Basement 	Required	Provided	MR
	<ul style="list-style-type: none"> • Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	Required	Provided	MR
	<ul style="list-style-type: none"> • Number of hydrants per floor 	Required	Provided 03 nos at each floor	MR
	<ul style="list-style-type: none"> • Hose Box 	Required	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hose Box 	N/A	N/A	N/A

13	Pumping Arrangements			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 900 LPM 40 mtrs. Required Required	 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided Provided Provided Provided	 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	 N/A N/A N/A N/A 5,000 L	 N/A N/A N/A N/A 5,000 L	 N/A N/A N/A N/A MR
15	Exit Signage.			
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	 N/A N/A N/A N/A N/A	 N/A N/A N/A N/A N/A	 N/A N/A N/A N/A N/A
17	Standby power supply			
18	Refuge Area			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A

19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO ₂ extinguisher provided near electric panels.	MR

The fire protection systems provided in the school were test checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no F6/DFS/MS/2011/2034 Dated: 19/08/2011 renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for approval pl.

[Handwritten Signature]
25/8/14

Signature of the Inspecting Officer
Name (D.B.Mukherjee)
Designation :- Assistant Divisional Officer

DD *[Handwritten]*

[Handwritten Signature]
25/8/14