

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Fax: 23412593, Tel: 011-23414333

No. F.6/DFS/MS//2014/ 52/1101

Dated: 01/09/14

**FIRE SAFETY CERTIFICATE**

Certified that Bipin Chandra Pal Memorial Trust, located at A-81,C.R.Park New Delhi-110019 comprised of basement, ground and 01 upper floor owned/occupied by Bipin Chandra Pal Memorial Trust was issued NOC vide letter no. F6/MS/DFS/99/674 dated: 03/08/1999 by this department. The building was re-inspected by the officer concerned of this department on 21/08/2014 in the presence of Mr.S.K.Chakraborty (Manager) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class- **Assembly** (Community Hall) with effect from ~~01/09/14~~ for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 .

Issued on ~~01/09/14~~ at New Delhi by.



(Dr. G.C. Misra)  
Chief Fire Officer

CLC  
11/9/14  
ADO(BLP)

Copy to: -

Mr. R. D. Choudhury  
Executive Trustee,  
A-81,C.R.Park  
New Delhi-110019

**Conditions for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [ sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building:- Bipin Chandra pal Memorial Bhawan, A-81, C.R. Park,  
New Delhi - 110019
2. Type of occupancy:- Community Hall
3. Type of case: - Renewal
4. Details of previous NOC:- F6/MS/DFS/99/674 dated: 03/08/1999
5. Fire safety directives No.- F6/DFS/MS/BP/95/483 dated-24/04/1995
6. Date of inspection:- 21/08/2014
7. Name of the inspecting officer:- D.B. Mukherjee A.D.O. (BCP)
8. Name & designation of officer From the building side: - Mr. S.K. Chakraborty (Manager)
9. Year of construction:- 1990
10. Applicant's letter No:- Nil Dated 07/07/2014
- Building is comprised of basement, ground and one upper floor

Sl. No	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
<b>1.</b>	<b>Access to Building</b>			
	1) Road width	9m	Provided	MR
	2) Gate width	5 m	Provided 02 nos. 5.90m & 5.90m	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2.</b>	<b>Number, Width Type &amp; Arrangement of Exits</b>			
	A. Number of staircases			
	1. Upper floors	02 Nos.	02 nos.	MR
	2. Basements	02 Nos.	02 nos.	MR
	B. Width of staircase			
	1. Upper floors	1.20 m	1.98m & 2.07m	MR
	2. Basements	1.20 m	1.36 m & 1.45m	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	02	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
<b>3.</b>	<b>Compartmentation</b>			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4.</b>	<b>Smoke Management System</b>			
	1) Basements	30 a/c per hour	Provided exhaust fans	MR
	2) Upper floors	12 a/c per hour	Natural	MR
<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	ISI Marked	24no	MR
	2) Types		ABC, Co2	MR
	3) ISI marking		Yes	MR



41/3


<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01 no.	Provided	MR
	2) Length of hose reel hose	30 m	Provided	MR
	3) Nozzle diameter	5 mm	Provided	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	Required	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants -</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants - Not required but provided</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	<b>1) Ground level</b>			
	a) Discharge of main pump	720Lpm	Provided	MR
	b) Head of main pump	37m	37m	MR
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	720Lpm	Provided	MR
	g) Stand by pump head	37m	Provided	MR
	h) Auto starting/Manual stopping	Required	Provided	MR
	<b>2) Terrace level</b>			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	50,000ltr	50,000ltr	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	15,000 ltr	15,000 ltr	MR
<b>15.</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16.</b>	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
<b>17.</b>	<b>Stand by Power Supply</b>	Yes	Provided DG Set	MR
<b>18.</b>	<b>Refuge Area</b>	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A

2/14

19.	<b>Fire Control Room</b>	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	<b>Special Fire Protection System for Protection of special Risk, if any:</b>			N/A
				N/A

The fire protection system provided in the building were checked and found functional at the time of inspection. Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the NOC issued vide letter no renewal under rules 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for approval pl.

  
25/6/14

Signature of the inspecting officer

Name: - D.B. Mukherjee

Designation:- Assistant Divisional Officer (BCP)