

NO.F6/DFS/MS/2014/SZ/ 1095

DATED: 01/09/14

FIRE SAFETY CERTIFICATE

Certified that the M/s G-Bar Discotheque situated at Hotel "The Grand " at Plot No. 2, Nelson Mandela Road, Vasant Kunj, New Delhi-110070 running at ground floor at the building comprised of two tier basements ground plus five upper floors owned/occupied by M/s Hotel The Grand have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Delhi Fire Service on 28.07.2014 in the presence of Sh. Ravi Medade (Fire Officer) of the building is fit for occupancy class D " Assembly" with effect from...01/09/14... for a period of 3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to the conditions mentioned below

Issued on ...01/09/14..... at New Delhi by


(Dr. G.C. Misra)
Chief Fire Officer

Copy To:-

1. The Authorized Signatory, M/s The Grand Hotel located at Plot No. 2, Nelson Mandela Road, Vasant Kunj, New Delhi-110070.
2. The Addl. Commissioner of Police (Lic.), First Floor, Police Station, Defence Colony New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| | | | |
|-----------------------------------|--|---|--|
| Name & address of the building | M/s G-Bar Discotheque situated at Hotel "The Grand " at Plot No. 2, Nelson Mandela Road, Vasant Kunj, New Delhi-110070 | | |
| Type of Occupancy | Assembly "D" Discotheque | | |
| Type of case | New | | |
| Details of previous NOC | No | | |
| Fire safety directives letter No | No | | |
| Date of inspection | 28.07.2014 | | |
| Name of the inspecting Officers : | DO D.P. Bhardwaj, ADO D.B. Mukherjee | | |
| Name and designation of officers | Sh. Ravi Medade | | |
| from the building side | | | |
| Year of construction | 1995 | two tier basements ground plus five upper floors | |
| Applicant's letter No. | 23608-13/Jt.C.P/Lic.(Amst.) Dated 01.07.2014 | (Discotheque running at ground floor) | |

| S. NO. | Minimum Standards on fire prevention and fire safety U/R 33 | BBL/NBC Requirement | Provided at site | Remarks MR / NMR |
|----------|---|---|-----------------------------|------------------|
| 1 | Access to building | | | |
| | 1) Road width | 9 Mtr | Provided | MR |
| | 2) Gate width | 4.5 Mtr | Provided | MR |
| | 3) Width of internal road | 6 Mtr | Provided | MR |
| 2 | Number, width Type & arrangement of exits | | | |
| | a. Number of staircases | | | |
| | 1. Upper floors | N/A | N/A | N/A |
| | 2. basements | N/A | N/A | N/A |
| | b. Width of staircase | | | |
| | 1. Upper floors | N/A | N/A | N/A |
| | 2. basements | N/A | N/A | N/A |
| | c. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | d. No. of continuous staircase to terrace | N/A | N/A | N/A |
| | e. Width of corridor | N/A | N/A | N/A |
| | f. Door size | 1.5 Mtr | Provided 2 Nos 1.5 Mtr each | MR (Old Case) |
| 3 | Compartmentation. | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Sealing of electrical shafts | N/A | N/A | N/A |
| | 3. Fire Rating of shaft door | N/A | N/A | N/A |
| | 4. water curtain | N/A | N/A | N/A |
| | 5. Fire dampers | N/A | N/A | N/A |
| 4 | Smoke Management system. | | | |
| | basement | 30 a/c per hour | N/A | N/A |
| | upper floors | 12 a/c per hour | Provided | MR |
| 5 | Fire Extinguishers | Provided & Maintain by Hotel | | |
| | total numbers | do | do | do |
| | Types | do | do | do |
| | ISI marking | do | do | do |
| 6 | First-Aid Hose Reels. | Provided & Maintain by Hotel | | |
| | total numbers on each floor | do | do | do |
| | Length of Hose reel hose | do | do | do |
| | Nozzle Diameter | do | do | do |

| | | | | |
|----|---|---|----|----|
| 7 | Automatic fire detection and alarming system:- | Provided & Maintain by Hotel | | |
| | Type of detectors | do | do | do |
| | location of Main Panel | do | do | do |
| | location of Repeater panel | do | do | do |
| | Alternate source of power | do | do | do |
| | hooter's location | do | do | do |
| 8 | MOEFA | Provided & Maintain by Hotel | | |
| 9 | Public Address System. | Provided & Maintain by Hotel | | |
| 10 | Automatic Sprinkler System. | Provided & Maintain by Hotel | | |
| | basement | do | do | do |
| | upper floors | do | do | do |
| | sprinkler above false ceiling | do | do | do |
| 11 | Internal Hydrants | Provided & Maintain by Hotel | | |
| | Size of riser/down-corner | do | do | do |
| | Number of Hydrants per floor | do | do | do |
| | hose Box | do | do | do |
| 12 | Yard Hydrants. | Provided & Maintain by Hotel | | |
| | total number of hydrants | do | do | do |
| | hose box | do | do | do |
| 13 | Pumping arrangements | Provided & Maintain by Hotel | | |
| | 1. Ground level | | | |
| | a. Discharge of main Pump | do | do | do |
| | b. Head of main pump | do | do | do |
| | c. Number of main pumps | do | do | do |
| | d. jockey pump out put | do | do | do |
| | e. jockey pump head | do | do | do |
| | f. Standby Pump output | do | do | do |
| | g. Stanby Pump head | do | do | do |
| | h. Auto Starting/Manual stopping | do | do | do |
| | pump house access | do | do | do |
| | 2. Terrace level | | | |
| | a. Discharge of pump | do | do | do |
| | b. head of the pump | do | do | do |
| | c. Power supply | do | do | do |
| | d. Auto starting of pump | do | do | do |
| 14 | Captive water storage for fire fighting | Provided & Maintain by Hotel | | |
| | 1. Underground tank capacity | do | do | do |
| | a. Draw-off connection | do | do | do |
| | b. fire service inlet | do | do | do |
| | c. Access to tank | do | do | do |
| | Over head tank Capacity | do | do | do |
| 15 | Exit Signage. | Provided & Maintain by Hotel | | |
| 16 | Provision of lifts. | Provided & Maintain by Hotel | | |
| | a. Pressurization of lift shaft | do | do | do |
| | b. pressurization of lift lobby | do | do | do |
| | c. communication in lift car | do | do | do |
| | d. Fireman's grounding switch | do | do | do |
| | e. Lift signage | do | do | do |
| 17 | Standby power supply | Provided & Maintain by Hotel | | |
| 18 | Refuge Area. | Provided & Maintain by Hotel | | |
| | total area | do | do | do |
| | location | do | do | do |

| Fire control room | Provided & Maintain by Hotel | | |
|--------------------------|------------------------------|----|----|
| a. detector system Panel | do | do | do |
| b. Flow switch Panel | do | do | do |
| c. PA system Panel | do | do | do |
| d. Batter backup | do | do | do |
| e. Building floor plans | do | do | do |

| | |
|----|---|
| 20 | Special Fire Protection systems for protection of special risks, if any: <p style="text-align: right;">Provided & Maintain by Hotel</p> |
|----|---|

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rule it is recommended to grant of Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010

Accordingly DFA is put up for your approval and signature please.

Signature of the Inspecting Officer
 Name D.P. BHARDWAJ
 Designation:- D.O. (South)

Signature of the Inspecting Officer
 Name :- D.B. Mukherjee
 Designation :- ADO (BCP)