

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

Fax:- 011-23412593

E-mail ID: cfhq.dlfire@nic.in

No F6/DFS/MS/Auditorium/2014/M02/1072 Dated 27/08/14

FIRE SAFETY CERTIFICATE

Certified that the **Indian National Theatre Trust (Shri Ram Centre Auditorium)** located at **4 Safdar Hashmi Marg, New Delhi** comprises of **Basement, Ground + 2 upper floors** was granted NOC by this department vide letter No. F6/DFS/MS/2011/1363 dated 28-06-2011. The premises was re-inspected by the officer concerned of this department on 07-07-2014 in the presence of Wg. Cdr. R S Kanwar (Manager Administration) and found that the said Auditorium have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy Class **Group D Assembly Building Sub Division D-2** with effect from ~~27/08/~~ 2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 27/08/14..... at New Delhi by.

(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph – 011-23414333

Copy to:-

1. The Joint. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi – 110049 w.r.t. letter No. 4684-89/Joint. C.P./Lic(H) dated New Delhi the 30-01-2014.
2. Sh. Wg. Cdr. R S Kanwar (Manager Administration) Indian National Theatre Trust (Shri Ram Centre Auditorium) located at 4 Safdar Hashmi Marg, New Delhi.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Indian National Theatre Trust (Shri Ram Centre Auditorium)
located at 4 Safdar Hashmi Marg, New Delhi.
2. Type of Occupancy : Assembly Building (B + Gr. + 02 upper floors)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/1363 dated 28/06/2011
5. Fire Safety directives Letter No. : NA
6. Date of inspection : 07/07/2014
- 7 Name of the Inspecting Officer : Sh. Gurmukh Singh (DO/CD) & Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Sh. Wg. Cdr. R S Kanwar (Manager Administration)
- 9 Year of Construction : old building
10. Applicant's letter No. : No.4684-89/Joint C.P./Lic.(Amst.) dated 30/01/14.

Old Case

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 Mtr.	12 Mtr.	MR
	• Gate width	4.5 Mtr.	5 Mtr.	MR
	• Width of internal road	6 Mtr.	6 Mtr.	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	2 Nos.	3 Nos.	MR
	• Basements	2 Nos.	2 Nos.	MR
	b. Width of staircases			
	• Upper floors	1.50 Mtr. each	1.50 Mtr. each	MR
	• Basements	1.0 Mtr. each	1.10 Mt & 1.50 Mtr.	MR
	c. Protection of exits			
	• Fire check door	Required	Provided	MR

	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	2 Nos.	2 Nos.	MR
	e. Width Of Corridor	1.0 Mtr.	1.50 Mtr.	MR
	f. Door Size	1.0 Mtr.	1.50 Mtr.	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	Required	Provided	MR
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	Required	Provided	MR
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	30 ACPH	Mechanical	MR
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	40 Nos.	44 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	03	03	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	At G. floor	At G. floor	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	DG Set	DG Set	MR
	<ul style="list-style-type: none"> • Hooters' Location 	All floors	All floors	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	MR

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	Required NA	Provided NA	MR NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box per floor 	100 MM 2 Nos. 2 Nos.	100 MM 2 Nos. 2 Nos.	MR MR MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	02 02	02 02	MR MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put(Diseal) Standby Pump Head auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA 180 LPM 35 Mtr. 1800 LPM 70 Mtr. Required Required NA NA NA NA NA	NA NA NA 180 LPM 35 Mtr. 1800 LPM 70 Mtr. Provided Provided NA NA NA NA	NA NA NA MR MR MR MR MR MR NA NA NA NA NA
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet Access to tank Overhead Tank capacity 	50,000 Ltr. Required Required Required 20,000 Ltr.	70,000 Ltr. Provided Provided Provided 20,000 Ltr.	MR MR MR MR MR


N/10

15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> • Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> • Communication in lift Car 	Required	Provided	MR
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	Required	Provided	MR
	<ul style="list-style-type: none"> • Lift Signage 	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area 	NA	NA	NA
	<ul style="list-style-type: none"> • Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> • Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC, Co ₂	MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/1363 dated 28/06/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended please.

Signature of the Inspecting Officer



Name :- Sh. Gurmukh Singh
Designation :-DO(CD)

Signature of the Inspecting Officer



Name:- Sh. M. K. Sharma
Designation :- A. D.O. (CC)