

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/2014 / school / w2 / 1075

Dated: 28/08 /2014

**FIRE SAFETY CERTIFICATE**

Certified that Jay Pee Public School, 45,46, Vijay Vihar, C-Block, Rohini, Sector 4, Delhi-85 comprised of Ground + One upper floor owned/occupied by Jay Pee Public School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 28/07/2014 in the presence of Mrs. R.R Arya (Principal) and that the building / premises is fit for occupancy of Educational building with effect from 28 / 08 /2014 for a period of three years, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 28/08/14 at New Delhi



(Dr. G.C. Mishra)  
Chief Fire Officer  
Ph: 011-23414333

**Copy to:**

1. The Principal, Jay Pee Public School, 45,46, Vijay Vihar, C-Block, Rohini, Sector 4, Delhi-85
2. The Director of Education, Old Secretariat, Delhi.



## INSPECTION REPORT

1. Name & address of the building: JAY PEE PUBLIC SCHOOL, U5-46 VIJAY VIHAR  
C-BLOCK, ROHINI, DELHI-85
2. Type of Occupancy : Educational
3. Type of Case : New Case / Renewal (GF + F.F.)
4. Details of previous NOC : .....
5. Fire Safety directives letter No : Circular of the director of Edn dt- 01-3-11
6. Date of inspection : 28-7-14
7. Name of the Inspecting Officers : N.P. Sharma
8. Name and designation of officers  
from the building side : ms R.R. Arya
9. Year of Construction : 2000 ✓
10. Applicant's letter No. : - 7-7-14

Plot area:- 450 sqds Covered area:- 200 sqds No.'s of students:- 150 No's of classrooms:- 09.

### Minimum Standards on fire prevention and fire safety U/R 33

Dir. of Edu  
BBE/NBE  
Requirement

Provided at site

Remarks  
MR/NMR

#### 1 Access to building

- Road width
- Gate width
- Width of internal road

Accessible

Accessible

MR ✓

#### 2 Number, Width, Type & Arrangement of Exits

##### a. Number of staircases

- Upper Floors
- Basements

R

P

MR ✓

01 ✓

02 ✓

MR ✓

NA

NA

NA

##### b. Width of staircases

- Upper Floors
- Basements

1.5 mtr

1- 1.5 mtr  
2- 1.4 mtr

MR ✓

NA

NA

NA

##### c. Protection of exits

- Fire check door
- Pressurization

NA

NA

NA

NA

NA

NA

NA

NA

NA

##### e. No. of continuous staircases to terrace

NA

NA

NA

##### g. Width of Corridor

NA

NA

NA

##### h. Door Size

One meter

1.0 mtr

MR ✓

3	<b>Compartmentation.</b>		NA	NA	NA
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>		NA	NA	NA
4	<b>Smoke Management System.</b>				
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour	NA	NA	NA
5	<b>Fire Extinguishers</b>				
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	02 ISI marked	04 ABC yes	MR	MR
6	<b>First-Aid Hose Reels.</b>		NA		
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm	NA	NA	NA
7	<b>Automatic fire detection and alarming system.</b>		NA		
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>		NA	NA	NA
8	<b>MOEFA</b>		NA	NA	NA
9	<b>Public Address System.</b>		NA	NA	NA
10	<b>Automatic Sprinkler System.</b>		NA		
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>		NA	NA	NA
11	<b>Interrial Hydrants</b>		NA		
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>		NA	NA	NA

12	<b>Yard Hydrants.</b>	NA		
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA	NA	NA
13	<b>Pumping Arrangements.</b>	NA		
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pum</li> </ul> </li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
14	<b>Captive Water Storage for fire fighting.</b>	NA		
	<ul style="list-style-type: none"> <li>Underground tank capacity <ul style="list-style-type: none"> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> </ul> </li> <li>Overhead Tank capacity</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15	<b>Exit Signage.</b>	NA		
		NA	NA	NA
16	<b>Provision of Lifts.</b>	NA		
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17	<b>Standby power supply</b>	NA		
		NA	NA	NA

117

18	<b>Refuge Area.</b>	NA		
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	<b>Fire Control Room</b>	NA		
	• Detector System Panel			
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

*M.P. Sharma*

Signature of the Inspecting Officer 30-7-14

Name M.P. Sharma

Designation ADO R

Signature of the Inspecting Officer

Name

Designation

