


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI

No FG/DFS/MS/2014/S2/107/ Dated 27/08/14

FIRE SAFETY CERTIFICATE

Certified that the "The Musical Fountain Complex (Block 3) located at Netaji Nagar, New Delhi, comprised of Ground Floor only Owned/Occupied by Applause Hospitality Services Pvt. Ltd., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verified by the officers concerned of Fire Service on 19.08.2014 in the presence of Mr. Batra and found that the premises is fit for occupancy class - D Assembly Building with effect from 27/08/14... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...27/08/14..... at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
T.No011-23414333

Copy to: - Sh. P.J.Thareja

Authorised Signatory , Applause Hospitality Services Pvt. Ltd.

Musical Fountain Complex Netaji Nagar, New Delhi,

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: Musical Fountain Complex, (Block 3 only)
at Netaji Nagar, New Delhi.
2. Building comprises of : Ground floor only.
3. Type of Occupancy : Assembly
4. Type of Case : New
5. Details of previous NOC : N/A
6. Fire Safety directives Letter No. : F6/DFS/MS/2014/170 Dated 16.06.2014
7. Date of inspection : 19.08.2014
8. Name of the Inspecting Officer : Atul Garg (Dy.CFO), Vedpal(ADO)
9. Name and designation of Officer
from the building side : Mr. Batra
10. Year of Construction : 2014
11. Applicant letter No. : Party letter No. Nil Dated 01.08.2014

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6 mtr.	Main Road	MR
	• Gate width	5 mtr	6 mtr.	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	b. Width of staircases			
	• Upper floors	N/A	N/A	N/A
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	1no.	01no.	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size	03 No. 2 mtr. each 02 No. 1 mtr. each	Provided	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
		N/A	N/A	N/A

NIS

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto starting of pump 	N/A	N/A	N/A
		450 Lpm	450LPM	MR
		40 M	40 M	MR
		Required	Provided	MR
		Required	Provided	MR
14.	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> • Under ground tank capacity ➤ Draw of connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		YES	YES	MR
		N/A	N/A	N/A
		10000 Liters	10000 Liters	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none"> ➤ Pressurization of Lift Shaft ➤ Pressurization of lift lobby ➤ Communication in lift Car ➤ Fireman's Grounding Switch ➤ Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> ➤ Total area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire control room			
	<ul style="list-style-type: none"> ➤ Detector system panel ➤ Flow Switch Panel ➤ PA System Panel ➤ Batter backup ➤ Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name Atul Garg

Name Vedpal

Designation Dy.CFO

Designation ADO