

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/school/2014/W2/1097

Dated: 01/08/2014

FIRE SAFETY CERTIFICATE

Certified that **Rising Era Convent School, Khera Khurd, Delhi - 110082** comprised of **Ground Floor Only** owned / occupied by **Rising Era Convent School**, has already been issued fire safety certificate vide this office **letter No F-6/DFS/MS/2011/1799 dated 29/07/2011**. The premise was re-inspected by the officer from this department on dated **11/08/2014** in the presence of **Sh. S. C. Bhardwaj (Manager)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have there fore deemed complied with the requirements of **Circular No F.16/Estate/cc/Fire Safety /2011/ 3298-3398 dated 01/03/2011** and the building/premise is fit for occupancy of **Group Class B (Educational)** with effect from **01 / 08 /2014** for a period of **three years**, subject to compliance of the conditions.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 01/08/14 at New Delhi by


(Dr. G.C. Mishra)
Chief Fire Officer
Ph: 011-23414333

Copy to:

1. The Principal, Rising Era Convent School, Khera Khurd, Delhi - 110082
2. The Director of Education, old Secretariat, Delhi.



INSPECTION REPORT

1. Name & address of the building : *Rising Era Convent School Kharakhead Delhi-82*
2. Type of Occupancy : *Educational*
3. Type of Case : *New case/ Renewal*
4. Details of previous NOC : *F-6/DFS/MS/2011/1799 dt. 29.7.14*
5. Fire Safety directives letter No : *Dir. of Edu. 1-3-11*
6. Date of inspection : *11.2.14*
7. Name of the Inspecting Officers : *ADD (B)*
8. Name and designation of officers from the building side : *Sh. S.C. Bhardwaj Manager*
9. Year of Construction : *2009*
10. Applicant's letter No. : *RECS/14-15/007 dt. 30.7.14*

Plot area- *1035 Sq. yards* Covered area- *600 Sq. yards* No's of student- *80* No's of class room- *6*
2 room other purpose.

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<i>Accessible</i>	<i>Accessible</i>	<i>MR ✓</i>
	• Gate width	<i>-</i>	<i>-</i>	<i>-</i>
	• Width of internal road	<i>-</i>	<i>-</i>	<i>-</i>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<i>1 mtr</i>	<i>1 mtr</i>	<i>MR</i>
3	Compartmentation.			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	<i>30 a/c per hour</i>		
	• Upper floors	<i>12 a/c per hour</i>		
5	Fire Extinguishers			
	• Total numbers	<i>2 ABC</i>	<i>2</i>	<i>MR ✓</i>
	• Types	<i>ABC</i>	<i>ABC</i>	<i>MR ✓</i>
	• IS marking	<i>ISI marked</i>	<i>Yes</i>	<i>MR ✓</i>

- Length of hose reel hose 50 m
- Nozzle diameter 5 mm

7 Automatic fire detection and alarming system.

- Type of detectors
- Location of Main Panel
- Location of Repeater Panel
- Alternate source of power
- Hooters' Location

N/A

8 MOEFA

9 Public Address System.

10 Automatic Sprinkler System.

- Basement
- Upper Floor
- Sprinkler above false ceiling

11 Internal Hydrants

- Size of riser/down-comer
- Number of hydrants per floor
- Hose Box

N/A

12 Yard Hydrants.

- Total number of hydrants
- Hose Box

13 Pumping Arrangements.

- Ground Level
 - Discharge of main Pump
 - Head of Main pump
 - Number of main pumps
 - Jockey Pump out put
 - Jockey pump head
 - Standby Pump out put
 - Standby Pump Head
 - Auto Starting/ Manual stopping
 - Pump House Access
- Terrace level
 - Discharge of pump
 - Head of the pump
 - Power Supply
 - Auto Starting of pump

N/A

14 Captive Water Storage for fire fighting.

- Underground tank capacity
 - Draw-off connection
 - Fire service inlet
 - Access to tank
- Overhead Tank capacity

N/A

	<ul style="list-style-type: none"> • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. P-6/DFS/45/2011/1799 dated 29-7-11 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature

Signature of the Inspecting Officer

Name

Designation

Signature
15/8/14

ASO (B.W)