

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2014/W2/1088

Dated: 29/08/2014

FIRE SAFETY CERTIFICATE

Certified that **Sant Sujan Singh Ji International School, Kushak No-2, Saroop Nagar, Delhi** comprised of **Ground + Two upper floor** owned / occupied by **Sant Sujan Singh Ji International School** has already been issued fire safety certificate vide letter no. **F6/DFS/MS/2009/2429 dated 06/08/2009**. The premises was re-inspected by the officer from this department on **07/07/2014** in the presence of **Smt. Mandira Yadav (Principal)** and observed that a temporary shed for storage of furniture is added on the terrace. All the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular issued by Director of Education letter dated 17/01/2005** and verified by the officer concerned of Fire Service and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **29 / 08 /2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 6 The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [Sub rule (1) of rule 37] along with a copy of this Certificate, Six months prior to its expiry.
- 7 The storage made in the shed on terrace shall be removed over shed not used for any other purpose including conducting classes.
- 8 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 29/08/14 at New Delhi

(Dr. G.C. Mishra)
Chief Fire Officer
Ph: 011-23414333

Copy to:

1. The Principal, Sant Sujan Singh Ji International School, Kushak No-2, Saroop Nagar, Delhi.
2. The Director of Education, Old Sectt. Delhi

INSPECTION REPORT

Ground + 2 upper floor + Temp. Shed Hall

1. Name & address of the building : Sant Sujan Singh Ji International School, Kushak No-2, Saroop Nagar, Delhi
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2009/2429 dated 06/08/2009
5. Fire Safety directives letter No : Dir. Of Education / NBC Part-IV
6. Date of inspection : 07/07/2014
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers from the building side : Smt. Mandira Yadav (Principal)
9. Year of Construction : 1998
10. Applicant's letter No. : SSSRIS/14-15/26-A dated 26/05/2014

Plot Area- 11957.09 Sq. Yds. Covered Area- 2400 M². No of Students- 1000 No of Class Room-31

Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. / NBC Requirement	Provided at site	Remarks MR/NMR
1 Access to building			
• Road width	Accessible	Accessible	M/R
• Gate width	Accessible	Accessible	M/R
• Width of internal road	--	--	--
2 Number, Width, Type & Arrangement of Exits			
a. Number of staircases			
• Upper Floors	02	03	M/R
• Basements	--	--	--
b. Width of staircases			
• Upper Floors	1.5 mtr	1.5 mtr each	M/R
• Basements	--	--	--
c. Protection of exits			
• Fire check door	--	--	--
• Pressurization	--	--	--
e. No. of continuous staircases to terrace	01	01	M/R
g. Width of Corridor	--	--	--
h. Door Size	01 mtr	1 mtr	M/R
3 Compartmentation.			
• Fire check door	N/A	N/A	N/A
• Sealing of electrical shafts	N/A	N/A	N/A
• Fire Rating of shaft door	N/A	N/A	N/A
• Water Curtain	N/A	N/A	N/A

5	Fire Extinguishers	One @ 300 m each	20	M/R
	<ul style="list-style-type: none"> Total numbers Types IS marking 		ABC	M/R
		ISI marked	Yes	M/R
6	First-Aid Hose Reels.	Three at each floor	P	M/R
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	P P	M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm	P	M/R
		03	03 at each floor	M/R
		N/A	N/A	N/A
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping <ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		180 LPM	P	M/R
		40 M	P	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		R	P	M/R
		R	P	M/R
		450 LPM	P	

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 ltr	P	M/R
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	R	62 KVA	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The temp shop at 3rd floor used for storage waste/old furniture (Affiliate)

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no **F6/DFS/MS/2009/2429 dated 06/08/2009** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

(1/2)

Joseph
4/8/14

N/A

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 ltr	P	M/R
15	Exit Signage.	N/A	N/A	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	R	62 KVA	M/R
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The temp shop at 3rd floor used for storage waste / old furniture (Affiliated Engg)

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC issued vide letter no **F6/DFS/MS/2009/2429 dated 06/08/2009** renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

DeFO (W/2)

Signature
5/8/14

What about fire safety arrangements on terrace. He