

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001.**

E-mail:- cfohq.dlfire@nic.in

Fax:- 011-23412593

No-F6/DFS/MS/EH/2014/SZ/1082

Date- 28/08/14

FIRE SAFETY CERTIFICATE

Certified that the **M/S Spinns Restaurant**, G-2A & G-2B, ground floor, Sonia PVR complex, Vikaspuri, New Delhi 110018 is running at ground floor of the Sonia PVR complex building. The restaurant building was issued NOC by this department vide letter No. F6/DFS/MS/EH/2011/1989 dated 12.08.2011 owned/occupied by M/S Spinns Restaurant. The Restaurant building was re-inspected by the officers concerned of this department on 21.08.2014 in the presence of Sh. Sachin Kumar (Shift Manager) and found that the management have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the restaurant building (**at ground floor only**) is fit for occupancy class Group D assembly building w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on..... 28/08/14at New Delhi.


28/8

(DR. G.C. MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph:- 011-23414333


MCS
28/8/14

Copy to:-

1. The Manager,
M/S Spinns Restaurant,
J G-2A & G-2B, Sonia PVR complex,
Vikaspuri, New Delhi 110018
2. Dy. Health Officer,
South Zone Municipal Corporation,
Public Health Department, West Zone,
Vishal Enclave, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per the building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

N/4

M/S Spinns Restaurant is running at G-2A & G-2B, ground floor only of Sonia PVR complex, Vikaspuri, New Delhi 110018

INSPECTION REPORT

1. Name & address of the building: M/S Spinns Restaurant, G-2A & G-2B, ground floor only of Sonia PVR complex, Vikaspuri, New Delhi 110018.
2. Type of Occupancy : Group D (Assembly)
3. Type of Case : Renewal
4. Details of Previous NOC : F6/DFS/MS/EH/2011/1989 dated 12.08.2011.
5. Fire Safety directives letter No : Nil.
6. Date of inspection : 21.08.2014
7. Name of Inspecting Officer : D.O. S.K. Tomar and A.D.O. Sandeep Duggal
8. Name and designation of officers
From the building side : Sh. Sachin Kumar (Shift Manager)
9. Year of Construction : 2011
10. Applicant's letter No. : Nil dated Nil

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/ BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	Accessible	09 mtrs 200, 125, 125 cms	M/R M/R —
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	— —		
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	—	—	(Restaurant at Ground Floor only)
	<ul style="list-style-type: none"> • Upper Floors • Basements 	—	—	(Restaurant at Ground Floor only)
	b. Width of staircases	—	—	(Restaurant at Ground Floor only)
	<ul style="list-style-type: none"> • Upper Floor • Basements 	—	—	(Restaurant at Ground Floor only)
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	—	—	(Restaurant at Ground Floor only)
		—	—	(Restaurant at Ground Floor only)
	d. No. of continuous staircases to terrace	—	—	(Restaurant at Ground Floor only)
	e. Width of Corridor	—	Opening in hall	—
	f. Door Size	—	95 cms	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A	N/A N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements 	—	—	(Restaurant at Ground Floor only)

215

M/S Spinns Restaurant is running at G-2A & G-2B, ground floor only of Sonia PVR complex, Vikaspuri, New Delhi 110018

	<ul style="list-style-type: none"> Upper floors 	—	—	(Restaurant at Ground Floor only)
5.	Fire Extinguishers (Restaurant at Ground Floor only)			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	Four no's / floor ABC/CO2	Provided	M/R
			Provided	M/R
		ISI marked	ISI marked	M/R
6.	First-Aid Hose Reels (Restaurant at Ground Floor only)			
	<ul style="list-style-type: none"> Total numbers on ground floor Length of hose reel hose Nozzle diameter 	one 30 mtrs 5 mm	Provided	M/R
			Provided	M/R
			Provided	M/R
7.	Automatic fire detection and alarming system (Restaurant at Ground Floor only)			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke & Heat	Provided	M/R
		—	G. Floor	M/R
		—	—	—
		Required	Provided	M/R
			Near exits	M/R
8.	MOEFA	Required	Provided	M/R
9.	Public Address System	Required	Provided	M/R
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	—	—	(Restaurant at Ground Floor only)
		Required	Provided	M/R
		N/A	N/A	N/A
11.	Internal Hydrants (Restaurant at Ground Floor only)			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants Hose Box 	100mm	Provided	M/R
		One	Provided	M/R
		One	Provided	M/R
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	—	—	—
		—	—	—
13.	Pumping Arrangements (common with sonia PVR complex)			
	<ul style="list-style-type: none"> Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/Manual Stopping 			
		2280 LPM	Provided	M/R
		70 mtrs	Provided	M/R
		01	Provided	M/R
		220 LPM	Provided	M/R
		70 mtrs	Provided	M/R
		2280 LPM	Provided	M/R
		70 mtrs	Provided	M/R
		Required	Provided	M/R

N/16

M/S Spinns Restaurant is running at G-2A & G-2B, ground floor only of Sonia PVR complex, Vikaspuri, New Delhi 110018

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	Required	Provided	M/R
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive Water Storage for fire fighting (common with sonia PVR complex)			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	130000 Ltrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
		10000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts. (Restaurant at Ground Floor only)			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	Required	Provided	M/R
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	N/A	N/A

N/7

M/S Spinns Restaurant is running at G-2A & G-2B, ground floor only of Sonia PVR complex Vikaspuri, New Delhi 110018

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F6/DFS/MS/EH/2011/1989 dated 12.08.2011 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Note: - The Photocopy of Fire Safety Certificate No. F6/DFS/MS/Cinema/2014/1201 dated 02.06.2014 of PVR, Vikaspuri, New Delhi- 110018 situated in same complex having common fire fighting system is placed at C-6.

Signature of Inspecting Officer

Name:- S.K. Tomar

Designation:- Divisional Officer

Signature of Inspecting Officer

Name:- Sandeep Duggal

Designation:- Asstt. Divisional Officer