

No F6/DFS/MS/Auditorium/2014/NO2/1121 Dated: 03/08/14

FIRE SAFETY CERTIFICATE

Certified that the **Abhimanch Auditorium, NSD located at, Bhawalpur House Bhagwandass Road, New Delhi** comprises of Ground floor & first floor was granted NOC by this department vide letter No. F6/DFS/MS/2011/1273 dated 22-06-2011. The premises was re-inspected by the officer concerned of this department on 28-08-2014 in the presence of Mr. S.Chakarvarti (Manager) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of class **Group D "Assembly Building" Sub Division D-2** floor with effect from 03/08/2014 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ... 03/08/14 at New Delhi by.

(Dr. G. C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph -011-23414333

G. C. Misra

Copy to:-

1. The Joint. Commissioner of Police(Lic), First Floor, P.S. Defence Colony New Delhi- 110049 w.r.t. letter no 4691-95/Joint. C.P./Lic(H)/ dated New Delhi 30-01-2014.
2. Mr. S.Chakarvarti (Manager), Abhimanch Auditorium, NSD located at, Bhawalpur House Bhagwandass Road, New Delhi.
3. Ramkishan (Registrar) National School of Drama Located at Bhawalpur House Bhagwandass Road, New Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Abhimanch Auditorium, NSD located at, Bhawalpur House,
Bhagwandass Road, New Delhi.
2. Type of Occupancy : Assembly Building (Ground & first floor)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2011/1273 dated 21/06/2011
5. Fire Safety directives Letter No. : NA
6. Date of inspection : 28/08/2014
- 7 Name of the Inspecting Officer : Sh. M. K. Sharma (ADO/CC)
- 8 Name and designation of Officer
from the building side : Mr. S. Chakarvarti (Manager)
- 9 Year of Construction : 1989
10. Applicant's letter No. : No. 4691-95/Joint C.P./Lic.(Amst.) dated Delhi the 30/01/14.
Old Case

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	9 Mtr. 4.5 Mtr. NA	12 Mtr. 4.5 Mtr. NA	MR MR NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	2 Nos. NA	2 Nos. NA	MR NA
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper floors • Basements 	1.0 & 0.65 Mtr. Existing NA	1.05 & 0.65 Mtr. Existing NA	MR NA NA
	c. Protection of exits			
		NA	NA	NA

	<ul style="list-style-type: none"> • Fire check door • Pressurization 	NA	NA	NA
	d. No of continuous staircase to terrace	2 Nos.	2 Nos.	MR
	e. Width Of Corridor	NA 1.50 Mtr.	NA 1.60 Mtr.	NA MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door 	NA	NA	NA
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	NA	NA	NA
	<ul style="list-style-type: none"> • Water Curtain 	NA	NA	NA
	<ul style="list-style-type: none"> • Fire Dampers 	NA	NA	NA
4	Smoke managements System			
	<ul style="list-style-type: none"> • Basements 	NA	NA	NA
	<ul style="list-style-type: none"> • Upper floors 	12 ACPH	NATURAL	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	20 Nos.	22 Nos.	MR
	<ul style="list-style-type: none"> • Types 	ABC, CO ₂ , Wco ₂	ABC, CO ₂ , Wco ₂	MR
	<ul style="list-style-type: none"> • IS marking 	Required	Provided	MR
6	First – Aid Hose Reels			
	<ul style="list-style-type: none"> • Total numbers on each floor 	03	03	MR
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 Mtr.	30 Mtr.	MR
	<ul style="list-style-type: none"> • Nozzle diameter 	05 MM	05 MM	MR
7	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> • Type of detectors 	Required	Provided	MR
	<ul style="list-style-type: none"> • Location of Main Panel 	At G. floor	At G. floor	MR
	<ul style="list-style-type: none"> • Location of Repeater Panel 	NA	NA	NA
	<ul style="list-style-type: none"> • Alternate source of power 	Required	Provided	MR
	<ul style="list-style-type: none"> • Hooters' Location 	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10	Automatic Sprinkler			

	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA	NA	NA
		Required	Provided	MR
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 MM	100 MM	MR
		3 Nos.	3 Nos.	MR
		3 Nos.	3 Nos.	MR
12	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	03	03	MR
		03	03	MR
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head auto Staring/Manual stopping Pump House Access 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
	<ul style="list-style-type: none"> Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	450 LPM	450 LPM 2nos.	MR
		30 Mtr.	30 Mtr.	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive water Storage for fire fighting			
	<ul style="list-style-type: none"> Under ground tank capacity Draw of connection Fire service inlet 	50,000 Ltr.	70,000 Ltr.	MR
		Required	Provided	MR
		Required	Provided	MR

N/28

	<ul style="list-style-type: none"> Access to tank Overhead Tank capacity 	Required 10,000 Ltr.	Provided 10,000 Ltr.	MR MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of lift lobby 	NA	NA	NA
	<ul style="list-style-type: none"> Communication in lift Car 	NA	NA	NA
	<ul style="list-style-type: none"> Fireman's Grounding Switch 	NA	NA	NA
	<ul style="list-style-type: none"> Lift Signage 	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	<ul style="list-style-type: none"> Total area 	NA	NA	NA
	<ul style="list-style-type: none"> Location 	NA	NA	NA
19	Fire control room			
	<ul style="list-style-type: none"> Detector system panel 	NA	NA	NA
	<ul style="list-style-type: none"> Flow Switch Panel 	NA	NA	NA
	<ul style="list-style-type: none"> PA System Panel 	NA	NA	NA
	<ul style="list-style-type: none"> Batter backup 	NA	NA	NA
	<ul style="list-style-type: none"> Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	Co2 & DCP	MR

The fire protection systems provided in the building were randomly tested, checked randomly and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. F6/DFS/MS/2011/1275 dated 21/06/2011 renewal under rule 35 of the Delhi Fire Service rules 2010, is recommended.

Signature of the Inspecting Officer

Name :- Sh. M. K. Sharma
Designation :- A. D.O. (CC)

1-9-14
813
KOP

DA (P.O.) AMR