

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F.6/DFS/MS/ School/2014/W2/1167

Dated: 11/09/2014

FIRE SAFETY CERTIFICATE

Certified that Delhi Heritage School, Main Kanjhawala Road, Sect-22, Rohini, Delhi-110085 comprised of Basement + Ground + Three upper floor owned/occupied by Delhi Heritage School have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by the officer concerned of Fire Service on 01/09/2014 in the presence of Mrs. Vibha Gupta and that the building / premises is fit for occupancy of Group Class B (Educational) building with effect from 11/09/2014 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 11/09/14 at New Delhi by


(VIPIN KENTAL)
Dy. Chief Fire Officer
Ph: 011-23846352

Copy to:

1. The Principal, Delhi Heritage School, Main Kanjhawala Road, Sect-22, Rohini, Delhi-110085
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building :Delhi Heritage School, Main Kanjhawala Road, Sect-22,
Rohini, Delhi-110085 (B +G + 3)
 2. Type of Occupancy : Education
 3. Type of Case : New Case
 4. Details of previous NOC : nil
 5. Fire Safety directives letter No : Director of Edu. Dated 01/03/2011
 6. Date of inspection : 01/09/2014
 7. Name of the Inspecting Officers : DO(NW) & ADO (Rohini)
 8. Name and designation of officers
from the building side : Vibha Gupta
 9. Year of Construction : 2004
 10. Applicant's letter No. : Nil dated 28/07/2014
- PA-2847 m² CA-6039 Sq.m NOS- 130 NOT-1+10 CR-50 (in use on GF 6)**

	Minimum Standards on fire prevention and fire safety U/R 33	Director of Edu. Dated 01/03/2011	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	M/R
	• Gate width	--	--	--
	• Width of internal road	--	--	--
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	M/R
	• Basements	02	B to G-06nos G + 3 -02 nos	M/R
	b. Width of staircases			
	• Upper Floors	1.5 mtr x 1 0.75 mtr x 1	1) 165 cms 2) 91cms	M/R (old paper submitted)
	• Basements	-do-	5 more than 1.5 mtr 1 more than 1.25 mtr	M/R
	c. Protection of exits			
	• Fire check door	N/R	--	--
	• Pressurization	N/A	--	--
	e. No. of continuous staircases to terrace	01	02	M/R

	g. Width of Corridor	--	--	--
	h. Door Size	1 mtr	110 cms	M/R
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	--	--	--
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	Exhaust fan provided	M/R ✓
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour		N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	21	21	M/R
	<ul style="list-style-type: none"> • Types 	ISI marked	10 Co2, 11 ABC	M/R ✓
	<ul style="list-style-type: none"> • IS marking 		yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	One	P	M/R
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	P	M/R
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	P	M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	N/A
8	MOEFA	R	P	M/R
9	Public Address System.	R	P	M/R
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	R	P	M/R ✓
	<ul style="list-style-type: none"> • Upper Floor 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	N/A

11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	4''	P	M/R ✓
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	P	M/R ✓
	<ul style="list-style-type: none"> Hose Box 	01	P	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	01	P	M/R
	<ul style="list-style-type: none"> Hose Box 	01	P	M/R
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 			
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	900 LPM	P	M/R ✓
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 m	P	M/R
	<ul style="list-style-type: none"> ➤ Power Supply 	R	P	M/R
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 			
	<ul style="list-style-type: none"> ➤ Draw-off connection 	R	P	M/R
	<ul style="list-style-type: none"> ➤ Fire service inlet 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Access to tank 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Overhead Tank capacity 	15,000	15,000	M/R ✓
15	Exit Signage.			
		R	P	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	--	--	--

	<ul style="list-style-type: none"> • Pressurization of Lift lobby 	--	--	--
	<ul style="list-style-type: none"> • Communication In lift Car 	--	--	--
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	N/A
17	Standby power supply	R	P	M/R
18	Refuge Area.			
	➤ Total Area	--	--	--
	➤ Location	--	--	--
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	N/A
	<ul style="list-style-type: none"> • PA System Panel 	R	P	M/R
	<ul style="list-style-type: none"> • Batter backup 	R	P	M/R
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

Note: The school management has provided documentary evidence regarding year of construction as 2005. The case is dealt under the circular issued by Director of Education dated 01/03/2011. One staircase of 1.5 mtr and one of 0.75 mtr is required and the staircase meets the requirement.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Deep (W2)

Designation

Signature of the Inspecting Officer

Name

[Signature]
5/9/14

Designation

[Handwritten note]