

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


NO. F6/DFS/MS/School/2014/SZ/ 1111

DATED: 02/09/14

FIRE SAFETY CERTIFICATE

Certified that the Delhi Jain Public School, 12 ,Railway Road , Palam Colony, New Delhi – 110077, comprised of ground plus two upper floors was granted NOC by this department vide letter No.F6/DFS/MS/2011/738 Dated. 21.4.2011. The management have deemed complied with the fire prevention and fire safety requirements in accordance with circular No.F.16/Estate//CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt. of NCT of Delhi and verified by the officer concerned of fire service on 20.8.2014 in presence of Smt. Sunita Panrar (Principal) and that the school building is fit for occupancy of class B, 'Educational Building" with effect from...02/09/14.....for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, and subject to conditions printed overleaf.

Issued on ...02/09/14..... at New Delhi by



(Dr. GC Misra)  
Chief Fire Officer  
Ph.011-23414333

GC



Copy to:

1. The Dy. Director (Education), G.N.C.T. of Delhi, Old Secretariat, New Delhi-54
2. The Principal, Delhi Jain Public School, 12, Railway Road, Palam Colony, New Delhi – 110077.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of the Licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this **Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37)** along with a copy of the certificate, six months prior to its expiry.

## INSPECTION REPORT

1	Name & address of the building	Delhi Jain Public School, 12 , Railway Road, Palam Colony, New Delhi-110077.		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	Renewal		
4	Details of previous NOC	F6/DFS/MS/2011/738 Dated 21.4.2011		
5	Fire safety directives letter No	Directorate of Education:F/16/Estate/CC/fire Safety/2011/3298-3398, Dated 1.3.2011		
6	Date of inspection	20.08.2014		
7	Name of the inspecting Officers	ADO S.P. Bhardwaj		
8	Name and designation of officers from the building side	Mrs. Sunita Panwar (Principal)		
9	Year of construction	1973	Ground+Two upper floor	
10	Applicant's letter No.	Nil 8.8.2014		
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	6 Mtrs.	30 Mtrs.	MR
	2) Gate width	Approachable	5 Mtrs.	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	4 Nos.	4 Nos.	MR
	2. basements	N/A	N/A	N/A
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtrs.	1.5 & 1 Mtr.	MR
	2. basements	N/A	N/A	N/A
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	2 Nos.	MR
	e. Width of corridor	1.25 Mtrs.	1.5 to 3 Mtrs.	MR
	f. Door size	1 Mtr.	1 Mtr.	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement		N/A	N/A
	upper floors	12 a/c charge	Natural Vent.	MR
5	<b>Fire Extinguishers</b>			
	total numbers	One No. Co2 OR ABC for every 300 Sq.Mtrs.	15 Nos.	MR
	Types	ISI Marked	Co2 & Wco2	old case
	ISI marking		Provided	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	3 Nos. each floor	3 Nos.each floor	MR
	Length of Hose reel hose	30 m	30 Mtrs.	MR
	Nozzle Diameter	5 mm	5 mm	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	Required	Provided	old case
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	N/A	N/A	N/A
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	Required	Provided	old case
	Number of Hydrants per floor	Required	3 Nos.each floor	old case
	hose Box	Required	3 Nos.each floor	old case
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b.Head of main pump	N/A	N/A	N/A
	c.Number of main pumps	N/A	N/A	N/A
	d.jockey pump out put	N/A	N/A	N/A
	e.jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g.Stanby Pump head	N/A	N/A	N/A
	h.Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2.Terrace level</b>			
	a. Discharge of pump	450, 150 Lpm.	450, 150 LPM	old case
	b. head of the pump	40 Mtrs.	40 Mtrs.	old case
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	MR
	c.Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5000 Lts.	5000 Ltrs.	old case
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	MR
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

	<b>Standby power supply</b>	N/A	N/A	N/A
<b>18</b>	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
<b>19</b>	<b>Fire control room</b>			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
<b>20</b>	<b>Special Fire Protection systems for protection of special risks, if any:</b>	<b>Co2 Provided</b>		

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety required under the rules , renewal of FSC issued vided letter no.F6/MS/DFS/2011/738 Dated 21.4.2011 is recommended under rules 35 of the Delhi Fire Service Rules 2010.

Accordingly DFA is put up for approval and signature please.

  
Signature of the Inspecting Officer

Name S.P. Bhardwaj

Designation ADO (Dwarka)