

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/EH/2014/W2/1165

Dated: 11 / 09 / 2014

FIRE SAFETY CERTIFICATE

Certified that Embassy Restaurant, 13, Ali Pur, Road, Civil Line, Delhi 110054 comprised of Ground + Mezz. Floor with 77 no's of seats of a four storied building owned / occupied by Sh. Sunil Malhotra was granted NOC by this department vide letter no F-6/DFS/MS/2011/EH/ 1256 dated 16/06/2011. The premises was re-inspected by the officers concerned of this department on 28/ 08 / 2014 in presence of Mr. Negi (Manager) and found that the building have deem complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 11 / 09 / 2014 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of Delhi Fire Service Rules, 2010.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 11 / 09 / 14 at New Delhi by

<sup>16</sup>  
<sup>10/9/14</sup>  
(VIPIN KENTAL)  
Dy. Chief Fire Officer  
Ph: 011-23846352

Copy to:

1. The Dy Health Officer, North Delhi Municipal Corporation, Health Department, Civil Zone, 16, Rajpur Road, Delhi 110054 for information
2. The authorized signatory, Embassy Restaurant, 13, Ali Pur, Road, Civil Line, Delhi 110054

**INSPECTION REPORT**

1. Name & address of the building: Embassy Restaurant at 13, Ali Pur Road, Delhi.
2. Type of Occupancy : Restaurant (Restaurant with 77 seats at Ground and
3. Type of Case : Renewal Mezzanine floor of four storied building)
4. Details of previous NOC : F6/DFS/MS/2011/EH/1256 dated 16/06/2011
5. Fire Safety directives letter No : NBC Part IV
6. Date of inspection : 28/08/2014
7. Name of the Inspecting Officers : DO (NW)
8. Name and designation of officers  
from the building side : Mr. Negi (Manager)
9. Year of Construction : 2006
10. Applicant's letter No. : DHO/CLZ/2014/1036 Dated 08/08/2014 from MCD

	Minimum Standards on fire prevention and fire safety U/R 33	NBC / BBL Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	Accessible	Accessible	M/R
		----	----	----
		----	----	----
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	02 --	02 --	M/R --
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	1.5 mtr --	1) 105cm (2) 75 cm --	M/R --
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	-- --	-- --	-- --
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	--	--	--
	h. Door Size	Old case	Old case	Old case

Embassy Restaurant at 13, Ali Pur Road, Delhi.

3	<b>Compartmentation.</b>			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	--	--	--
	• Fire Rating of shaft door	--	--	--
	• Water Curtain	--	--	--
	• Fire Dampers	--	--	--
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	Exhaust fan provided	M/R
	• Upper floors	12 a/c per hour	P	M/R
5.	<b>Fire Extinguishers</b>			
	• Total numbers	06	08	M/R
	• Types	ISI marked	WCO <sub>2</sub> & CO <sub>2</sub>	M/R
	• IS marking		Yes	M/R
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	R	P	M/R
	• Length of hose reel hose	30 m	P	M/R
	• Nozzle diameter	5 mm	P	M/R
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N.A	N.A	N.A
	• Location of Main Panel	--	--	--
	• Location of Repeater Panel	--	--	--
	• Alternate source of power	--	--	--
	• Hooters' Location	--	--	--
8	<b>MOEFA</b>	R	P	M/R
9	<b>Public Address System.</b>	N.A	N.A	N.A
10	<b>Automatic Sprinkler System.</b>			
	• Basement	--	--	--
	• Upper Floor	R	P	M/R
	• Sprinkler above false ceiling	--	--	--
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	04"	P	M/R
	• Number of hydrants per floor	01	01	M/R
	• Hose Box	01	01	M/R

12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	01	P	M/R
	• Hose Box	01	P	M/R
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	--	--	--
	➤ Head of Main pump	--	--	--
	➤ Number of main pumps	--	--	--
	➤ Jockey Pump out put	180 LPM	P	M/R
	➤ Jockey pump head	--	--	--
	➤ Standby Pump out put	--	--	--
	➤ Standby Pump Head	--	--	--
	➤ Auto Starting/ Manual stopping	--	--	--
	➤ Pump House Access	--	--	--
	• Terrace level			
	➤ Discharge of pump	450 LPM	P	M/R
	➤ Head of the pump	40 m	P	M/R
	➤ Power Supply	R	P	M/R
	➤ Auto Starting of pump	R	P	M/R
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	--	--	--
	➤ Draw-off connection	R	P	M/R
	➤ Fire service inlet	R	P	M/R
	➤ Access to tank	--	--	--
	• Overhead Tank capacity	10,000 ltr	10,000 ltr	M/R
15	<b>Exit Signage.</b>	R	P	M/R
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	--	--	--
	• Communication In lift Car	--	--	--
	• Fireman's Grounding Switch	--	--	--
	• Lift Signage	--	--	--
17	<b>Standby power supply</b>	R	125 KVA	M/R

Embassy Restaurant at 13, Ali Pur Road, Delhi.

18	<b>Refuge Area.</b>			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	--	--	--

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures as required under the rules the NOC/<sup>FSC</sup> issued vide letter no. **F6/DFS/MS/2011/EH/1256 dated 16/06/2011** Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

*Defto (1/2)*

Designation

*[Signature]*  
3/9/14  
SS Tuli

553/DA  
9/9/14