

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/school/2014/w2/1106

Dated: 02/08/2014

**FIRE SAFETY CERTIFICATE**

Certified that **G. R. M. Public School, Khasra No-88/23/2, Shiv Vihar, Karala, Delhi 110081** comprised of **Ground + One upper floor** owned / occupied by **G. R. M. Public School** has already been issued fire safety certificate vide letter no. **F.6/DFS/MS/2010/3058** dated **01/11/2010**. The premises was re-inspected by the officer from this department on dated **26/07/2014** in the presence of **Smt Manju Lata (Principal)** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **Circular issued by Director of Education letter dated 17/01/2005** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from 02/08/2014 for a period of **three years**, subject to compliance of the conditions mentioned below:

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 02/08/14 at New Delhi by

  
(Dr. G.C. Mishra)  
Chief Fire Officer  
Ph: 011-23414333

**Copy to:**

1. The Principal, G. R. M. Public School, Khasra No-88/23/2, Shiv Vihar, Karala, Delhi 110081.
2. The Director of Education, Old Secretariat, Delhi

N-7

Gr. 7 one floor

**INSPECTION REPORT**

1. Name & address of the building : G.R.M. Public School Kh. No. 88/23/2 Shalimar Karala Delhi-81
  2. Type of Occupancy : Educational
  3. Type of Case : New case/ Renewal
  4. Details of previous NOC : F-6/DFS/MS/2010/3058 dt. 01/11/2010
  5. Fire Safety directives letter No : Dir. of Edu. 2005
  6. Date of inspection : 26.7.14
  7. Name of the Inspecting Officers : ADO (RWS)
  8. Name and designation of officers from the building side : Smt Manjya Lata, Principal
  9. Year of Construction : 2010
  10. Applicant's letter No. : Lt No Nil dt. 15.7.14
- Plot area- 1210m<sup>2</sup> Covered area- 527m<sup>2</sup> No's of student- 390 No's of class room- 9  
7 room other purpose

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	—	—	—
	• Upper Floors	2	2	MR ✓
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper Floors	1.50m <sup>2</sup> each	1.60 & 1.65m <sup>2</sup>	MR ✓
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	1m <sup>2</sup>	1.03m <sup>2</sup>	MR ✓
3	<b>Compartmentation.</b>			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	• Total numbers	SABC	5	MR
	• Types		ABC	MR

M-8

	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30 m 5 mm	P P	MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	N/A		
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N/A		
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	N/A		
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/A		
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	N/A		
		450 GPM	450 GPM	MR
		40M	40M	MR
		—	—	—
		—	—	—
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>	N/A		
		2500 lts	2500 lts	MR

N-9

	<ul style="list-style-type: none"><li>• Pressurization of Lift lobby</li><li>• Communication In lift Car</li><li>• Fireman's Grounding Switch</li><li>• Lift Signage</li></ul>			
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"><li>• Detector System Panel</li><li>• Flow Switch Panel</li><li>• PA System Panel</li><li>• Batter backup</li><li>• Building Floor Plans</li></ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. P-4/DPS/MS/2010/3058 dated 1-11-2010 Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name

Designation

*[Handwritten Signature]*  
11/8/14

*[Handwritten Designation]*