

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

No. F.6/DFS/MS/2014/MD2/1192

Dated: 12/9/14

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls/Boys Sec. School at Kondli Gharoli, Mayur Vihar -III, Delhi-96, owned/occupied by Govt. Girls/Boys Sec. School, comprised of ground floor in pota cabin only was issued FSC vide letter no. No.F.6/DFS/MS/School/2011/3292 dated 01.12.2011. The school building was re-inspected by the officer concerned of this department on 27.08.2014 in the presence of Smt. Komal Bala Verma (HOS) of school and found that the school building have deemed complied with the fire prevention and fire safety requirements in accordance with the circular no.F.16/Estate/CC/FS/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education and found that the building is fit for occupancy class B "Educational Building" with effect from ..12.19.14... for a period of three years, subject to conditions printed overleaf.

Issued on ..12.19.14..... at New Delhi by



(Dr.G.C.Misra)  
Chief Fire Officer  
Ph.011-23414333

OK f

To,

HOS  
Govt. Girls Sec. School  
Kondli Gharoli, Mayur Vihar -III, Delhi-96,

Copy to:-

1. The Dy. Director of Education  
D-Block, Anad Vihar, Delhi.
2. The Principal  
Govt. Boys Sec. School  
Kondli Gharoli, Mayur Vihar -III, Delhi-96,

**- Conditions -**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in good working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety certificate can not be treated in any case for regularizations of unauthorized construction if any.
- 6 . "The owner /occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J'[sub rule(1) of rule 37] along with a copy of this certificate,six months prior to its expiry"
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building: GGSS Kondli Gharoli, Mayur Vihar-III, Delhi-96.
2. Building is comprised of : Ground floor only (Pota Cabin)
3. Type of Occupancy : Educational
4. Type of Case : Renewal
5. Details of Previous FSC : F.6/DFS/MS/School/2011/3292 dated 01.12.11
6. Fire Safety Circular No. : F.16/Estate/CC/FS/2011/3298 to 3398  
dated 1.3.11
7. Date of Inspection :27.08.2014
8. Name of the Inspecting officers : DO Virendra Singh
9. Name and designation of  
Officer from the building side : Smt. Komal Bala Verma (HOS).
10. Year of Construction :2003
11. 11.Applicant's letter No : Dated 11.08.2014


NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	06 Mtrs.	10 Mtrs.	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
	e. No. of continuous staircases to terrace	N/A	N/A	N/A
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper floor</li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> </ul>	06 Nos.	13 Nos.	MR
		ABC & Co2	ABC & Co2	MR
	<ul style="list-style-type: none"> <li>• IS marking</li> </ul>	ISI marked	ISI marked	MR

6	First-aid-Hose Reels.			
	Total numbers of each floor			
	• Length of hose reel hose	N/A	N/A	N/A
	• Nozzle diameter	N/A	N/A	N/A
		N/A	N/A	N/A
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
8	MOEFA	N/A	N/A	N/A
9	Public address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants	N/A	N/A	N/A
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
12	Yard Hydrants.	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.	N/A	N/A	N/A
	• Ground Level	N/A	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level	N/A	N/A	N/A
	➤ Discharge of pump	N/A	N/A	N/A
	➤ Head of the Pump	N/A	N/A	N/A
	➤ Power supply	N/A	N/A	N/A
	➤ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.	N/A	N/A	N/A
	• Underground tank capacity	N/A	N/A	N/A
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage.	N/A	N/A	N/A

16	Provision of Lifts.	N/A	N/A	N/A
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	N/A	N/A	N/A
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room	N/A	N/A	N/A
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules. The FSC issued vide letter no. F.6/DFS/MS/School/2011/3292 Dated 01.12.11 renewal under the circular no. F.16/Estate/CC/FS/2011/3298 to 3398 dated 1.3.11 is recommended.

  
 Signature of the Inspecting Officer  
 Name:-Virendra Singh  
 Designation:-DO (ED)

DCFO(NDZ)