

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2014/W2/1140

Dated: 05/09/2014

FIRE SAFETY CERTIFICATE

Certified that Govt. Co-ed Sec. School, P-Block, Sultan Puri, Delhi - 110086 comprised of 03 Blocks, A Block G.F + F.F, B & C Block G.F only owned/occupied by Govt. Co-Edu Sec. School, have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 23/08/2014 in the presence of Mrs. M. Kohli (Vice-Principal) and that the building / premises is fit for occupancy of Educational building with effect from 05/09/2014 for a period of three years, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:


- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 7 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 8 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in

Issued on 05/09/14 at New Delhi


(Dr. G.C. Mishra)
Chief Fire Officer
Ph: 011-23414333

Copy to:

1. The Principal, Govt. Co-ed Sec. School, P-Block, Sultan Puri, Delhi - 110086
2. The Director of Education, Old Secretariat, Delhi



Total Three Blocks - A-Block - G.F + FF, Band C Blocks - G.F. only ✓

INSPECTION REPORT

1. Name & address of the building: Govt Co-ed. Sr. Sec. school, P-Block,
2. Type of Occupancy : Sultan Luri, Delhi-86
3. Type of Case : Educational
4. Details of previous NOC : New Case / Renewal
5. Fire Safety directives letter No : Circular of the director of Edn
6. Date of inspection : 23-8-14
7. Name of the Inspecting Officers : N. P. Sharma
8. Name and designation of officers
from the building side : Mrs M. Kohli - (Vice Principal)
9. Year of Construction : 1996
10. Applicant's letter No. : 1587

Plot area:- 4171 m² Covered area:- 1745 m² No.'s of students:- 2027 No's of classrooms:- 27

Minimum Standards on fire prevention and fire safety U/R 33		Dir. of Edu BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	
	• Upper Floors	02	02	MR ✓
	• Basements	—	—	MR ✓
	b. Width of staircases	R	P	
	• Upper Floors	1.5 mtr	1-1.45 mtr each	MR ✓
	• Basements	—	—	MR ✓
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size <u>Two doors in each classroom</u>	one mtr	1.10 mtr x 2	MR ✓

3	Compartmentation.	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	—	—	—
4	Smoke Management System.	NA		
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	— —	— —
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	one @ 300m ² 10 ISI marked	25 ABC type yes	MR ✓ MR ✓ MR ✓
6	First-Aid Hose Reels.	NA		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	— — —	— — —
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— — — — —	— — — — —	— — — — —
8	MOEFA	—	—	—
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	— — —	— — —	— — —
11	Internal Hydrants	NA		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	— — —	— — —	— — —

12	Yard Hydrants.	NA		
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	—	—	—
13	Pumping Arrangements.	NA		
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pum 	—	—	—
14	Captive Water Storage for fire fighting.	NA		
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—	—	—
15	Exit Signage.	NA		
16	Provision of Lifts.	NA		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
7	Standby power supply	—	—	—

18	Refuge Area.	NA		
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	NA		
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer  23814

Name N.P. Sharma

Designation ADO R 1

Signature of the Inspecting Officer

Name

Designation