

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F.6/DFS/MS/school/2014/W2/1139

Dated: 05/09/2014

FIRE SAFETY CERTIFICATE

Certified that **Govt. Girls Secondary School, Azad Pur Village, Delhi-110033** comprised of **Ground Floor + First Floor** owned / occupied by **Govt. Girls Secondary School** has already been issued fire safety certificate **vide letter no. F.6/DFS/MS/2011/2102 Dated 26/08/2011.** The premises was re-inspected by the officer from this department on dated **19/08/2014** in the presence of **Mrs. Manju Khattar** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore complied with the requirements of **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from 05/09/2014 for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / occupier shall apply for renewal of this fire safety Certificate to the Director of Form 'J' [sub rule (1) 37] along with a copy of this Certificate, Six month prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 05/09/14 at New Delhi by


(Dr. G.C. Mishra)
Chief Fire Officer
Ph: 011-23414333

Copy to:

1. The Principal, Govt. Girls Secondary School, Azad Pur Village, Delhi-110033
2. The Director of Education, Old Secretariat, Delhi



NIS
one block - GR + FF

INSPECTION REPORT

1. Name & address of the building: Govt Girls Secondary School, Azadpur
 2. Type of Occupancy: Village, Delhi-33
 3. Type of Case: Educational
 : New Case / Renewal
 4. Details of previous NOC: P-6/DFS/MS/2011/2102 dt 26-8-11
 5. Fire Safety directives letter No: Circular of the director of Education 1311
 6. Date of inspection: 19-8-14
 7. Name of the Inspecting Officers: N.P. Sharma
 8. Name and designation of officers
 from the building side: Mrs Manju Khattar
 9. Year of Construction: 1970
 10. Applicant's letter No: GGSS/APV/2014/466/4/8/14 dt 02-8-14

Plot area:- 338m² Covered area:- 1997m² No.'s of students:- 1345 No's of classrooms:- 17

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBE/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	-	-	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR
	• Upper Floors	02	03	MR
	• Basements	-	-	-
	b. Width of staircases	R	P	MR
	• Upper Floors	1.5 mtr	one - 1.3 mtr two nos - 1.6 mtr each	MR
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size <u>Two doors in each C.R.</u>	1. mtr	1 mtr	MR

3	Compartmentation.	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
4	Smoke Management System.	NA	NA	NA
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	-	-
		12 a/c per hour	-	-
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	one @ 300ml 09 ISI marked	10 ABC yes	MR MR MR
6	First-Aid Hose Reels.	NA		
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	-	-
			-	-
			-	-
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
8	MOEFA	-	-	-
9	Public Address System.	-	-	-
10	Automatic Sprinkler System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	-	-	-
		-	-	-
		-	-	-
11	Internal Hydrants	NA		
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	-	-	-
		-	-	-
		-	-	-

M/7

12	Yard Hydrants.	NA		
	• Total number of hydrants	-	-	-
	• Hose Box	-	-	-

13	Pumping Arrangements.	NA		
	• Ground Level			
	> Discharge of main Pump			
	> Head of Main pump			
	> Number of main pumps			
	> Jockey Pump out put			
	> Jockey pump head			
	> Standby Pump out put			
	> Standby Pump Head			
	> Auto Starting/ Manual stopping			
	> Pump House Access			
	• Terrace level			
	> Discharge of pump			
	> Head of the pump			
	> Power Supply			
	> Auto Starting of pum			

14	Captive Water Storage for fire fighting.	NA		
	• Underground tank capacity	-	-	-
	> Draw-off connection	-	-	-
	> Fire service inlet	-	-	-
	> Access to tank	-	-	-
	• Overhead Tank capacity	-	-	-

	Exit Signage.	-	-	-
	Provision of Lifts.	NA		
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
	• Standby power supply	-	-	-

N/8

18	Refuge Area.	NA		
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	NA		
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter no. P-6/OPS/MS/2011/2102.....Dated 26/8/2011. Renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer [Signature] 19-8-14

Name N. P. Sharma

Designation AO & R.

Signature of the Inspecting Officer

Name

Designation