

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2014/W2/114

Dated: 05/09/2014


FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girls Secondary School, HaiderPur, Delhi - 110088** comprised of **Ground + First Floor** owned/occupied by **Govt. Girls Secondary School** has already been issued fire safety certificate vide letter **no. F-6/DFS/MS/School/2011/3296 dated 01/12/2011.** The premises was re-inspected by the officer from this department on dated **22/08/2014** in the presence of **Mrs. Harsh Pahwa** and observed that all the fire prevention & fire safety arrangements as provided in the premises found in good working condition. The premises have therefore deemed complied with the requirements of **circular issued by Director of Education letter dated 01/03/2011** and the building / premise is fit for occupancy of **Group Class B (Educational)** with effect from **05/09/2014** for a period of **three years**, subject to compliance of the conditions mentioned below:

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction.
- 7 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
- 8 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 05/09/14 at New Delhi


(Dr. G.C. Mishra)
Chief Fire Officer
Ph: 011-23414333

Copy to:

1. The Principal, Govt. Girls Secondary School, HaiderPur, Delhi - 110088
2. The Director of Education, Old Secretariat, Delhi



INSPECTION REPORT

1. Name & address of the building: Govt Girls Secondary School
 2. Type of Occupancy: Haiderpur - Delhi
 3. Type of Case: Educational ✓
 4. Details of previous NOC: Case / Renewal
 5. Fire Safety directives letter No: F-6/DPS/ms/school/2011/3296 dt 01-12-11
 6. Date of inspection: Circular of the Director of Edn 1-311
 7. Name of the Inspecting Officers: 22-8-14
 8. Name and designation of officers: N.P. Sharma
 from the building side: Mrs Harsh Pathwa
 9. Year of Construction: 1986
 10. Applicant's letter No: HP/GGSS/14/166 dt 06-8-14

Plot area: 4600m² Covered area: 1900 m² No.'s of students: 1068 No.'s of classrooms: 16

	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu BBL/NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR ✓
	• Gate width	—	—	—
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	P	MR ✓
	• Upper Floors	02	02	MR ✓
	• Basements	—	—	—
	b. Width of staircases	R	P	MR ✓
	• Upper Floors	1.5mtrs	1.5mtr x 2	MR ✓
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	—	—	—
	g. Width of Corridor	—	—	—
	h. Door Size	one meter	one mtr x 2	MR ✓

3	Compartmentation.	NA		
	• Fire check door	—	—	—
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4	Smoke Management System.	NA		
	• Basements	30 a/c per hour	—	—
	• Upper floors	12 a/c per hour	—	—
5	Fire Extinguishers			
	• Total numbers	one @ 300m ²	13	MR ✓
	• Types	10 ISI marked	ABC	MR ✓
	• IS marking		yes	MR ✓
6	First-Aid Hose Reels.	NA		
	• Total numbers on each floor		—	—
	• Length of hose reel hose	30 m	—	—
	• Nozzle diameter	5 mm	—	—
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	—	—	—
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooter Location	—	—	—
8	MOEFA	—	—	—
9	Public Address System.	—	—	—
10	Automatic Sprinkler System.	NA		
	• Basement	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11	Internal Hydrants	NA		
	• Size of riser/down-corer	—	—	—
	• Number of hydrants per floor	—	—	—
	• Hose Box	—	—	—

M/7

12	Yard Hydrants.		
	• Total number of hydrants	NA	
	• Hose Box	—	—

13	Pumping Arrangements.		
	• Ground Level	NA	
	➤ Discharge of main Pump	—	—
	➤ Head of Main pump	—	—
	➤ Number of main pumps	—	—
	➤ Jockey Pump out put	—	—
	➤ Jockey pump head	—	—
	➤ Standby Pump out put	—	—
	➤ Standby Pump Head	—	—
	➤ Auto Starting/ Manual stopping	—	—
	➤ Pump House Access	—	—
	• Terrace level	—	—
	➤ Discharge of pump	—	—
	➤ Head of the pump	—	—
	➤ Power Supply	—	—
	➤ Auto Starting of pum	—	—

14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	NA	
	➤ Draw-off connection	—	—
	➤ Fire service inlet	—	—
	➤ Access to tank	—	—
	• Overhead Tank capacity	—	—

	Exit Signage.	—	—
--	----------------------	---	---

	Provision of Lifts.		
	• Pressurization of Lift Shaft	NA	
	• Pressurization of Lift lobby	—	—
	• Communication In lift Car	—	—
	• Fireman's Grounding Switch	—	—
	• Lift Signage	—	—
	Standby power supply	—	—

N/S

Refuge Area.		N A		
> Total Area		—	—	—
> Location		—	—	—
Fire Control Room		N A		
• Detector System Panel		—	—	—
• Flow Switch Panel		—	—	—
• PA System Panel		—	—	—
• Batter backup		—	—	—
• Building Floor Plans		—	—	—
Special Fire Protection Systems for Protection of special Risks, if any:		—	—	—

The fire protection systems provided in the building were test checked and found functional the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and safety measures as required under the rules the NOC issued vide letter no. F-6/OPS/MS/school/2011/3296 Dated 01/12/2011 ~~Renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.~~ under circular issued by DOE dt 1-3-11 is recommended. u

Signature of the Inspecting Officer N.P. Sharma
23-8-14

Name N.P. Sharma

Designation ADO R.

Signature of the Inspecting Officer

Name

Designation